

**SYRACUSE CITY SCHOOL DISTRICT
PSLA and FOWLER HIGH SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	08/15/20 RESULTS (ppb)	08/15/20 ORIGINAL ACTIONS	11/14/20 RESULTS (ppb)	11/14/20 ACTIONS	12/04/20 RESULTS (ppb)	12/04/20 ACTIONS	12/30/20 RESULTS (ppb)	12/30/20 ACTIONS
BUILDING SECTION 'A'												
Rm. 108 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	013	FR-S145	<1.0	None	--	--	--	--	--	--
Rm. 109 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	011	FR-S146	2.1	None	--	--	--	--	--	--
Rm. 111 - Cosmetology Room	Sink	Public Access	006	FR-S148	6.8	None	--	--	--	--	--	--
Rm. 113 - Faculty Lounge	Sink	Secured - SCSD Staff Only	048	FR-S144	1.2	None	--	--	--	--	--	--
Rm. 117 - Safety Classroom	Sink	Public Access	027	FR-S147	13.5	None	--	--	--	--	--	--
Rm. 119 - Home & Careers Room	Sink	Public Access	016	FR-S140	6.1	None	--	--	--	--	--	--
Rm. 119 - Home & Careers Room	Sink	Public Access	019	FR-S141	2.8	None	--	--	--	--	--	--
Rm. 119 - Home & Careers Room	Sink	Public Access	023	FR-S142	4.1	None	--	--	--	--	--	--
Rm. 119 - Home & Careers Room	Sink	Public Access	024	FR-S143	7.8	None	--	--	--	--	--	--
Rm. 121 - Hallway/Corridor	Fountain	Public Access	052	FR-F102	<1.0	None	--	--	--	--	--	--
Rm. 121 - Hallway/Corridor	Fountain	Public Access	053	FR-F103	<1.0	None	--	--	--	--	--	--
Rm. 124 - Boy's Bathroom	Sink	Public Access	056	FR-S134	<1.0	None	--	--	--	--	--	--
Rm. 124 - Boy's Bathroom	Sink	Public Access	057	FR-S135	<1.0	None	--	--	--	--	--	--
Rm. 124 - Boy's Bathroom	Sink	Public Access	061	FR-S136	<1.0	None	--	--	--	--	--	--
Rm. 125 - Girl's Bathroom	Sink	Public Access	049	FR-S137	1.2	None	--	--	--	--	--	--
Rm. 125 - Girl's Bathroom	Sink	Public Access	050	FR-S138	<1.0	None	--	--	--	--	--	--
Rm. 125 - Girl's Bathroom	Sink	Public Access	051	FR-S139	<1.0	None	--	--	--	--	--	--
Rm. 128 - Serving Room	Sink	Secured - SCSD Staff Only	033	FR-S112	9.3	None	--	--	--	--	--	--
Rm. 128C - Kitchen	Sink	Secured - SCSD Staff Only	038	FR-S113	3.6	None	--	--	--	--	--	--
Rm. 128C - Kitchen	Sink	Secured - SCSD Staff Only	042	FR-S114	4.3	None	--	--	--	--	--	--
Rm. 128C - Kitchen	Sink	Secured - SCSD Staff Only	043	FR-S115	2.7	None	--	--	--	--	--	--
Rm. 128C - Kitchen	Sink	Secured - SCSD Staff Only	044	FR-S116	2.1	None	--	--	--	--	--	--
Rm. 128C - Kitchen	Sink	Secured - SCSD Staff Only	045	FR-S117	4.5	None	--	--	--	--	--	--
Rm. 128C - Kitchen	Sink	Secured - SCSD Staff Only	046	FR-S118	1.5	None	--	--	--	--	--	--
Rm. 128C - Kitchen	Sink	Secured - SCSD Staff Only	047	FR-S119	1.2	None	--	--	--	--	--	--
Rm. 128C - Kitchen	Sink	Secured - SCSD Staff Only	054	FR-S120	14.9	None	--	--	--	--	--	--
Rm. 128C - Kitchen	Sink	Secured - SCSD Staff Only	055	FR-S121	1.5	None	--	--	--	--	--	--
Rm. 128C - Kitchen	Kettle	Secured - SCSD Staff Only	063 / 005	FR-S122	514.0	See Note 6	14.7	None	--	--	--	--

**SYRACUSE CITY SCHOOL DISTRICT
PSLA and FOWLER HIGH SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	08/15/20 RESULTS (ppb)	08/15/20 ORIGINAL ACTIONS	11/14/20 RESULTS (ppb)	11/14/20 ACTIONS	12/04/20 RESULTS (ppb)	12/04/20 ACTIONS	12/30/20 RESULTS (ppb)	12/30/20 ACTIONS
BUILDING SECTION 'A', cont.												
Rm. 128C - Kitchen	Hose Spray Stand	Secured - SCSD Staff Only	064	FR-S123	14.7	None	--	--	--	--	--	--
Rm. 128C - Kitchen	Kettle Faucet	Secured - SCSD Staff Only	066	FR-S124	<1.0	None	--	--	--	--	--	--
Rm. 128C - Kitchen	Combitherm Oven	Secured - SCSD Staff Only	058 / 006	FR-S126	36.9	See Note 6	6.1	None	--	--	--	--
Rm. 128C - Kitchen	Combitherm Oven	Secured - SCSD Staff Only	059 / 007	FR-S127	24.9	See Note 6	9.8	None	--	--	--	--
Rm. 128C - Kitchen	Combitherm Oven	Secured - SCSD Staff Only	060	FR-S128	15.0	None	--	--	--	--	--	--
Rm. 128C - Kitchen	Combitherm Oven	Secured - SCSD Staff Only	062	FR-S129	12.3	None	--	--	--	--	--	--
Rm. 128C - Kitchen	Hose Spray Stand	Secured - SCSD Staff Only	068	FR-S130	<1.0	None	--	--	--	--	--	--
Rm. 128C - Kitchen	Hose Spray Stand	Secured - SCSD Staff Only	069	FR-S131	<1.0	None	--	--	--	--	--	--
Rm. 128D - Kitchen/Corridor	Ice Machine	Secured - SCSD Staff Only	065	FR-S132	<1.0	None	--	--	--	--	--	--
Rm. 128E - Storage Room	Sink	Secured - SCSD Staff Only	067	FR-S133	4.0	None	--	--	--	--	--	--
Rm. 129 - Hallway/Corridor	Fountain	Public Access	005	FR-F101	<1.0	None	--	--	--	--	--	--
Rm. 131C - Storage Room Bathroom	Sink	Secured - SCSD Staff Only	007	FR-S102	1.4	None	--	--	--	--	--	--
Rm. 131G - Nurse's Office Bathroom	Sink	Public Access	008	FR-S106	1.5	None	--	--	--	--	--	--
Rm. 131H - Exam Room Bathroom	Sink	Public Access	009	FR-S105	12.6	None	--	--	--	--	--	--
Rm. 131I - Exam Room	Sink	Public Access	010	FR-S104	5.6	None	--	--	--	--	--	--
Rm. 131J - Nurse's Office	Sink	Public Access	014	FR-S103	11.5	None	--	--	--	--	--	--
Rm. 131R - Practical Treatment Room	Sink	Secured - SCSD Staff Only	029 / 002	FR-S111	22.3	See Note 6	2.0	None	--	--	--	--
Rm. 131U - Practical Treatment Room	Sink	Secured - SCSD Staff Only	025	FR-S110	1.5	None	--	--	--	--	--	--
Rm. 131V - Soiled Meds Room	Sink	Secured - SCSD Staff Only	017	FR-S107	2.9	None	--	--	--	--	--	--
Rm. 131W - Meds Room Bathroom	Sink	Secured - SCSD Staff Only	020	FR-S108	3.2	None	--	--	--	--	--	--
Rm. 131Y - Dental Office	Sink	Public Access	021	FR-S109	4.8	None	--	--	--	--	--	--
Rm. 137B - Boy's Locker Room Bathroom	Sink	Public Access	003	FR-S100	5.2	None	--	--	--	--	--	--
Rm. 137B - Boy's Locker Room Bathroom	Sink	Public Access	004	FR-S101	4.9	None	--	--	--	--	--	--
Rm. 137B - Boy's Locker Room Bathroom	Fountain	Public Access	002	FR-F100	2.6	None	--	--	--	--	--	--
Rm. 141 - Meter Room	Sink	Public Access	001	FR-S165	<1.0	None	--	--	--	--	--	--
Rm. 210A - Hallway/Corridor	Fountain	Public Access	082	FR-F518	<1.0	None	--	--	--	--	--	--
Rm. 210A - Hallway/Corridor	Fountain	Public Access	083	FR-F528	<1.0	None	--	--	--	--	--	--
Rm. 215 - Special Edu. Room	Sink	Public Access	079	FR-S541	<1.0	None	--	--	--	--	--	--

**SYRACUSE CITY SCHOOL DISTRICT
PSLA and FOWLER HIGH SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	08/15/20 RESULTS (ppb)	08/15/20 ORIGINAL ACTIONS	11/14/20 RESULTS (ppb)	11/14/20 ACTIONS	12/04/20 RESULTS (ppb)	12/04/20 ACTIONS	12/30/20 RESULTS (ppb)	12/30/20 ACTIONS
BUILDING SECTION 'A', cont.												
Rm. 216 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	081	FR-S536	1.1	None	--	--	--	--	--	--
Rm. 217 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	080	FR-S537	1.1	None	--	--	--	--	--	--
Rm. 224 - Girl's Bathroom	Sink	Public Access	090	FR-S529	<1.0	None	--	--	--	--	--	--
Rm. 224 - Girl's Bathroom	Sink	Public Access	091	FR-S530	<1.0	None	--	--	--	--	--	--
Rm. 224 - Girl's Bathroom	Sink	Public Access	092	FR-S531	<1.0	None	--	--	--	--	--	--
Rm. 225 - Boy's Bathroom	Sink	Public Access	086	FR-S532	<1.0	None	--	--	--	--	--	--
Rm. 225 - Boy's Bathroom	Sink	Public Access	087	FR-S533	<1.0	None	--	--	--	--	--	--
Rm. 225 - Boy's Bathroom	Sink	Public Access	088	FR-S534	<1.0	None	--	--	--	--	--	--
Rm. 231 - Concession Room	Sink	Secured - SCSD Staff Only	095	FR-S527	1.1	None	--	--	--	--	--	--
Rm. 245 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	112	FR-S526	2.3	None	--	--	--	--	--	--
Rm. 246 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	111	FR-S525	1.1	None	--	--	--	--	--	--
Rm. 257 - Boy's Bathroom	Sink	Public Access	101	FR-S519	<1.0	None	--	--	--	--	--	--
Rm. 257 - Boy's Bathroom	Sink	Public Access	102	FR-S520	<1.0	None	--	--	--	--	--	--
Rm. 257 - Boy's Bathroom	Sink	Public Access	103	FR-S521	1.1	None	--	--	--	--	--	--
Rm. 257/285 - Hallway/Corridor	Fountain	Public Access	098	FR-F516	<1.0	None	--	--	--	--	--	--
Rm. 257/285 - Hallway/Corridor	Fountain	Public Access	099	FR-F517	<1.0	None	--	--	--	--	--	--
Rm. 258 - Girl's Bathroom	Sink	Public Access	106	FR-S522	1.4	None	--	--	--	--	--	--
Rm. 258 - Girl's Bathroom	Sink	Public Access	107	FR-S523	<1.0	None	--	--	--	--	--	--
Rm. 258 - Girl's Bathroom	Sink	Public Access	108	FR-S524	<1.0	None	--	--	--	--	--	--
Rm. 273 - Girl's Locker Room	Fountain	Public Access	105	FR-F501	4.3	None	--	--	--	--	--	--
Rm. 273B - Girl's Locker Room Bathroom	Sink	Public Access	109/009/001/001	FR-S504	77.2	See Note 6	132	See Note 6	24.9	See Note 6	24.9	See Note 6
Rm. 273B - Girl's Locker Room Bathroom	Sink	Public Access	110	FR-S505	11.6	None	--	--	--	--	--	--
Rm. 274B - Boy's Locker Room Bathroom	Sink	Public Access	100	FR-S502	4.6	None	--	--	--	--	--	--
Rm. 274B - Boy's Locker Room Bathroom	Sink	Public Access	104 / 008	FR-S503	33.1	See Note 6	8.4	None	--	--	--	--
Rm. 278 - Hallway/Corridor	Fountain	Public Access	072	FR-F500	1.9	None	--	--	--	--	--	--
Rm. 280 Boy's Locker Room	Fountain	Public Access	074	FR-F506	<1.0	None	--	--	--	--	--	--
Rm. 280 Boy's Locker Room	Fountain	Public Access	076	FR-F507	<1.0	None	--	--	--	--	--	--
Rm. 280A - Boy's Locker Room Bathroom	Sink	Public Access	077	FR-S508	1.2	None	--	--	--	--	--	--

**SYRACUSE CITY SCHOOL DISTRICT
PSLA and FOWLER HIGH SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	08/15/20 RESULTS (ppb)	08/15/20 ORIGINAL ACTIONS	11/14/20 RESULTS (ppb)	11/14/20 ACTIONS	12/04/20 RESULTS (ppb)	12/04/20 ACTIONS	12/30/20 RESULTS (ppb)	12/30/20 ACTIONS
BUILDING SECTION 'A', cont.												
Rm. 280A - Boy's Locker Room Bathroom	Sink	Public Access	078	FR-S509	2.0	None	--	--	--	--	--	--
Rm. 280D - Boy's PE Office Bathroom	Sink	Secured - SCSD Staff Only	084	FR-S510	2.4	None	--	--	--	--	--	--
Rm. 281 - Girl's Locker Room	Fountain	Public Access	085	FR-F511	<1.0	None	--	--	--	--	--	--
Rm. 281 - Girl's Locker Room	Fountain	Public Access	089	FR-F512	<1.0	None	--	--	--	--	--	--
Rm. 281A - Girl's Locker Room Bathroom	Sink	Public Access	093	FR-S513	1.0	None	--	--	--	--	--	--
Rm. 281A - Girl's Locker Room Bathroom	Sink	Public Access	094	FR-S514	1.9	None	--	--	--	--	--	--
Rm. 281D - Girl's PE Bathroom	Sink	Secured - SCSD Staff Only	096	FR-S515	2.2	None	--	--	--	--	--	--
Rm. 292E - Staff's Bathroom	Sink	Secured - SCSD Staff Only	075	FR-S535	1.2	None	--	--	--	--	--	--
Rm. 333 - Hallway/Corridor	Fountain	Public Access	116	FR-F106	<1.0	None	--	--	--	--	--	--
Rm. 333 - Hallway/Corridor	Fountain	Public Access	117	FR-F107	<1.0	None	--	--	--	--	--	--
Rm. 334 - Boy's Bathroom	Sink	Public Access	128	FR-S154	<1.0	None	--	--	--	--	--	--
Rm. 334 - Boy's Bathroom	Sink	Public Access	129	FR-S155	<1.0	None	--	--	--	--	--	--
Rm. 334 - Boy's Bathroom	Sink	Public Access	130	FR-S156	1.1	None	--	--	--	--	--	--
Rm. 336 - Girl's Bathroom	Sink	Public Access	122	FR-S151	1.3	None	--	--	--	--	--	--
Rm. 336 - Girl's Bathroom	Sink	Public Access	123	FR-S152	<1.0	None	--	--	--	--	--	--
Rm. 336 - Girl's Bathroom	Sink	Public Access	124	FR-S153	<1.0	None	--	--	--	--	--	--
Rm. 352 - Boy's Bathroom	Sink	Public Access	118	FR-S157	1.2	None	--	--	--	--	--	--
Rm. 352 - Boy's Bathroom	Sink	Public Access	119	FR-S158	<1.0	None	--	--	--	--	--	--
Rm. 352 - Boy's Bathroom	Sink	Public Access	120	FR-S159	<1.0	None	--	--	--	--	--	--
Rm. 352 - Hallway/Corridor	Fountain	Public Access	113	FR-F108	<1.0	None	--	--	--	--	--	--
Rm. 352 - Hallway/Corridor	Fountain	Public Access	115	FR-F109	<1.0	None	--	--	--	--	--	--
Rm. 354 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	121	FR-S160	7.7	None	--	--	--	--	--	--
Rm. 355 - Girl's Bathroom	Sink	Public Access	125	FR-S161	<1.0	None	--	--	--	--	--	--
Rm. 355 - Girl's Bathroom	Sink	Public Access	126	FR-S162	<1.0	None	--	--	--	--	--	--
Rm. 355 - Girl's Bathroom	Sink	Public Access	127	FR-S163	2.2	None	--	--	--	--	--	--
Rm. 364 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	114	FR-S164	1.9	None	--	--	--	--	--	--
Rm. 316 - Hallway/Corridor	Fountain	Public Access	131	FR-F104	<1.0	None	--	--	--	--	--	--
Rm. 316 - Hallway/Corridor	Fountain	Public Access	132	FR-F105	<1.0	None	--	--	--	--	--	--

**SYRACUSE CITY SCHOOL DISTRICT
PSLA and FOWLER HIGH SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	08/15/20 RESULTS (ppb)	08/15/20 ORIGINAL ACTIONS	11/14/20 RESULTS (ppb)	11/14/20 ACTIONS	12/04/20 RESULTS (ppb)	12/04/20 ACTIONS	12/30/20 RESULTS (ppb)	12/30/20 ACTIONS
BUILDING SECTION 'B'												
Rm. 313 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	133	FR-S149	1.1	None	--	--	--	--	--	--
Rm. 314 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	134	FR-S150	1.2	None	--	--	--	--	--	--
Rm. 298 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	071	FR-S538	<1.0	None	--	--	--	--	--	--
Rm. 297 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	070	FR-S539	1.6	None	--	--	--	--	--	--
Rm. 201A - Work Room	Sink	Secured - SCSD Staff Only	073	FR-S540	1.6	None	--	--	--	--	--	--
Rm. 131I - Exam Room	Sink (Spray)	Public Access	012 / 001	FR-S104A	38.0	See Note 6	1.3	None	--	--	--	--
Rm. 131J - Nurse's Office	Sink (Spray)	Public Access	015	FR-S103A	5.9	None	--	--	--	--	--	--
Rm. 131V - Soiled Meds Room	Sink (Spray)	Secured - SCSD Staff Only	018	FR-S107A	4.2	None	--	--	--	--	--	--
Rm. 131Y - Dental Office	Sink (Spray)	Public Access	022 / 004	FR-S109A	38.3	See Note 6	2.9	None	--	--	--	--
Rm. 131U - Practical Treatment Room	Sink (Spray)	Secured - SCSD Staff Only	026	FR-S110A	4.2	None	--	--	--	--	--	--
Rm. 018 - Art Classroom	Sink	Public Access	028	FR-S3000	1.4	None	--	--	--	--	--	--
Rm. 131R - Practical Treatment Room	Sink (Spray)	Secured - SCSD Staff Only	030 / 003 / 002	FR-S111A	18.0	See Note 6	30.1	See Note 6	7.7	None	--	--
Rm. 018 - Art Classroom	Sink	Public Access	031	FR-S3001	2.5	None	--	--	--	--	--	--
Rm. 018 - Art Classroom	Sink	Public Access	032	FR-S3002	1.8	None	--	--	--	--	--	--
Rm. 018 - Art Classroom	Sink	Public Access	034	FR-S3003	2.2	None	--	--	--	--	--	--
Rm. 018 - Art Classroom	Sink	Public Access	035	FR-S3004	2.5	None	--	--	--	--	--	--
Rm. 016 - Art Classroom	Sink	Public Access	036	FR-S3005	7.6	None	--	--	--	--	--	--
Rm. 016 - Art Classroom	Sink	Public Access	037	FR-S3006	2.5	None	--	--	--	--	--	--
Rm. 016 - Art Classroom	Sink	Public Access	039	FR-S3007	3.3	None	--	--	--	--	--	--
Rm. 016 - Art Classroom	Sink	Public Access	040	FR-S3008	3.5	None	--	--	--	--	--	--
Rm. 016 - Art Classroom	Sink	Public Access	041	FR-S3009	1.5	None	--	--	--	--	--	--
Rm. 276 - Swimming Pool	Fountain	Public Access	097	FR-F3000P	461	See Note 7	--	--	--	--	--	--

SYRACUSE CITY SCHOOL DISTRICT

PSLA and FOWLER HIGH SCHOOL

Original Sample Notes [August 15, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-035
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project ID No. 70143044
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed, replaced, and re-sampled.
7. Fixture removed.

Re-Sample Notes [November 14, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-035
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project ID No. 70153828
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed, replaced, and re-sampled.

Re-Sample Notes [December 4, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-035
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project ID No. 70155707
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed, replaced, and re-sampled.

Re-Sample Notes [December 30, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-035
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project ID No. 70158352
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture placarded by SCSD.