

**SYRACUSE CITY SCHOOL DISTRICT
FRANKLIN ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	06/16/20 RESULTS (ppb)	06/16/20 ORIGINAL ACTIONS	08/08/20 RESULTS (ppb)	08/08/20 RE-SAMPLE ACTIONS	11/14/20 RESULTS (ppb)	11/14/20 RE-SAMPLE ACTIONS
Rm. 005 - Gym Teacher's Bathroom	Sink	Secured - SCSD Staff Only	004	FN-S217	2.3	None	--	--	--	--
Rm. A100 - Hallway/Vestibule	Fountain	Public Access	001	FN-F207	<1.0	None	--	--	--	--
Rm. A101 - Gymnasium	Fountain	Public Access	---	FN-F209	---	See Note 7	--	--	--	--
Rm. A101 - Gymnasium	Fountain	Public Access	---	FN-F210	---	See Note 7	--	--	--	--
Rm. A105 - Girl's Gym Bathroom	Sink	Public Access	005	FN-S218	1.8	None	--	--	--	--
Rm. A108 - Boy's Gym Bathroom	Sink	Public Access	006	FN-S216	1.7	None	--	--	--	--
Rm. 100 - Classroom	Sink	Public Access	070	FN-S203	1.9	None	---	--	--	--
Rm. 100 - Classroom	Fountain	Public Access	069	FN-F204	<1.0	None	--	--	--	--
Rm. 102 - Classroom	Sink	Public Access	051	FN-S204	1.8	None	--	--	--	--
Rm. 102 - Classroom	Fountain	Public Access	050	FN-F205	4.2	None	--	--	--	--
Rm. 103 - Classroom	Sink	Public Access	047	FN-S205	1.6	None	--	--	--	--
Rm. 103 - Classroom	Fountain	Public Access	048	FN-F206	2.2	None	--	--	--	--
Rm. 104 - Classroom	Sink	Public Access	044	FN-S110	1.4	None	--	--	--	--
Rm. 104 - Classroom	Fountain	Public Access	045	FN-F107	2.2	None	--	--	--	--
Rm. 106 - Classroom	Sink	Public Access	040	FN-S109	1.3	None	--	--	--	--
Rm. 106 - Classroom	Fountain	Public Access	039	FN-F106	7.3	None	--	--	--	--
Rm. 112 - Classroom	Sink	Public Access	032	FN-S107	1.2	None	--	--	--	--
Rm. 112 - Classroom	Fountain	Public Access	033	FN-F105	3.8	None	--	--	--	--
Rm. 113 - Classroom	Sink	Public Access	028	FN-S106	1.6	None	--	--	--	--
Rm. 113 - Classroom	Fountain	Public Access	029	FN-F104	4.6	None	--	--	--	--
Rm. 114 - Classroom	Sink	Public Access	025	FN-S105	2.1	None	--	--	--	--
Rm. 114 - Classroom	Fountain	Public Access	026	FN-F103	3.3	None	--	--	--	--
Rm. 116 - Classroom	Sink	Public Access	024	FN-S104	2.0	None	--	--	--	--
Rm. 116 - Classroom	Fountain	Public Access	023	FN-F102	4.6	None	--	--	--	--
Rm. 117 - Classroom	Sink	Public Access	020	FN-S103	2.4	None	--	--	--	--
Rm. 117 - Classroom	Fountain	Public Access	019	FN-F101	2.7	None	--	--	--	--
Rm. 119 - Hallway/Vestibule	Sink	Public Access	013	FN-S100	<1.0	None	--	--	--	--
Rm. 119 - Hallway/Vestibule	Sink	Public Access	015	FN-S101	<1.0	None	--	--	--	--
Rm. 119 - Hallway/Vestibule	Sink	Public Access	014	FN-S102	1.1	None	--	--	--	--
Rm. 119 - Hallway/Vestibule	Fountain	Public Access	011	FN-F100	<1.0	None	--	--	--	--

**SYRACUSE CITY SCHOOL DISTRICT
FRANKLIN ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	06/16/20 RESULTS (ppb)	06/16/20 ORIGINAL ACTIONS	08/08/20 RESULTS (ppb)	08/08/20 RE-SAMPLE ACTIONS	11/14/20 RESULTS (ppb)	11/14/20 RE-SAMPLE ACTIONS
Rm. 123 - Classroom	Sink	Public Access	009	FN-S201A	1.9	None	--	--	--	--
Rm. 123 - Classroom	Fountain	Public Access	010	FN-F200	<1.0	None	--	--	--	--
Rm. 124 - Classroom	Sink	Public Access	008	FN-S201B	1.9	None	--	--	--	--
Rm. 124 - Classroom	Fountain	Public Access	007	FN-F201	<1.0	None	--	--	--	--
Rm. 125 - Classroom	Sink	Public Access	003	FN-S202	1.8	None	--	--	--	--
Rm. 125 - Classroom	Fountain	Public Access	002	FN-F203	<1.0	None	--	--	--	--
Rm. 131 - Kitchen	Sink	Secured - SCSD Staff Only	066	FN-S112	1.6	None	--	--	--	--
Rm. 131 - Kitchen	Sink	Secured - SCSD Staff Only	056	FN-S113	1.4	None	--	--	--	--
Rm. 131 - Kitchen	Sink	Secured - SCSD Staff Only	060	FN-S114	3.2	None	--	--	--	--
Rm. 131 - Kitchen	Sink	Secured - SCSD Staff Only	062/001/002	FN-S115	54.7	See Note 6	45.1	See Note 6	<1.0	None
Rm. 131C - Kitchen Bathroom	Sink	Secured - SCSD Staff Only	068	FN-S111	<1.0	None	--	--	--	--
Rm. 138A - Teacher's Resource Bathroom	Sink	Secured - SCSD Staff Only	036	FN-S108	<1.0	None	--	--	--	--
Rm. 146C - Cafeteria Passage	Fountain	Public Access	067	FN-F202	<1.0	None	--	--	--	--
Rm. 146D - Boy's Bathroom	Sink	Public Access	054	FN-S207	1.0	None	--	--	--	--
Rm. 146E - Girl's Bathroom	Sink	Public Access	053	FN-S206	<1.0	None	--	--	--	--
Rm. 201 - Nurse's Office	Sink	Public Access	017	FN-S208	<1.0	None	--	--	--	--
Rm. 201C - Nurse's Office Bathroom	Sink	Public Access	012	FN-S209	9.6	None	--	--	--	--
Rm. 202 - Clinic Room	Sink	Public Access	021	FN-S211	3.7	None	--	--	--	--
Rm. 202 - Clinic Room	Sink	Public Access	022	FN-S212	2.4	None	--	--	--	--
Rm. 202 - Clinic/Examination Room	Sink	Public Access	027	FN-S213	6.1	None	--	--	--	--
Rm. 202 - Clinic/Examination Room	Sink	Public Access	030	FN-S214	3.0	None	--	--	--	--
Rm. 202 - Clinic Room	Sink	Public Access	031	FN-S215	1.3	None	--	--	--	--
Rm. 204 - Clinic Room	Sink	Public Access	018	FN-S210	1.6	None	--	--	--	--
Rm. 205 - Women's Bathroom	Sink	Public Access	034	FN-S134	<1.0	None	--	--	--	--
Rm. 206 - Men's Bathroom	Sink	Public Access	037	FN-S133	2.0	None	--	--	--	--
Rm. 208 - Teacher's Lounge Kitchenette	Sink	Secured - SCSD Staff Only	038	FN-S130	<1.0	None	--	--	--	--
Rm. 208A - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	042	FN-S131	<1.0	None	--	--	--	--
Rm. 208B - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	041	FN-S132	3.3	None	--	--	--	--
Rm. 209 - Classroom	Sink	Public Access	043	FN-S129	<1.0	None	--	--	--	--

**SYRACUSE CITY SCHOOL DISTRICT
FRANKLIN ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	06/16/20 RESULTS (ppb)	06/16/20 ORIGINAL ACTIONS	08/08/20 RESULTS (ppb)	08/08/20 RE-SAMPLE ACTIONS	11/14/20 RESULTS (ppb)	11/14/20 RE-SAMPLE ACTIONS
Rm. 210A - Classroom Bathroom	Sink	Public Access	046	FN-S128	3.7	None	--	--	--	--
Rm. 211 - Teacher's Resource	Sink	Public Access	052	FN-S127	1.2	None	--	--	--	--
Rm. 212B - Work Room	Sink	Secured - SCSD Staff Only	055	FN-S120	<1.0	None	--	--	--	--
Rm. 212D - Hallway/Vestibule	Sink	Public Access	058	FN-S122	<1.0	None	--	--	--	--
Rm. 212D - Hallway/Vestibule	Sink	Public Access	057	FN-S123	4.7	None	--	--	--	--
Rm. 212D - Hallway/Vestibule	Sink	Public Access	061	FN-S124	<1.0	None	--	--	--	--
Rm. 212D - Hallway/Vestibule	Fountain	Public Access	059	FN-F108	4.8	None	--	--	--	--
Rm. 215 - Computer Room	Sink	Public Access	063	FN-S126	2.4	None	--	--	--	--
Rm. 215 - Computer Room	Fountain	Public Access	---	FN-F110	---	See Note 7	--	--	--	--
Rm. 216 - Computer Room	Sink	Public Access	065	FN-S125	4.6	None	--	--	--	--
Rm. 216 - Computer Room	Fountain	Public Access	064	FN-F109	1.4	None	--	--	--	--
Rm. 220A - Classroom Bathroom	Sink	Public Access	072	FN-S121	1.6	None	--	--	--	--
Rm. 224 - Principal's Bathroom	Sink	Secured - SCSD Staff Only	089	FN-S117	1.2	None	--	--	--	--
Rm. 226 - Main Office Bathroom	Sink	Secured - SCSD Staff Only	088	FN-S116	2.2	None	--	--	--	--
Rm. 228B - Office Kitchenette	Sink	Secured - SCSD Staff Only	077	FN-S118	<1.0	None	--	--	--	--
Rm. 234 - Hallway/Corridor	Fountain	Public Access	035	FN-F111	<1.0	None	--	--	--	--
Rm. 245 - Staff Bathroom	Sink	Secured - SCSD Staff Only	071	FN-S119	<1.0	None	--	--	--	--
Rm. 307 - Hallway/Vestibule	Sink	Public Access	080	FN-S139	1.2	None	--	--	--	--
Rm. 307 - Hallway/Vestibule	Sink	Public Access	082	FN-S140	1.5	None	--	--	--	--
Rm. 307 - Hallway/Vestibule	Sink	Public Access	083	FN-S141	1.3	None	--	--	--	--
Rm. 307 - Hallway/Vestibule	Fountain	Public Access	081	FN-F114	<1.0	None	--	--	--	--
Rm. 309 - Classroom	Sink	Public Access	086	FN-S138	1.2	None	--	--	--	--
Rm. 309 - Classroom	Fountain	Public Access	087	FN-F113	2.1	None	--	--	--	--
Rm. 310 - Classroom	Sink	Public Access	085	FN-S137	1.3	None	--	--	--	--
Rm. 310 - Classroom	Fountain	Public Access	084	FN-F112	<1.0	None	--	--	--	--
Rm. 319 - Hallway/Vestibule	Sink	Public Access	076	FN-S219	6.0	None	--	--	--	--
Rm. 319 - Hallway/Vestibule	Sink	Public Access	075	FN-S220	<1.0	None	--	--	--	--
Rm. 319 - Hallway/Vestibule	Sink	Public Access	073	FN-S221	7.0	None	--	--	--	--
Rm. 319 - Hallway/Vestibule	Fountain	Public Access	074	FN-F208	<1.0	None	--	--	--	--

**SYRACUSE CITY SCHOOL DISTRICT
FRANKLIN ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	06/16/20 RESULTS (ppb)	06/16/20 ORIGINAL ACTIONS	08/08/20 RESULTS (ppb)	08/08/20 RE-SAMPLE ACTIONS	11/14/20 RESULTS (ppb)	11/14/20 RE-SAMPLE ACTIONS
Rm. 330 - Staff Bathroom	Sink	Secured - SCSD Staff Only	079	FN-S136	2.5	None	--	--	--	--
Rm. 331 - Staff Bathroom	Sink	Secured - SCSD Staff Only	078	FN-S135	2.7	None	--	--	--	--
Rm. 201A - Nurse Exam Room	Sink	Public Access	016	FN-S1000	<1.0	None	--	--	--	--
Rm. 210 - Classroom	Fountain	Public Access	049	FN-F1000	<1.0	None	--	--	--	--
Rm. 131 - Kitchen	Convotherm Oven Sprayer	Secured - SCSD Staff Only	001	FN-S4000	--	--	--	See Note 7	1.3	None

Original Sample Notes: [June 16, 2020 Event]

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-007
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70135383
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. In-line lead filter installed by SCSD.
7. Fixture not operating.

Re-Sample Notes: [August 08, 2020 Event]

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-007
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70141470
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Filter installed by SCSD.
7. Fixture not operating.

Re-Sample Notes: [November 14, 2020 Event]

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-007
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70153831
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.