

**SYRACUSE CITY SCHOOL DISTRICT
FRAZER PK-GRADE 8 SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE ID No.	TDK SAMPLE ID No.	06/16/20 RESULTS (ppb)	06/16/20 ORIGINAL ACTIONS	08/08/20 RE-SAMPLE RESULTS (ppb)	08/08/20 RE-SAMPLE ACTIONS	11/21/20 RE-SAMPLE RESULTS (ppb)	11/21/20 RE-SAMPLE ACTIONS
Rm. 000 - Hallway/Vestibule	Fountain	Public Access	018	FR-F104	<1.0	None	---	---	---	---
Rm. 000 - Hallway/Vestibule	Fountain	Public Access	---/---/007	FR-F105	---	See Note 7	---	See Note 7	<1.0	None
Rm. 000A - Hallway Corridor	Fountain	Public Access	002	FR-F100	<1.0	None	---	---	---	---
Rm. 000A - Hallway Corridor	Fountain	Public Access	001	FR-F101	<1.0	None	---	---	---	---
Rm. 0T1A - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	004	FR-S101	4.1	None	---	---	---	---
Rm. 0T1B - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	003	FR-S100	4.4	None	---	---	---	---
Rm. 002B - Gym Office Bathroom	Sink	Secured - SCSD Staff Only	032	FR-S118	6.4	None	---	---	---	---
Rm. 003B - Gym Office Bathroom	Sink	Secured - SCSD Staff Only	025	FR-S117	9.8	None	---	---	---	---
Rm. 05B - Technology Room	Sink	Public Access	008	FR-S110	4.5	None	---	---	---	---
Rm. 007 - Lounge	Sink	Secured - SCSD Staff Only	010	FR-S111	<1.0	None	---	---	---	---
Rm. 007A - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	037	FR-S112	1.7	None	---	---	---	---
Rm. 007B - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	038	FR-S113	3.7	None	---	---	---	---
Rm. 008A - Cafeteria	Fountain	Public Access	033	FR-F102	<1.0	None	---	---	---	---
Rm. 008A - Cafeteria	Fountain	Public Access	034	FR-F103	<1.0	None	---	---	---	---
Rm. 008E - Kitchen	Sink	Secured - SCSD Staff Only	057	FR-S102	3.8	None	---	---	---	---
Rm. 008E - Kitchen	Sink	Secured - SCSD Staff Only	056	FR-S103	3.8	None	---	---	---	---
Rm. 008E - Kitchen	Sink	Secured - SCSD Staff Only	055	FR-S104	1.8	None	---	---	---	---
Rm. 008E - Kitchen	Sink	Secured - SCSD Staff Only	053	FR-S105	3.4	None	---	---	---	---
Rm. 008E - Kitchen	Sink	Secured - SCSD Staff Only	046/001	FR-S106	89.6	See Note 6	3.0	None	---	---
Rm. 008J - Kitchen Staff Bathroom	Sink	Secured - SCSD Staff Only	061	FR-S107	<1.0	None	---	---	---	---
Rm. 008K - Custodian's Bathroom	Sink	Secured - SCSD Staff Only	060	FR-S108	2.1	None	---	---	---	---
Rm. 009 - Technology Room	Sink	Public Access	007	FR-S109	7.1	None	---	---	---	---
Rm. 100B - Hallway/Corridor	Fountain	Public Access	009	FR-F113	<1.0	None	---	---	---	---
Rm. 100H - Hallway/Corridor	Fountain	Public Access	054	FR-F111	<1.0	None	---	---	---	---
Rm. 101 - Classroom	Sink	Public Access	041	FR-S130	<1.0	None	---	---	---	---
Rm. 101 - Classroom	Fountain	Public Access	042	FR-F109	4.6	None	---	---	---	---
Rm. 101A - Classroom	Sink	Public Access	040	FR-S129	5.8	None	---	---	---	---
Rm. 101J - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	030	FR-S131	1.5	None	---	---	---	---
Rm. 101K - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	031	FR-S132	1.7	None	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT
FRAZER PK-GRADE 8 SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE ID No.	TDK SAMPLE ID No.	06/16/20 RESULTS (ppb)	06/16/20 ORIGINAL ACTIONS	08/08/20 RE-SAMPLE RESULTS (ppb)	08/08/20 RE-SAMPLE ACTIONS	11/21/20 RE-SAMPLE RESULTS (ppb)	11/21/20 RE-SAMPLE ACTIONS
Rm. 102A - Nurse's Bathroom	Sink	Public Access	045	FR-S127	2.7	None	---	---	---	---
Rm. 102B - Exam Room	Sink	Public Access	044	FR-S128	6.8	None	---	---	---	---
Rm. 105 - Special Education Room	Sink	Public Access	039	FR-S126	<1.0	None	---	---	---	---
Rm. 106 - Classroom	Sink	Public Access	036	FR-S125	<1.0	None	---	---	---	---
Rm. 106 - Classroom	Fountain	Public Access	035	FR-F108	3.7	None	---	---	---	---
Rm. 106A - Classroom Bathroom	Sink	Public Access	---/---/006	FR-S124	---	See Note 7	---	See Note 7	8.5	None
Rm. 107 - Classroom	Sink	Public Access	026	FR-S123	<1.0	None	---	---	---	---
Rm. 107 - Classroom	Fountain	Public Access	023	FR-F107	3.1	None	---	---	---	---
Rm. 107A - Classroom Bathroom	Sink	Public Access	024	FR-S122	8.5	None	---	---	---	---
Rm. 116 - Resource Room	Sink	Public Access	019	FR-S147	<1.0	None	---	---	---	---
Rm. 117C - Work Room	Sink	Secured - SCSD Staff Only	---/---/005	FR-S146	---	See Note 7	---	See Note 7	1.0	None
Rm. 118 - Work Room	Sink	Secured - SCSD Staff Only	015	FR-S145	<1.0	None	---	---	---	---
Rm. 118A - Work Room Bathroom	Sink	Secured - SCSD Staff Only	016	FR-S144	<1.0	None	---	---	---	---
Rm. 130 - Classroom	Sink	Public Access	006	FR-S139	<1.0	None	---	---	---	---
Rm. 131A - Class Bathroom	Sink	Public Access	005	FR-S140	1.3	None	---	---	---	---
Rm. 131A - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	059	FR-S138	8.0	None	---	---	---	---
Rm. 131B - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	058	FR-S137	12.2	None	---	---	---	---
Rm. 134B - Classroom Bathroom	Sink	Public Access	049	FR-S133	3.7	None	---	---	---	---
Rm. 142 - Classroom	Fountain	Public Access	050	FR-F110	<1.0	None	---	---	---	---
Rm. L-10 - Hallway/Corridor	Fountain	Public Access	062	FR-F112	<1.0	None	---	---	---	---
Rm. 200 - Computer Lab	Sink	Public Access	085	FR-S158	2.1	None	---	---	---	---
Rm. 200A - Hallway/Corridor	Fountain	Public Access	072	FR-F120	<1.0	None	---	---	---	---
Rm. 200A - Hallway/Corridor	Fountain	Public Access	071	FR-F121	2.4	None	---	---	---	---
Rm. 200A - Dark Room	Sink	Public Access	---/---/---	FR-S157	---	See Note 7	---	See Note 7	---	See Note 6
Rm. 200A - Hallway/Corridor	Fountain	Public Access	---/---/003	FR-F119	---	See Note 7	---	See Note 7	1.5	None
Rm. 200D - Hallway/Corridor	Fountain	Public Access	063	FR-F118	<1.0	None	---	---	---	---
Rm. 200H - Hallway/Corridor	Fountain	Public Access	080	FR-F116	<1.0	None	---	---	---	---
Rm. 200H - Hallway/Corridor	Fountain	Public Access	081	FR-F117	1.8	None	---	---	---	---
Rm. 203A - Work Room Bathroom	Sink	Secured - SCSD Staff Only	079	FR-S155	1.5	None	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT
FRAZER PK-GRADE 8 SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE ID No.	TDK SAMPLE ID No.	06/16/20 RESULTS (ppb)	06/16/20 ORIGINAL ACTIONS	08/08/20 RE-SAMPLE RESULTS (ppb)	08/08/20 RE-SAMPLE ACTIONS	11/21/20 RE-SAMPLE RESULTS (ppb)	11/21/20 RE-SAMPLE ACTIONS
Rm. 211 - Work Room	Sink	Secured - SCSD Staff Only	076	FR-S154	<1.0	None	---	---	---	---
Rm. 214 - Laboratory Room	Sink	Public Access	069	FR-S150	1.6	None	---	---	---	---
Rm. 214 - Laboratory Room	Sink	Public Access	073	FR-S151	2.9	None	---	---	---	---
Rm. 214 - Laboratory Room	Sink	Public Access	074	FR-S152	<1.0	None	---	---	---	---
Rm. 214 - Laboratory Room	Sink	Public Access	075	FR-S153	2.9	None	---	---	---	---
Rm. 217 - Home & Careers Room	Sink	Public Access	065	FR-S148	<1.0	None	---	---	---	---
Rm. 217 - Home & Careers Room	Sink	Public Access	66	FR-S149	<1.0	None	---	---	---	---
Rm. 230 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	078	FR-S163	7.5	None	---	---	---	---
Rm. 231 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	077	FR-S162	7.4	None	---	---	---	---
Rm. 231 - Classroom Bathroom	Sink	Public Access	064	FR-S164	3.8	None	---	---	---	---
Rm. 249 - Art Room	Sink	Public Access	017	FR-S156	<1.0	None	---	---	---	---
Rm. 002C - Girl's Locker Bathroom	Sink	Public Access	027	FR-S1000	1.4	None	---	---	---	---
Rm. 002C - Girl's Locker Bathroom	Sink	Public Access	028	FR-S1001	8.0	None	---	---	---	---
Rm. 002C - Girl's Locker Bathroom	Sink	Public Access	029	FR-S1002	6.0	None	---	---	---	---
Rm. 003C - Boy's Locker Bathroom	Sink	Public Access	020	FR-S1003	4.6	None	---	---	---	---
Rm. 003C - Boy's Locker Bathroom	Sink	Public Access	022	FR-S1004	3.5	None	---	---	---	---
Rm. 003C - Boy's Locker Bathroom	Sink	Public Access	021	FR-S1005	2.4	None	---	---	---	---
Rm. 008E - Kitchen	Oven Sprayer	Secured - SCSD Staff Only	047/003/002	FR-C1000	20.1	See Note 8	27.3	See Note 6	7.6	None
Rm. 1T2 - Hallway/Vestibule	Sink	Public Access	048	FR-S1006	<1.0	None	---	---	---	---
Rm. 1T2 - Hallway/Vestibule	Sink	Public Access	051	FR-S1007	<1.0	None	---	---	---	---
Rm. 1T2 - Hallway/Vestibule	Sink	Public Access	052	FR-S1008	<1.0	None	---	---	---	---
Rm. 1T1 - Hallway/Vestibule	Sink	Public Access	012	FR-S1009	1.2	None	---	---	---	---
Rm. 1T1 - Hallway/Vestibule	Sink	Public Access	013	FR-S1010	1.0	None	---	---	---	---
Rm. 1T1 - Hallway/Vestibule	Sink	Public Access	014	FR-S1011	<1.0	None	---	---	---	---
Rm. 100B - Hallway/Corridor	Fountain	Public Access	---/---/004	FR-F1000	---	See Note 7	---	See Note 7	<1.0	None
Rm. 100B - Hallway/Corridor	Fountain	Public Access	011	FR-F1001	<1.0	None	---	---	---	---
Rm. 2T2 - Hallway/Vestibule	Sink	Public Access	082	FR-S1012	<1.0	None	---	---	---	---
Rm. 2T2 - Hallway/Vestibule	Sink	Public Access	083	FR-S1013	<1.0	None	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT
FRAZER PK-GRADE 8 SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE ID No.	TDK SAMPLE ID No.	06/16/20 RESULTS (ppb)	06/16/20 ORIGINAL ACTIONS	08/08/20 RE-SAMPLE RESULTS (ppb)	08/08/20 RE-SAMPLE ACTIONS	11/21/20 RE-SAMPLE RESULTS (ppb)	11/21/20 RE-SAMPLE ACTIONS
Rm. 2T2 - Hallway/Vestibule	Sink	Public Access	084	FR-S1014	1.1	None	---	---	---	---
Rm. 2T1 - Hallway/Vestibule	Sink	Public Access	070	FR-S1015	<1.0	None	---	---	---	---
Rm. 2T1 - Hallway/Vestibule	Sink	Public Access	067	FR-S1016	<1.0	None	---	---	---	---
Rm. 2T1 - Hallway/Vestibule	Sink	Public Access	068	FR-S1017	<1.0	None	---	---	---	---
Rm. 0088E - Kitchen	Oven Sprayer	Secured - SCSD Staff Only	043/002/001	FR-C1001	31.4	See Note 8	15.1	See Note 6	2.5	None

Original Sample Notes [June 16, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-012
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70135384
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed, replaced and resampled.
7. Fixture not operating/accessible.

Re-Sample Notes [August 8, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-012
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70141471
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Remediation performed by SCSD.
7. Fixture not operating/accessible.

Re-Sample Notes [November 21, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-012
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70154657005
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture to be removed by SCSD.