

**SYRACUSE CITY SCHOOL DISTRICT
GRANT MIDDLE SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE ID No.	TDK SAMPLE ID No.	08/06/20 RESULTS (ppb)	08/06/20 ORIGINAL ACTIONS	10/24/20 RESULTS (ppb)	10/24/20 RE- SAMPLE ACTIONS	12/30/20 RESULTS (ppb)	12/30/20 RE- SAMPLE ACTIONS	01/23/21 RESULTS (ppb)	01/23/21 RE- SAMPLE ACTIONS
Rm. B-2 - Storage Room	Sink	Secured - SCSD Staff Only	008	GT-S204	7.1	None	---	---	---	---	---	---
Rm. B-13 - Girl's Locker Room Bathroom	Sink	Public Access	010	GT-S202	5.7	None	---	---	---	---	---	---
Rm. B-13 - Girl's Locker Room Bathroom	Sink	Public Access	014	GT-S203	6.8	None	---	---	---	---	---	---
Rm. B-18 - Boy's Locker Room Bathroom	Sink	Public Access	004	GT-S(M)200	2.6	None	---	---	---	---	---	---
Rm. B-18 - Boy's Locker Room Bathroom	Sink	Public Access	007	GT-S201	10.1	None	---	---	---	---	---	---
Rm. B-18 - Boy's Locker Room Bathroom	Fountain	Public Access	002	GT-F201	5.3	None	---	---	---	---	---	---
Rm. 107D - Office Bathroom	Sink	Secured - SCSD Staff Only	089/010	GT-S216	24.3	See Note 6	1.7	None	---	---	---	---
Rm. 108B - Exam Room	Sink	Public Access	086	GT-S217	6.0	None	---	---	---	---	---	---
Rm. 109 - Nurse's Office	Sink	Public Access	087/011	GT-S218	16.3	See Note 6	1.5	None	---	---	---	---
Rm. 109A - Nurse's Office Bathroom	Sink	Public Access	081	GT-S219	4.7	None	---	---	---	---	---	---
Rm. 110 - Classroom	Sink	Public Access	076	GT-S220	8.6	None	---	---	---	---	---	---
Rm. 115 - Music Room	Sink	Public Access	050/012	GT-S226	1200.0	See Note 6	12.1	None	---	---	---	---
Rm. 117 - Main Office Bathroom	Sink	Secured - SCSD Staff Only	063	GT-S223	4.5	None	---	---	---	---	---	---
Rm. 118 - Main Office Bathroom	Sink	Secured - SCSD Staff Only	059	GT-S222	2.0	None	---	---	---	---	---	---
Rm. 123 - Work Room	Sink	Secured - SCSD Staff Only	054	GT-S221	8.4	None	---	---	---	---	---	---
Rm. 131 - Serving Room	Sink	Secured - SCSD Staff Only	032/008	GT-S212	18.7	See Note 6	1.4	None	---	---	---	---
Rm. 132A - Medical Assistance Waiting Room	Sink	Public Access	042	GT-S109	3.3	None	---	---	---	---	---	---
Rm. 132A - Medical Assistance Waiting Room	Sink	Public Access	044	GT-S112	1.7	None	---	---	---	---	---	---
Rm. 132A - Medical Assistance Waiting Room	Sink	Public Access	146	GT-S113	13.7	None	---	---	---	---	---	---
Rm. 132A - Medical Assistance Waiting Room	Sink	Public Access	145	GT-S114	8.4	None	---	---	---	---	---	---
Rm. 132B - Dental Office	Sink	Public Access	147	GT-S115	5.2	None	---	---	---	---	---	---
Rm. 132F - Examination Room	Sink	Public Access	143	GT-S111	3.3	None	---	---	---	---	---	---
Rm. 132G - Medical Assistance Bathroom	Sink	Public Access	141	GT-S110	0.97	None	---	---	---	---	---	---
Rm. 133A - Kitchen	Sink	Secured - SCSD Staff Only	036	GT-S206	3.4	None	---	---	---	---	---	---
Rm. 133A - Kitchen	Sink	Secured - SCSD Staff Only	035	GT-S207	7.9	None	---	---	---	---	---	---
Rm. 133A - Kitchen	Sink (spray nozzle)	Secured - SCSD Staff Only	021	GT-S208	5.7	None	---	---	---	---	---	---
Rm. 133A - Kitchen	Sink	Secured - SCSD Staff Only	022	GT-S209	1.7	None	---	---	---	---	---	---
Rm. 133A - Kitchen	Sink	Secured - SCSD Staff Only	023	GT-S210	3.7	None	---	---	---	---	---	---
Rm. 134A - Kitchen Bathroom	Sink	Secured - SCSD Staff Only	017/007	GT-S211	16.2	See Note 6	2.2	None	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT
GRANT MIDDLE SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE ID No.	TDK SAMPLE ID No.	08/06/20 RESULTS (ppb)	08/06/20 ORIGINAL ACTIONS	10/24/20 RESULTS (ppb)	10/24/20 RE- SAMPLE ACTIONS	12/30/20 RESULTS (ppb)	12/30/20 RE- SAMPLE ACTIONS	01/23/21 RESULTS (ppb)	01/23/21 RE- SAMPLE ACTIONS
Rm. 140B - Swimming Pool Office	Sink	Secured - SCSD Staff Only	137	GT-S119	8.5	None	---	---	---	---	---	---
Rm. 151 - Hallway/Vestibule	Fountain	Public Access	118	GT-F100	0.60	None	---	---	---	---	---	---
Rm. 151 - Hallway/Vestibule	Sink	Public Access	114	GT-S101	9.1	None	---	---	---	---	---	---
Rm. 169 - Work Room	Sink	Secured - SCSD Staff Only	058	GT-S224	9.7	None	---	---	---	---	---	---
Rm. 170 - Audio/Video Storage	Sink	Secured - SCSD Staff Only	057	GT-S225	1.0	None	---	---	---	---	---	---
Rm. 177A - Computer Lab Bathroom	Sink	Public Access	108/009	GT-S231	111.0	See Note 6	1.8	None	---	---	---	---
Rm. 177B - Computer Lab Bathroom	Sink	Public Access	110	GT-S232	9.5	None	---	---	---	---	---	---
Rm. 182 - Classroom	Sink	Public Access	129	GT-S103	0.88	None	---	---	---	---	---	---
Rm. 182A - Nurse's Waiting Room	Sink	Public Access	135	GT-S106	1.5	None	---	---	---	---	---	---
Rm. 182B - Classroom Office	Sink	Public Access	130	GT-S104	9.8	None	---	---	---	---	---	---
Rm. 182D - Examination Room	Sink	Public Access	136	GT-S108	3.2	None	---	---	---	---	---	---
Rm. 184 - Swimming Pool	Fountain	Public Access	132	GT-F101	5.9	None	---	---	---	---	---	---
Rm. 182E - Nurse's Office Bathroom	Sink	Public Access	140	GT-S107	1.7	None	---	---	---	---	---	---
Rm. 182G - Sick/Rest Waiting Room	Sink	Public Access	133	GT-S105	1.8	None	---	---	---	---	---	---
Rm. 185C - Office	Sink	Secured - SCSD Staff Only	121	GT-S102	10.8	None	---	---	---	---	---	---
Rm. 203 - Classroom	Sink	Public Access	107	GT-S124	3.1	None	---	---	---	---	---	---
Rm. 204 - Classroom Bathroom	Sink	Public Access	106	GT-S123	12.2	None	---	---	---	---	---	---
Rm. 207 - Girl's Bathroom	Sink	Public Access	112	GT-S132	1.0	None	---	---	---	---	---	---
Rm. 212 - Girl's Coach Office	Sink	Secured - SCSD Staff Only	115	GT-S129	5.2	None	---	---	---	---	---	---
Rm. 227 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	085	GT-S142	0.97	None	---	---	---	---	---	---
Rm. 227B - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	083	GT-S140	8.4	None	---	---	---	---	---	---
Rm. 228A - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	084	GT-S141	9.6	None	---	---	---	---	---	---
Rm. 234A - Art Storage Room	Sink	Public Access	049/---/003	GT-S145	18.3	See Note 7	---	See Note 6	25.0	See Note 7	---	---
Rm. 238A - Classroom Bathroom	Sink	Public Access	---/---/005/001	GT-S136	---	See Note 8	---	See Note 7	28.0	See Note 6	5.1	None
Rm. 242A - Work Room	Sink	Secured - SCSD Staff Only	056	GT-S148	9.9	None	---	---	---	---	---	---
Rm. 242A - Work Room	Sink	Secured - SCSD Staff Only	062/004/004	GT-S149	28.3	See Note 9	238.0	See Note 6	2.3	None	---	---
Rm. 270 - Hallway/Vestibule	Fountain	Public Access	128	GT-F102	1.6	None	---	---	---	---	---	---
Rm. 294 - Home & Careers Room	Sink	Public Access	109	GT-S125	3.9	None	---	---	---	---	---	---
Rm. 294 - Home & Careers Room	Sink	Public Access	111	GT-S126	6.7	None	---	---	---	---	---	---
Rm. 296 - Home & Careers Room	Sink	Public Access	105/005/007	GT-S120	32.0	See Note 6	18.0	See Note 6	12.5	None	---	---

**SYRACUSE CITY SCHOOL DISTRICT
GRANT MIDDLE SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE ID No.	TDK SAMPLE ID No.	08/06/20 RESULTS (ppb)	08/06/20 ORIGINAL ACTIONS	10/24/20 RESULTS (ppb)	10/24/20 RE- SAMPLE ACTIONS	12/30/20 RESULTS (ppb)	12/30/20 RE- SAMPLE ACTIONS	01/23/21 RESULTS (ppb)	01/23/21 RE- SAMPLE ACTIONS
Rm. 296 - Home & Careers Room	Sink	Public Access	---/---/---	GT-S121	---	See Note 8	---	See Note 7	---	---	---	---
Rm. 296 - Home & Careers Room	Sink	Public Access	104	GT-S122	0.84	None	---	---	---	---	---	---
Rm. 317 - Work Room	Sink	Secured - SCSD Staff Only	013/002	GT-S237	17.8	See Note 9	23.2	See Note 6	25.4	See Note 7	---	---
Rm. 317 - Work Room	Sink	Secured - SCSD Staff Only	012	GT-S238	7.4	None	---	---	---	---	---	---
Rm. 131 - Serving Room	Ice Machine	Secured - SCSD Staff Only	031	GT-S1000	<1.0	None	---	---	---	---	---	---
Rm. 152 - Vestibule	Fountain	Public Access	046	GT-F1000	<1.0	None	---	---	---	---	---	---
Rm. 152 - Vestibule	Sink	Public Access	047	GT-S1001	0.79	None	---	---	---	---	---	---
Rm. 152 - Vestibule	Sink	Public Access	048	GT-S1002	0.70	None	---	---	---	---	---	---
Rm. 155B - Vestibule	Sink	Public Access	067	GT-S1003	0.50	None	---	---	---	---	---	---
Rm. 155B - Vestibule	Sink	Public Access	068	GT-S1004	0.56	None	---	---	---	---	---	---
Rm. 120 - Hallway/ Corridor	Fountain	Public Access	074	GT-F1001	<1.0	None	---	---	---	---	---	---
Rm. 120 - Hallway/ Corridor	Fountain	Public Access	073	GT-F1002	<1.0	None	---	---	---	---	---	---
Rm. 155B - Vestibule	Sink	Public Access	071	GT-S1005	7.5	None	---	---	---	---	---	---
Rm. 155B - Vestibule	Sink	Public Access	072	GT-S1007	0.46	None	---	---	---	---	---	---
Rm. 189B - Vestibule	Sink	Public Access	101	GT-S1008	0.64	None	---	---	---	---	---	---
Rm. 189B - Vestibule	Sink	Public Access	102	GT-S1009	0.54	None	---	---	---	---	---	---
Rm. 189B - Vestibule	Sink	Public Access	094	GT-S1010	0.41	None	---	---	---	---	---	---
Rm. 189B - Vestibule	Sink	Public Access	096	GT-S1011	0.46	None	---	---	---	---	---	---
Rm. 189B - Vestibule	Sink	Public Access	097	GT-S1012	0.44	None	---	---	---	---	---	---
Rm. 189B - Vestibule	Sink	Public Access	100	GT-S1013	0.86	None	---	---	---	---	---	---
Rm. 139 - Hallway/ Corridor	Fountain	Public Access	090	GT-F1003	<1.0	None	---	---	---	---	---	---
Rm. 139 - Hallway/ Corridor	Fountain	Public Access	092	GT-F1004	<1.0	None	---	---	---	---	---	---
Rm. 151 - Vestibule	Sink	Public Access	116	GT-S1014	1.6	None	---	---	---	---	---	---
Rm. 247 - ADA Bathroom	Sink	Public Access	045	GT-S1015	<1.0	None	---	---	---	---	---	---
Rm. 218 - Hallway/ Corridor	Fountain	Public Access	043	GT-F1005	<1.0	None	---	---	---	---	---	---
Rm. 218 - Hallway/ Corridor	Fountain	Public Access	044	GT-F1006	0.77	None	---	---	---	---	---	---
Rm. 262 - Vestibule	Sink	Public Access	065	GT-S1016	1.3	None	---	---	---	---	---	---
Rm. 262 - Vestibule	Sink	Public Access	069	GT-S1017	1.7	None	---	---	---	---	---	---
Rm. 262 - Vestibule	Fountain	Public Access	066	GT-F1007	<1.0	None	---	---	---	---	---	---
Rm. 260A - Vestibule	Sink	Public Access	078	GT-S1018	0.50	None	---	---	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT
GRANT MIDDLE SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE ID No.	TDK SAMPLE ID No.	08/06/20 RESULTS (ppb)	08/06/20 ORIGINAL ACTIONS	10/24/20 RESULTS (ppb)	10/24/20 RE- SAMPLE ACTIONS	12/30/20 RESULTS (ppb)	12/30/20 RE- SAMPLE ACTIONS	01/23/21 RESULTS (ppb)	01/23/21 RE- SAMPLE ACTIONS
Rm. 260A - Vestibule	Sink	Public Access	079	GT-S1019	0.53	None	---	---	---	---	---	---
Rm. 260A - Vestibule	Sink	Public Access	080	GT-S1020	0.34	None	---	---	---	---	---	---
Rm. 260A - Vestibule	Sink	Public Access	082	GT-S1021	0.59	None	---	---	---	---	---	---
Rm. 208 - Hallway/ Corridor	Fountain	Public Access	075	GT-F1008	<1.0	None	---	---	---	---	---	---
Rm. 208 - Hallway/ Corridor	Fountain	Public Access	077	GT-F1009	<1.0	None	---	---	---	---	---	---
Rm. 255 - Hallway/ Corridor	Fountain	Public Access	088	GT-F1010	<1.0	None	---	---	---	---	---	---
Rm. 255 - Hallway/ Corridor	Fountain	Public Access	091	GT-F1011	<1.0	None	---	---	---	---	---	---
Rm. 250A - Vestibule	Sink	Public Access	093	GT-S1022	0.59	None	---	---	---	---	---	---
Rm. 250A - Vestibule	Sink	Public Access	095	GT-S1023	0.50	None	---	---	---	---	---	---
Rm. 250A - Vestibule	Sink	Public Access	099	GT-S1024	0.85	None	---	---	---	---	---	---
Rm. 250A - Vestibule	Sink	Public Access	098	GT-S1025	0.47	None	---	---	---	---	---	---
Rm. 207 - Boy's Bathroom	Sink	Public Access	113	GT-S1026	0.57	None	---	---	---	---	---	---
Rm. 211 - Girl's Lockerroom	Sink	Public Access	117	GT-S1027	1.6	None	---	---	---	---	---	---
Rm. 211 - Girl's Lockerroom	Sink	Public Access	119	GT-S1028	0.96	None	---	---	---	---	---	---
Rm. 220 - Boy's Lockerroom	Sink	Public Access	126	GT-S1029	1.1	None	---	---	---	---	---	---
Rm. 220 - Boy's Lockerroom	Sink	Public Access	124	GT-S1030	1.4	None	---	---	---	---	---	---
Rm. 271 - Vestibule	Fountain	Public Access	127	GT-F1012	<1.0	None	---	---	---	---	---	---
Rm. 210 - Hallway/ Corridor	Fountain	Public Access	120	GT-F1013	<1.0	None	---	---	---	---	---	---
Rm. 273 - Boy's Bathroom	Sink	Public Access	123	GT-S1031	7.1	None	---	---	---	---	---	---
Rm. 272 - Boy's Bathroom	Sink	Public Access	125/006	GT-S1032	16.4	See Note 6	7.1	None	---	---	---	---
Rm. 350 - ADA Bathroom	Sink	Public Access	009	GT-S1033	0.58	None	---	---	---	---	---	---
Rm. 315 - Hallway/ Corridor	Fountain	Public Access	006	GT-F1014	0.31	None	---	---	---	---	---	---
Rm. 133A - Kitchen	Sink	Public Access	024	GT-S3000	8.6	None	---	---	---	---	---	---
Rm. 315 - Hallway/ Corridor	Fountain	Public Access	005	GT-F1015	<1.0	None	---	---	---	---	---	---
Rm. 347 - Vestibule	Sink	Public Access	019	GT-S1034	0.5	None	---	---	---	---	---	---
Rm. 347 - Vestibule	Sink	Public Access	020	GT-S1035	0.6	None	---	---	---	---	---	---
Rm. 347 - Vestibule	Fountain	Public Access	018	GT-F1016	<1.0	None	---	---	---	---	---	---
Rm. 308 - Hallway/ Corridor	Fountain	Public Access	025	GT-F1017	0.28	None	---	---	---	---	---	---
Rm. 308 - Hallway/ Corridor	Fountain	Public Access	026	GT-F1018	<1.0	None	---	---	---	---	---	---
Rm. 344B - Vestibule	Sink	Public Access	028	GT-S1036	0.57	None	---	---	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT
GRANT MIDDLE SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE ID No.	TDK SAMPLE ID No.	08/06/20 RESULTS (ppb)	08/06/20 ORIGINAL ACTIONS	10/24/20 RESULTS (ppb)	10/24/20 RE- SAMPLE ACTIONS	12/30/20 RESULTS (ppb)	12/30/20 RE- SAMPLE ACTIONS	01/23/21 RESULTS (ppb)	01/23/21 RE- SAMPLE ACTIONS
Rm. 344B - Vestibule	Sink	Public Access	027	GT-S1037	0.63	None	---	---	---	---	---	---
Rm. 344B - Vestibule	Sink	Public Access	029	GT-S1038	0.50	None	---	---	---	---	---	---
Rm. 344B - Vestibule	Sink	Public Access	030	GT-S1039	0.37	None	---	---	---	---	---	---
Rm. 326 - Hallway/ Corridor	Fountain	Public Access	034	GT-F1019	<1.0	None	---	---	---	---	---	---
Rm. 326 - Hallway/ Corridor	Fountain	Public Access	033	GT-F1020	<1.0	None	---	---	---	---	---	---
Rm. 375B - Vestibule	Sink	Public Access	037	GT-S1040	0.70	None	---	---	---	---	---	---
Rm. 375B - Vestibule	Sink	Public Access	038	GT-S1041	0.58	None	---	---	---	---	---	---
Rm. 375B - Vestibule	Sink	Public Access	041	GT-S1042	0.42	None	---	---	---	---	---	---
Rm. 375B - Vestibule	Sink	Public Access	040	GT-S1043	0.41	None	---	---	---	---	---	---
Rm. 140E - Boy's Locker Room Bathroom	Sink	Public Access	138	GT-S1044	0.76	None	---	---	---	---	---	---
Rm. 137 - Girls Locker Room Bathroom	Sink	Public Access	139	GT-S1045	0.81	None	---	---	---	---	---	---
Rm. 184 - Swimming Pool	Fountain	Public Access	134	GT-F1021	0.52	None	---	---	---	---	---	---
Rm. 372 - Art Room	Sink	Public Access	001/001/001	GT-S5000	15.4	See Note 6	35.4	See Note 6	3.0	None	---	---
Rm. 372 - Art Room	Sink	Public Access	003	GT-S5001	7.9	None	---	---	---	---	---	---
Rm. 371 - Classroom	Sink	Public Access	011/003	GT-S5002	68.0	See Note 6	7.9	None	---	---	---	---
Rm. 370 - Classroom	Sink	Public Access	015	GT-S5003	10.2	None	---	---	---	---	---	---
Rm. 370 - Classroom	Sink	Public Access	016	GT-S5004	76.5	See Note 7	---	---	---	---	---	---
Rm. 133A - Kitchen	Convotharm (Oven)	Secured - SCSD Staff Only	039	GT-C1000	14.1	None	---	---	---	---	---	---
Rm. 133A - Kitchen	Convotharm (Oven)	Secured - SCSD Staff Only	042	GT-C1001	9.0	None	---	---	---	---	---	---
Rm. 151 - Vestibule	Sink	Public Access	045	GT-S1014B	<1.0	None	---	---	---	---	---	---
Rm. 243 - Art Room	Sink	Public Access	051	GT-S5005	13.2	None	---	---	---	---	---	---
Rm. 243 - Art Room	Sink	Public Access	052	GT-S5006	8.9	None	---	---	---	---	---	---
Rm. 242 - Classroom	Sink	Public Access	053	GT-S5007	18.8	See Note 7	---	---	---	---	---	---
Rm. 242 - Classroom	Sink	Public Access	055	GT-S5008	28.6	See Note 7	---	---	---	---	---	---
Rm. 241 - Classroom	Sink	Public Access	060	GT-S5009	59.5	See Note 7	---	---	---	---	---	---
Rm. 241 - Classroom	Sink	Public Access	061	GT-S5010	7.8	None	---	---	---	---	---	---
Rm. 155A - ADA Toilet	Sink	Public Access	064	GT-S3001	0.39	None	---	---	---	---	---	---
Rm. 189B - Vestibule	Sink	Public Access	098	GT-S1012SA	0.47	None	---	---	---	---	---	---

SYRACUSE CITY SCHOOL DISTRICT GRANT MIDDLE SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE ID No.	TDK SAMPLE ID No.	08/06/20 RESULTS (ppb)	08/06/20 ORIGINAL ACTIONS	10/24/20 RESULTS (ppb)	10/24/20 RE- SAMPLE ACTIONS	12/30/20 RESULTS (ppb)	12/30/20 RE- SAMPLE ACTIONS	01/23/21 RESULTS (ppb)	01/23/21 RE- SAMPLE ACTIONS
Rm. 189A - ADA Toilet	Sink	Public Access	103	GT-S3002	0.72	None	---	---	---	---	---	---
Rm. 151 - Vestibule	Sink	Public Access	044	GT-S1014A	0.77	None	---	---	---	---	---	---
Rm. 181 - Classroom	Sink	Public Access	131	GT-S3004	7.8	None	---	---	---	---	---	---
Rm. 185C - Office	Sink	Secured - SCSD Staff Only	122/---/013/008	GT-S3003A	208.0	See Notes 6 & 10	42.4	See Note 6	5.2	None	---	---
Rm. 238 - Classroom	Sink	Public Access	---/---/006	GT-S136A	---	---	---	See Note 8	6.6	None	---	---

Original Sample Notes: [August 6, 2020 Event]

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-032
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70141198
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed, replaced and resampled.
7. Fixture signed / placarded.
8. Fixture not operational or not accessible.
9. Replaced filter and resampled.
10. S3003A was designated as S3003 on 08/06/20.

Re-Sample Notes: [October 24, 2020 Event]

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-032
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70151491
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Remediation performed by SCSD and fixture resampled.
7. Fixture not operational or not accessible.
8. Fixture repaired and sampling performed.

Re-Sample Notes: [December 30, 2020 Event]

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-032
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70158334
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed, replaced and resampled.
7. Fixture signed / placarded.

SYRACUSE CITY SCHOOL DISTRICT GRANT MIDDLE SCHOOL

Re-Sample Notes: [January 23, 2021 Event]

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-032
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70160642
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.