

**SYRACUSE CITY SCHOOL DISTRICT
HW SMITH PK - GRADE 8 SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE ID No.	TDK SAMPLE ID No.	07/21/20 RESULTS (ppb)	07/21/20 ORIGINAL ACTIONS	08/28/20 RE-SAMPLE RESULTS (ppb)	08/28/20 RE-SAMPLE ACTIONS	11/18/20 RE-SAMPLE RESULTS (ppb)	11/18/20 RE-SAMPLE ACTIONS
Rm. A-A - Classroom	Sink	Public Access	052	HW-S308	<1.0	None	---	---	---	---
Rm. A-A - Classroom	Sink	Public Access	138	HW-S309	2.2	None	---	---	---	---
Rm. A-01 - ESL Room	Sink	Public Access	---/---/002	HW-S306	---	See Note 6	---	See Note 6	1.3	None
Rm. A-01 - ESL Room	Sink	Public Access	053	HW-S307	<1.0	None	---	---	---	---
Rm. A-02 - Classroom	Sink	Public Access	---/002/001	HW-S312	---	See Note 6	4.3	None	2.2	None
Rm. A-02 - Classroom	Sink	Public Access	048/001	HW-S313	23.8	See Note 7	6.1	None	---	---
Rm. A-03 - Classroom	Sink	Public Access	037	HW-S315	9.4	None	---	---	---	---
Rm. A-03 - Classroom	Fountain	Public Access	034	HW-F302	1.9	None	---	---	---	---
Rm. A-03B - Classroom Bathroom	Sink	Public Access	038	HW-S314	1.5	None	---	---	---	---
Rm. A-04 - Classroom	Sink	Public Access	031	HW-S316	3.0	None	---	---	---	---
Rm. A-04 - Classroom	Fountain	Public Access	029	HW-F303	3.2	None	---	---	---	---
Rm. A-04B - Classroom Bathroom	Sink	Public Access	033	HW-S317	1.2	None	---	---	---	---
Rm. A-05 - Classroom	Sink	Public Access	021	HW-S319	5.1	None	---	---	---	---
Rm. A-05 - Classroom	Fountain	Public Access	019	HW-F305	6.1	None	---	---	---	---
Rm. A-05B - Classroom Bathroom	Sink	Public Access	022	HW-S318	1.8	None	---	---	---	---
Rm. A-06 - Classroom	Sink	Public Access	016	HW-S322	<1.0	None	---	---	---	---
Rm. A-06 - Classroom	Fountain	Public Access	014	HW-F306	3.9	None	---	---	---	---
Rm. A-06B - Classroom Bathroom	Sink	Public Access	018	HW-S321	1.2	None	---	---	---	---
Rm. A-07 - Classroom	Sink	Public Access	011	HW-S324	1.4	None	---	---	---	---
Rm. A-07 - Classroom	Fountain	Public Access	013	HW-F307	<1.0	None	---	---	---	---
Rm. A-07B - Classroom Bathroom	Sink	Public Access	012	HW-S323	1.7	None	---	---	---	---
Rm. A-12 - Teacher's Work Room	Sink	Secured - SCSD Staff Only	024	HW-S320	4.6	None	---	---	---	---
Rm. A-16 - Staff Bathroom	Sink	Secured - SCSD Staff Only	043/003	HW-S311	30.3	See Note 7	3.6	None	---	---
Rm. A-17 - Staff Bathroom	Sink	Secured - SCSD Staff Only	045	HW-S310	2.3	None	---	---	---	---
Rm. A-22D - Storage Room	Sink	Secured - SCSD Staff Only	060	HW-S303	11.9	None	---	---	---	---
Rm. A-30A - Hallway/Corridor	Fountain	Public Access	026	HW-F304	<1.0	None	---	---	---	---
Rm. A-30D - Hallway/Vestibule	Sink	Public Access	058	HW-S301	2.1	None	---	---	---	---
Rm. A-30D - Hallway/Vestibule	Sink	Public Access	057	HW-S302	<1.0	None	---	---	---	---
Rm. A-30D - Hallway/Vestibule	Sink	Public Access	055	HW-S304	<1.0	None	---	---	---	---

SYRACUSE CITY SCHOOL DISTRICT
HW SMITH PK - GRADE 8 SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE ID No.	TDK SAMPLE ID No.	07/21/20 RESULTS (ppb)	07/21/20 ORIGINAL ACTIONS	08/28/20 RE-SAMPLE RESULTS (ppb)	08/28/20 RE-SAMPLE ACTIONS	11/18/20 RE-SAMPLE RESULTS (ppb)	11/18/20 RE-SAMPLE ACTIONS
Rm. A-30D - Hallway/Vestibule	Sink	Public Access	056	HW-S305	3.4	None	---	---	---	---
Rm. A-30H - Hallway/Corridor	Fountain	Public Access	059	HW-F301	<1.0	None	---	---	---	---
Rm. A-33 - Classroom	Sink	Public Access	001	HW-S104	2.6	None	---	---	---	---
Rm. A-33 - Classroom	Fountain	Public Access	003	HW-F101	<1.0	None	---	---	---	---
Rm. A-33B - Classroom Bathroom	Sink	Public Access	002	HW-S103	1.5	None	---	---	---	---
Rm. A-34 - Staff Bathroom	Sink	Secured - SCSD Staff Only	009	HW-S105	<1.0	None	---	---	---	---
Rm. A-35 - Classroom	Sink	Public Access	005	HW-S102	<1.0	None	---	---	---	---
Rm. A-35 - Classroom	Fountain	Public Access	007	HW-F100	2.1	None	---	---	---	---
Rm. A-35B - Classroom Bathroom	Sink	Public Access	008	HW-S101	<1.0	None	---	---	---	---
Rm. A100B - Girl's Bathroom	Sink	Public Access	111	HW-S106	<1.0	None	---	---	---	---
Rm. A100C - Girl's Bathroom	Sink	Public Access	112	HW-S107	<1.0	None	---	---	---	---
Rm. A100D - Boy's Bathroom	Sink	Public Access	115	HW-S108	2.0	None	---	---	---	---
Rm. A100E - Boy's Bathroom	Sink	Public Access	107/008	HW-S109	156	See Note 7	3.1	None	---	---
Rm. A100J - Hallway/Corridor	Fountain	Public Access	073	HW-F308	<1.0	None	---	---	---	---
Rm. A100K - Hallway/Corridor	Fountain	Public Access	110	HW-F102	<1.0	None	---	---	---	---
Rm. A100K - Hallway/Corridor	Fountain	Public Access	109	HW-F103	<1.0	None	---	---	---	---
Rm. A104 - Office	Sink	Secured - SCSD Staff Only	102	HW-S110	<1.0	None	---	---	---	---
Rm. A106 - Copy Room	Sink	Secured - SCSD Staff Only	100	HW-S112	2.2	None	---	---	---	---
Rm. A106A - Staff Bathroom	Sink	Secured - SCSD Staff Only	101	HW-S111	<1.0	None	---	---	---	---
Rm. A106A - Staff Bathroom	Sink	Secured - SCSD Staff Only	071	HW-S341	1.4	None	---	---	---	---
Rm. A108 - Art Room	Sink	Public Access	098	HW-S113	4.6	None	---	---	---	---
Rm. A108 - Art Room	Sink	Public Access	097/005/004	HW-S114	37.3	See Note 7	15.9	See Note 7	6.1	None
Rm. A108 - Art Room	Sink	Public Access	099	HW-S115	1.4	None	---	---	---	---
Rm. A108C - Home & Careers Room	Sink	Public Access	089	HW-S337	1.1	None	---	---	---	---
Rm. A108C - Home & Careers Room	Sink	Public Access	091	HW-S338	1.2	None	---	---	---	---
Rm. A108C - Home & Careers Room	Sink	Public Access	092	HW-S339	3.5	None	---	---	---	---
Rm. A108C - Home & Careers Room	Sink	Public Access	093	HW-S340	5.0	None	---	---	---	---
Rm. A109 - Science Room	Sink	Public Access	084/004/003	HW-S333	15.2	See Note 7	50.2	See Note 7	7.5	None
Rm. A109 - Science Room	Sink	Public Access	086	HW-S334	9.7	None	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT
HW SMITH PK - GRADE 8 SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE ID No.	TDK SAMPLE ID No.	07/21/20 RESULTS (ppb)	07/21/20 ORIGINAL ACTIONS	08/28/20 RE-SAMPLE RESULTS (ppb)	08/28/20 RE-SAMPLE ACTIONS	11/18/20 RE-SAMPLE RESULTS (ppb)	11/18/20 RE-SAMPLE ACTIONS
Rm. A109 - Science Room	Sink	Public Access	088	HW-S335	2.7	None	---	---	---	---
Rm. A109B - Boy's Bathroom	Sink	Public Access	081	HW-S331	4.4	None	---	---	---	---
Rm. A110 - Technology Shop	Sink	Public Access	095	HW-S336	1.4	None	---	---	---	---
Rm. A112 - Classroom	Sink	Public Access	069	HW-S342	<1.0	None	---	---	---	---
Rm. A112B - Girl's Bathroom	Sink	Public Access	075	HW-S329	1.1	None	---	---	---	---
Rm. A113 - Science Room	Sink	Public Access	078	HW-S326	<1.0	None	---	---	---	---
Rm. A113 - Science Room	Sink	Public Access	079	HW-S327	1.9	None	---	---	---	---
Rm. A113 - Science Room	Sink	Public Access	080	HW-S328	12.2	None	---	---	---	---
Rm. A113B - Boy's Bathroom	Sink	Public Access	082	HW-S332	1.1	None	---	---	---	---
Rm. A120A - Girl's Bathroom	Sink	Public Access	077	HW-S330	1.4	None	---	---	---	---
Rm. A122 - Classroom	Sink	Public Access	063	HW-S343	4.8	None	---	---	---	---
Rm. A123 - Classroom	Sink	Public Access	065	HW-S344	1.9	None	---	---	---	---
Rm. A125 - Classroom	Sink	Public Access	067	HW-S345	2.2	None	---	---	---	---
Rm. A200 - Girl's Bathroom	Sink	Public Access	090	HW-S369	1.0	None	---	---	---	---
Rm. A200B - Hallway/Corridor	Fountain	Public Access	094	HW-F311	<1.0	None	---	---	---	---
Rm. A200B - Hallway/Corridor	Fountain	Public Access	096	HW-F312	<1.0	None	---	---	---	---
Rm. A200C - Girl's Bathroom	Sink	Public Access	087	HW-S368	1.9	None	---	---	---	---
Rm. A200D - Boy's Bathroom	Sink	Public Access	085	HW-S367	1.5	None	---	---	---	---
Rm. A200E - Boy's Bathroom	Sink	Public Access	076	HW-S365	1.1	None	---	---	---	---
Rm. A202B - Classroom	Sink	Public Access	083	HW-S366	7.1	None	---	---	---	---
Rm. A205A - Hallway/Corridor	Fountain	Public Access	066	HW-F310	<1.0	None	---	---	---	---
Rm. A206B - Staff's Bathroom	Sink	Secured - SCSD Staff Only	074	HW-S364	<1.0	None	---	---	---	---
Rm. A208A - Copy Room	Sink	Secured - SCSD Staff Only	072	HW-S363	<1.0	None	---	---	---	---
Rm. A209B - Boy's Bathroom	Sink	Public Access	070	HW-S362	1.1	None	---	---	---	---
Rm. A214A - Girl's Bathroom	Sink	Public Access	064	HW-S360	<1.0	None	---	---	---	---
Rm. A215B - Boy's Bathroom	Sink	Public Access	068	HW-S361	<1.0	None	---	---	---	---
Rm. A216B - Girl's Bathroom	Sink	Public Access	062	HW-S359	1.3	None	---	---	---	---
Rm. B-03 - Staff Bathroom	Sink	Secured - SCSD Staff Only	061	HW-S100	6.7	None	---	---	---	---
Rm. B106 - Staff Bathroom	Sink	Secured - SCSD Staff Only	129	HW-S126	2.0	None	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT
HW SMITH PK - GRADE 8 SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE ID No.	TDK SAMPLE ID No.	07/21/20 RESULTS (ppb)	07/21/20 ORIGINAL ACTIONS	08/28/20 RE-SAMPLE RESULTS (ppb)	08/28/20 RE-SAMPLE ACTIONS	11/18/20 RE-SAMPLE RESULTS (ppb)	11/18/20 RE-SAMPLE ACTIONS
Rm. B106 - Staff Bathroom	Sink	Secured - SCSD Staff Only	131	HW-S127	1.6	None	---	---	---	---
Rm. B109 - Boy's Locker Room	Fountain	Public Access	103	HW-F105	<1.0	None	---	---	---	---
Rm. B112 - Boy's Bathroom	Sink	Public Access	104	HW-S116	10.9	None	---	---	---	---
Rm. B116A - Boy's Coach Bathroom	Sink	Secured - SCSD Staff Only	106/009	HW-S117	22.4	See Note 7	4.4	None	---	---
Rm. B119A - Girl's Coach Bathroom	Sink	Secured - SCSD Staff Only	108	HW-S118	1.7	None	---	---	---	---
Rm. B123 - Girl's Bathroom	Sink	Public Access	114	HW-S119	2.4	None	---	---	---	---
Rm. B126 - Girl's Locker Room	Fountain	Public Access	113	HW-F106	<1.0	None	---	---	---	---
Rm. B128 - OT/PT Room	Sink	Public Access	127	HW-S121	<1.0	None	---	---	---	---
Rm. B128A - OT/PT Room Bathroom	Sink	Public Access	125	HW-S120	1.4	None	---	---	---	---
Rm. B131 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	117	HW-S347	2.0	None	---	---	---	---
Rm. B132 - Dental Room	Sink	Public Access	118	HW-S346	<1.0	None	---	---	---	---
Rm. B133 - Health Center Bathroom	Sink	Public Access	120/007	HW-S349	16.2	See Note 7	6.3	None	---	---
Rm. B134 - Hallway/Corridor	Fountain	Public Access	105	HW-F104	<1.0	None	---	---	---	---
Rm. B135B - Exam Room	Sink	Public Access	122	HW-S353	3.6	None	---	---	---	---
Rm. B136 - Health Center	Sink	Public Access	124	HW-S348	2.5	None	---	---	---	---
Rm. B138 - Nurse's Room	Sink	Public Access	128	HW-S352	4.2	None	---	---	---	---
Rm. B138A - Nurse's Bathroom	Sink	Public Access	126/006	HW-S351	22.2	See Note 7	13.6	None	---	---
Rm. B147 - Staff Office Bathroom	Sink	Secured - SCSD Staff Only	132	HW-S356	2.3	None	---	---	---	---
Rm. B149 - Main Office	Sink	Secured - SCSD Staff Only	133	HW-S357	10.8	None	---	---	---	---
Rm. B164 - Library Bathroom	Sink	Public Access	137	HW-S358	1.0	None	---	---	---	---
Rm. B168 - Conference Room	Sink	Secured - SCSD Staff Only	136	HW-S355	1.6	None	---	---	---	---
Rm. B171 - Staff Bathroom	Sink	Secured - SCSD Staff Only	135	HW-S354	<1.0	None	---	---	---	---
Rm. B172 - Work Room	Sink	Secured - SCSD Staff Only	121	HW-S125	1.7	None	---	---	---	---
Rm. B173 - Work Room Bathroom	Sink	Secured - SCSD Staff Only	123	HW-S124	2.2	None	---	---	---	---
Rm. B174 - Staff Bathroom	Sink	Secured - SCSD Staff Only	116	HW-S123	3.3	None	---	---	---	---
Rm. B176 - Classroom Bathroom	Sink	Public Access	119	HW-S122	1.8	None	---	---	---	---
Rm. B204 - Hallway/Corridor	Fountain	Public Access	039	HW-F108	<1.0	None	---	---	---	---
Rm. B209 - Hallway/Corridor	Fountain	Public Access	035	HW-F107	<1.0	None	---	---	---	---
Rm. B210 - Girl's Bathroom	Sink	Public Access	025	HW-S132	4.0	None	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT
HW SMITH PK - GRADE 8 SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE ID No.	TDK SAMPLE ID No.	07/21/20 RESULTS (ppb)	07/21/20 ORIGINAL ACTIONS	08/28/20 RE-SAMPLE RESULTS (ppb)	08/28/20 RE-SAMPLE ACTIONS	11/18/20 RE-SAMPLE RESULTS (ppb)	11/18/20 RE-SAMPLE ACTIONS
Rm. B210 - Girl's Bathroom	Sink	Public Access	027	HW-S133	1.6	None	---	---	---	---
Rm. B210 - Girl's Bathroom	Sink	Public Access	028	HW-S134	2.8	None	---	---	---	---
Rm. B211 - Boy's Bathroom	Sink	Public Access	032	HW-S135	2.0	None	---	---	---	---
Rm. B211 - Boy's Bathroom	Sink	Public Access	030	HW-S136	4.8	None	---	---	---	---
Rm. B220 - Band Room	Sink	Public Access	041	HW-S137	4.2	None	---	---	---	---
Rm. B222 - Kitchen	Sink	Secured - SCSD Staff Only	054	HW-S370	<1.0	None	---	---	---	---
Rm. B222 - Kitchen	Sink	Secured - SCSD Staff Only	036/010	HW-S371	76.6	See Note 7	6.3	None	---	---
Rm. B222 - Kitchen	Sink	Secured - SCSD Staff Only	040	HW-S372	5.9	None	---	---	---	---
Rm. B222 - Kitchen	Sink	Secured - SCSD Staff Only	042	HW-S373	3.6	None	---	---	---	---
Rm. B222 - Kitchen	Sink	Secured - SCSD Staff Only	046	HW-S374	<1.0	None	---	---	---	---
Rm. B222 - Kitchen	Sink	Secured - SCSD Staff Only	049	HW-S375	<1.0	None	---	---	---	---
Rm. B222B - Kitchen Serving Area	Sink	Secured - SCSD Staff Only	051	HW-S377	2.4	None	---	---	---	---
Rm. B224 - Kitchen Bathroom	Sink	Secured - SCSD Staff Only	044	HW-S376	2.4	None	---	---	---	---
Rm. B231A - Classroom Bathroom	Sink	Public Access	017	HW-S131	1.3	None	---	---	---	---
Rm. B232A - Classroom Bathroom	Sink	Public Access	015	HW-S130	1.4	None	---	---	---	---
Rm. B233A - Classroom Bathroom	Sink	Public Access	006	HW-S129	1.4	None	---	---	---	---
Rm. B234A - Classroom Bathroom	Sink	Public Access	004	HW-S128	2.6	None	---	---	---	---
Rm. B233 - Classroom	Fountain	Public Access	010	HW-F3000	10.7	None	---	---	---	---
Rm. B232 - Classroom	Fountain	Public Access	020	HW-F3002	5.3	None	---	---	---	---
Rm. B231 - Classroom	Sink	Public Access	023	HW-S3003	1.9	None	---	---	---	---
Rm. B222 - Kitchen	Convotharm Oven	Secured - SCSD Staff Only	047/011	HW-C1000	17.1	See Note 8	4.1	None	---	---
Rm. B222 - Kitchen	Convotharm Oven	Secured - SCSD Staff Only	050/012	HW-C1001	68.7	See Note 8	4.0	None	---	---
Rm. B139 - Office	Sink	Public Access	130	HW-S1000	1.8	None	---	---	---	---
Rm. B104 - Hallway/Corridor	Fountain	Public Access	134	HW-F3004	<1.0	None	---	---	---	---
Rm. B234 - Classroom	Fountain	Public Access	---/---/005	HW-F3001	---	See Note 6	---	See Note 6	7.3	None

SYRACUSE CITY SCHOOL DISTRICT

HW SMITH PK - GRADE 8 SCHOOL

Original Sample Notes [July 21, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-018
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70139558
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture not operating.
7. Fixture removed, replaced and resampled.
8. In-line filter installed by SCSD and resampling performed.

Re-Sample Notes [August 28, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-018
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70143989
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture not operating.
7. Remediation performed by SCSD.

Re-Sample Notes [November 18, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-018
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70134141
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Remediation performed by SCSD.