

SYRACUSE CITY SCHOOL DISTRICT
HUGHES and SYRACUSE LATIN ELEMENTARY SCHOOLS

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	07/07/20 RESULTS (ppb)	07/07/20 ACTIONS	11/04/20 RESULTS (ppb)	11/04/20 ACTIONS	12/30/20 RESULTS (ppb)	12/30/20 ACTIONS
Rm. 001A - Staff Bathroom	Sink	Secured - SCSD Staff Only	027	HS-S100	1.4	None	--	--	--	--
Rm. 002 - Music Room	Sink	Public Access	038	HS-S102	6.9	None	--	--	--	--
Rm. 002 - Music Room	Fountain	Public Access	035	HS-F101	1.1	None	--	--	--	--
Rm. 002A - Music Room Bathroom	Sink	Public Access	034	HS-S101	4.0	None	--	--	--	--
Rm. 003 - Classroom	Sink	Public Access	030	HS-S104	1.9	None	--	--	--	--
Rm. 003 - Classroom	Fountain	Public Access	031	HS-F103	7.9	None	--	--	--	--
Rm. 004 - Classroom	Sink	Public Access	022	HS-S103	1.0	None	--	--	--	--
Rm. 004 - Classroom	Fountain	Public Access	024	HS-F102	3.9	None	--	--	--	--
Rm. 007 - Home & Careers Room	Sink	Public Access	016	HS-S106	<1.0	None	--	--	--	--
Rm. 007 - Home & Careers Room	Sink	Public Access	018	HS-S107	<1.0	None	--	--	--	--
Rm. 008 - Classroom	Sink	Public Access	013	HS-S108	1.0	None	--	--	--	--
Rm. 008 - Classroom	Fountain	Public Access	014 / 005	HS-F104	26.7	See Note 6	<1.0	None	--	--
Rm. 009 - Classroom	Sink	Public Access	009	HS-S109	<1.0	None	--	--	--	--
Rm. 009 - Classroom	Fountain	Public Access	010	HS-F105	10.2	None	--	--	--	--
Rm. 010 - Classroom	Sink	Public Access	007	HS-S110	6.0	None	--	--	--	--
Rm. 010 - Classroom	Fountain	Public Access	008 / 004	HS-F106	18.0	See Note 6	1.3	None	--	--
Rm. 011 - Classroom	Sink	Public Access	005	HS-S111	6.8	None	--	--	--	--
Rm. 011 - Classroom	Fountain	Public Access	006	HS-F107	5.2	None	--	--	--	--
Rm. 012 - Classroom	Sink	Public Access	001	HS-S112	7.3	None	--	--	--	--
Rm. 012 - Classroom	Fountain	Public Access	002	HS-F108	11.6	None	--	--	--	--
Rm. 013 - Classroom	Sink	Public Access	003	HS-S113	5.3	None	--	--	--	--
Rm. 013 - Classroom	Fountain	Public Access	004	HS-F109	3.5	None	--	--	--	--
Rm. 024 - Hallway/Corridor	Fountain	Public Access	040	HS-F114	5.6	None	--	--	--	--
Rm. 024 - Hallway/Corridor	Fountain	Public Access	093	HS-F120	12.3	None	--	--	--	--
Rm. 024A - Custodian's Bathroom	Sink	Secured - SCSD Staff Only	019	HS-S105	<1.0	None	--	--	--	--
Rm. 037 - Staff Bathroom	Sink	Secured - SCSD Staff Only	039	HS-S124	<1.0	None	--	--	--	--
Rm. 037C - Hallway/Corridor	Fountain	Public Access	026	HS-F100	<1.0	None	--	--	--	--
Rm. 050 - Hallway/Corridor	Fountain	Public Access	046	HS-F115	<1.0	None	--	--	--	--

SYRACUSE CITY SCHOOL DISTRICT
HUGHES and SYRACUSE LATIN ELEMENTARY SCHOOLS

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	07/07/20 RESULTS (ppb)	07/07/20 ACTIONS	11/04/20 RESULTS (ppb)	11/04/20 ACTIONS	12/30/20 RESULTS (ppb)	12/30/20 ACTIONS
Rm. 051 - Hallway/Corridor	Fountain	Public Access	074	HS-F119	<1.0	None	--	--	--	--
Rm. 057 - Boy's Bathroom	Sink	Public Access	048	HS-S127	4.5	None	--	--	--	--
Rm. 057 - Boy's Bathroom	Sink	Public Access	049	HS-S128	3.8	None	--	--	--	--
Rm. 093 - Girl's Bathroom	Sink	Public Access	076	HS-S143	2.5	None	--	--	--	--
Rm. 093 - Girl's Bathroom	Sink	Public Access	077	HS-S144	6.3	None	--	--	--	--
Rm. 103 - Kitchen	Sink	Secured - SCSD Staff Only	075	HS-S162	1.5	None	--	--	--	--
Rm. 103 - Kitchen	Sink	Secured - SCSD Staff Only	078	HS-S163	4.6	None	--	--	--	--
Rm. 103 - Kitchen	Sink	Secured - SCSD Staff Only	079	HS-S164	6.4	None	--	--	--	--
Rm. 103 - Kitchen	Sink	Secured - SCSD Staff Only	080	HS-S165	12.6	None	--	--	--	--
Rm. 103X - Classroom	Sink	Public Access	011	HS-S114	9.2	None	--	--	--	--
Rm. 104X - Kitchen Bathroom	Sink	Secured - SCSD Staff Only	084	HS-S161	6.9	None	--	--	--	--
Rm. 106 - Classroom	Sink	Public Access	012	HS-S115	2.0	None	--	--	--	--
Rm. 106 - Classroom	Fountain	Public Access	015	HS-F110	3.3	None	--	--	--	--
Rm. 107 - Classroom	Sink	Public Access	017	HS-S116	3.7	None	--	--	--	--
Rm. 108 - Classroom	Sink	Public Access	020	HS-S117	1.5	None	--	--	--	--
Rm. 108 - Classroom	Fountain	Public Access	021	HS-F111	3.7	None	--	--	--	--
Rm. 109 - Classroom	Sink	Public Access	023	HS-S118	13.7	None	--	--	--	--
Rm. 109 - Classroom	Fountain	Public Access	025	HS-F112	2.8	None	--	--	--	--
Rm. 110 - Classroom	Sink	Public Access	028	HS-S119	3.2	None	--	--	--	--
Rm. 110 - Classroom	Fountain	Public Access	029	HS-F113	2.6	None	--	--	--	--
Rm. 113 - Audiologist's Room	Sink	Public Access	037	HS-S121	9.6	None	--	--	--	--
Rm. 113A - Audiologist's Bathroom	Sink	Public Access	038	HS-S120	3.8	None	--	--	--	--
Rm. 114 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	032	HS-S122	<1.0	None	--	--	--	--
Rm. 114D - Teacher's Lounge Bathroom	Sink	Secured - SCSD Staff Only	033	HS-S123	<1.0	None	--	--	--	--
Rm. 121 - Girl's Bathroom	Sink	Public Access	089	HS-S157	2.7	None	--	--	--	--
Rm. 121 - Girl's Bathroom	Sink	Public Access	090	HS-S158	1.7	None	--	--	--	--
Rm. 122 - Boy's Bathroom	Sink	Public Access	091	HS-S159	<1.0	None	--	--	--	--
Rm. 122 - Boy's Bathroom	Sink	Public Access	092	HS-S160	<1.0	None	--	--	--	--

SYRACUSE CITY SCHOOL DISTRICT
HUGHES and SYRACUSE LATIN ELEMENTARY SCHOOLS

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	07/07/20 RESULTS (ppb)	07/07/20 ACTIONS	11/04/20 RESULTS (ppb)	11/04/20 ACTIONS	12/30/20 RESULTS (ppb)	12/30/20 ACTIONS
Rm. 123 - Classroom	Sink	Public Access	066	HS-S137	4.1	None	--	--	--	--
Rm. 123 - Classroom	Sink	Public Access	067 / 003	HS-S138	34.9	See Note 6	12.7	None	--	--
Rm. 123 - Classroom	Fountain	Public Access	068	HS-F118	5.7	None	--	--	--	--
Rm. 124 - Classroom	Sink	Public Access	069 / 002	HS-S135	23.1	See Note 6	5.1	None	--	--
Rm. 125 - Classroom	Sink	Public Access	063	HS-S133	5.6	None	--	--	--	--
Rm. 125 - Classroom	Sink	Public Access	064	HS-S134	2.3	None	--	--	--	--
Rm. 125 - Classroom	Fountain	Public Access	065	HS-F117	3.7	None	--	--	--	--
Rm. 126 - Classroom	Sink	Public Access	061	HS-S131	3.9	None	--	--	--	--
Rm. 126 - Classroom	Sink	Public Access	059	HS-S132	1.8	None	--	--	--	--
Rm. 126 - Classroom	Fountain	Public Access	060	HS-F116	1.7	None	--	--	--	--
Rm. 127 - Classroom	Sink	Public Access	054	HS-S129	3.9	None	--	--	--	--
Rm. 127 - Classroom	Sink	Public Access	055	HS-S130	3.1	None	--	--	--	--
Rm. 128C - Office Bathroom	Sink	Secured - SCSD Staff Only	070	HS-S139	4.0	None	--	--	--	--
Rm. 129 - Classroom	Sink	Public Access	072	HS-S140	1.4	None	--	--	--	--
Rm. 129 - Classroom	Sink	Public Access	073	HS-S141	14.6	None	--	--	--	--
Rm. 129B - Classroom Bathroom	Sink	Public Access	071	HS-S142	5.8	None	--	--	--	--
Rm. 137D - Hallway/Corridor	Fountain	Public Access	086	HS-F121	<1.0	None	--	--	--	--
Rm. 138B - Resource Room Bathroom	Sink	Public Access	085	HS-S147	1.5	None	--	--	--	--
Rm. 141 - Kitchen	Sink	Secured - SCSD Staff Only	087	HS-S148	9.6	None	--	--	--	--
Rm. 141 - Kitchen	Sink	Secured - SCSD Staff Only	088	HS-S149	1.4	None	--	--	--	--
Rm 142D - Main Office	Sink	Secured - SCSD Staff Only	101	HS-S152	2.6	None	--	--	--	--
Rm. 144 - Nurse's Office	Sink	Public Access	095	HS-S155	4.0	None	--	--	--	--
Rm. 144B - Nurse's Office Bathroom	Sink	Public Access	096 / 001	HS-S154	19.1	See Note 6	1.5	None	--	--
Rm. 144C - Nurse's Office Bathroom	Sink	Public Access	094	HS-S156	9.7	None	--	--	--	--
Rm. 144D - Exam Room	Sink	Public Access	098	HS-S153	1.9	None	--	--	--	--
Rm. 144E - Main Office Bathroom	Sink	Secured - SCSD Staff Only	100	HS-S151	2.1	None	--	--	--	--
Rm. 144F - Main Office Bathroom	Sink	Secured - SCSD Staff Only	099	HS-S150	2.7	None	--	--	--	--
Rm. 146 - Girl's Bathroom	Sink	Public Access	081	HS-S145	3.3	None	--	--	--	--

SYRACUSE CITY SCHOOL DISTRICT
HUGHES and SYRACUSE LATIN ELEMENTARY SCHOOLS

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	07/07/20 RESULTS (ppb)	07/07/20 ACTIONS	11/04/20 RESULTS (ppb)	11/04/20 ACTIONS	12/30/20 RESULTS (ppb)	12/30/20 ACTIONS
Rm. 146 - Girl's Bathroom	Sink	Public Access	082	HS-S146	3.2	None	--	--	--	--
Rm. 150 - Boy's Bathroom	Sink	Public Access	042	HS-S125	7.4	None	--	--	--	--
Rm. 150 - Boy's Bathroom	Sink	Public Access	043	HS-S126	5.0	None	--	--	--	--
Rm. 209 - Classroom	Sink	Public Access	056	HS-S171	3.6	None	--	--	--	--
Rm. 209 - Classroom	Fountain	Public Access	057	HS-F124	2.7	None	--	--	--	--
Rm. 211 - Classroom	Sink	Public Access	058	HS-S172	2.1	None	--	--	--	--
Rm. 211 - Classroom	Fountain	Public Access	062	HS-F125	7.4	None	--	--	--	--
Rm. 213A - Hallway/Corridor	Fountain	Public Access	044	HS-F122	1.4	None	--	--	--	--
Rm. 213B - Hallway/Corridor	Fountain	Public Access	051	HS-F123	<1.0	None	--	--	--	--
Rm. 217 - Staff Bathroom	Sink	Secured - SCSD Staff Only	045	HS-S168	2.3	None	--	--	--	--
Rm. 221 - Boy's Bathroom	Sink	Public Access	047	HS-S166	12.0	None	--	--	--	--
Rm. 221 - Boy's Bathroom	Sink	Public Access	050	HS-S167	1.1	None	--	--	--	--
Rm. 231 - Girl's Bathroom	Sink	Public Access	052	HS-S169	1.9	None	--	--	--	--
Rm. 231 - Girl's Bathroom	Sink	Public Access	053	HS-S170	5.5	None	--	--	--	--
Rm. 143Y - Clinic Bathroom	Sink	Public Access	041	HS-S2000	3.8	None	--	--	--	--
Rm. 103 - Kitchen	Convothem Oven	Secured - SCSD Staff Only	083 / 006	HS-S3000	47.1	See Note 7	7.7	None	--	--
Rm. 024 - Hallway/Corridor	Fountain	Public Access	097	HS-F3001	11.0	None	--	--	--	--
Rm. 107 - Classroom	Sink (Spray)	Public Access	---/---/ 001	HS-S116A	--	--	--	--	1.5	None

SYRACUSE CITY SCHOOL DISTRICT

HUGHES and SYRACUSE LATIN ELEMENTARY SCHOOLS

Original Sample Notes [July 7, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-019
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70137877
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed, replaced, and resampled.
7. Remediation performed by SCSD.

Re-Sample Notes [November 4, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-019
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70152550
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.

Re-Sample Notes [December 30, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-019
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70158353
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.