

**SYRACUSE CITY SCHOOL DISTRICT
INSTITUTE OF TECHNOLOGY AT SYRACUSE CENTRAL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	7/22/20 RESULTS (ppb)	7/22/20 ORIGINAL ACTIONS	8/28/20 RESULTS (ppb)	8/28/20 RESAMPLE ACTIONS	11/14/20 RESULTS (ppb)	11/14/20 RESAMPLE ACTIONS	11/21/20 RESULTS (ppb)	11/21/20 RESAMPLE ACTIONS
Rm. 007 - Storage Room	Sink	Secured - SCSD Staff Only	001	IT-S100	<1.0	None	---	---	---	---	---	---
Rm. 100 - Hallway/Corridor	Fountain	Public Access	079	IT-F106	<1.0	None	---	---	---	---	---	---
Rm. 100 - Hallway/Corridor	Fountain	Public Access	080	IT-F107	<1.0	None	---	---	---	---	---	---
Rm. 102 - Concessions Room	Sink	Secured - SCSD Staff Only	082	IT-S139	3.5	None	---	---	---	---	---	---
Rm. 102 - Concessions Room	Sink	Secured - SCSD Staff Only	083	IT-S140	4.3	None	---	---	---	---	---	---
Rm. 103 - Patient Room	Sink	Public Access	084	IT-S138	1.2	None	---	---	---	---	---	---
Rm. 110 - Boy's Gym Office Bathroom	Sink	Secured - SCSD Staff Only	077	IT-S148	2.7	None	---	---	---	---	---	---
Rm. 111 - Boy's Locker Room Bathroom	Sink	Public Access	072	IT-S145	1.1	None	---	---	---	---	---	---
Rm. 111 - Boy's Locker Room Bathroom	Sink	Public Access	073	IT-S146	1.9	None	---	---	---	---	---	---
Rm. 111 - Boy's Locker Room Bathroom	Sink	Public Access	075	IT-S147	1.1	None	---	---	---	---	---	---
Rm. 113 - Girl's Locker Room Bathroom	Sink	Public Access	056	IT-S141	2.5	None	---	---	---	---	---	---
Rm. 113 - Girl's Locker Room Bathroom	Sink	Public Access	057	IT-S142	1.7	None	---	---	---	---	---	---
Rm. 113 - Girl's Locker Room Bathroom	Sink	Public Access	059	IT-S143	2.1	None	---	---	---	---	---	---
Rm. 115 - Girl's Gym Office Bathroom	Sink	Secured - SCSD Staff Only	060	IT-S144	2.1	None	---	---	---	---	---	---
Rm. 116 - Hallway/Corridor	Fountain	Public Access	062	IT-F108	<1.0	None	---	---	---	---	---	---
Rm. 117 - Boy's Bathroom	Sink	Public Access	063	IT-S149	2.2	None	---	---	---	---	---	---
Rm. 117 - Boy's Bathroom	Sink	Public Access	064	IT-S150	1.0	None	---	---	---	---	---	---
Rm. 117 - Boy's Bathroom	Sink	Public Access	066	IT-S151	<1.0	None	---	---	---	---	---	---
Rm. 118 - Girl's Bathroom	Sink	Public Access	068	IT-S152	6.5	None	---	---	---	---	---	---
Rm. 118 - Girl's Bathroom	Sink	Public Access	070	IT-S153	2.0	None	---	---	---	---	---	---
Rm. 118 - Girl's Bathroom	Sink	Public Access	071	IT-S154	2.2	None	---	---	---	---	---	---
Rm. 133 - Nurse's Office	Sink	Public Access	090	IT-S106	1.7	None	---	---	---	---	---	---
Rm. 134 - Nurse's Office Bathroom	Sink	Public Access	091	IT-S105	2.8	None	---	---	---	---	---	---
Rm. 135 - Exam Room	Sink	Public Access	092	IT-S104	1.9	None	---	---	---	---	---	---
Rm. 138 - Library Bathroom	Sink	Public Access	081	IT-S134	5.5	None	---	---	---	---	---	---
Rm. 138 - Library	Sink	Public Access	085	IT-S135	13.1	None	---	---	---	---	---	---
Rm. 140 - Hallway/Corridor	Fountain	Public Access	078	IT-F100	<1.0	None	---	---	---	---	---	---
Rm. 147 - Main Office	Sink	Secured - SCSD Staff Only	088	IT-S137	3.4	None	---	---	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT
INSTITUTE OF TECHNOLOGY AT SYRACUSE CENTRAL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	7/22/20 RESULTS (ppb)	7/22/20 ORIGINAL ACTIONS	8/28/20 RESULTS (ppb)	8/28/20 RESAMPLE ACTIONS	11/14/20 RESULTS (ppb)	11/14/20 RESAMPLE ACTIONS	11/21/20 RESULTS (ppb)	11/21/20 RESAMPLE ACTIONS
Rm. 148 - Main Office Bathroom	Sink	Secured - SCSD Staff Only	086	IT-S136	<1.0	None	---	---	---	---	---	---
Rm. 157 - Tech Lab Bathroom	Sink	Public Access	049	IT-S131	6.6	None	---	---	---	---	---	---
Rm. 157 - Tech Lab	Fountain	Public Access	052	IT-F105	6.6	None	---	---	---	---	---	---
Rm. 157 - Tech Lab	Sink	Public Access	051/006/002	IT-S132	70.9	See Note 6	16.4	See Note 6	5.1	None	---	---
Rm. 157 - Tech Lab	Sink	Public Access	050/005/---/001	IT-S133	15.6	See Note 6	39.9	See Note 6	---	See Note 6	4.8	None
Rm. 163 - Lockers Bathroom	Sink	Public Access	048	IT-S130	5.1	None	---	---	---	---	---	---
Rm. 165 - Tech Lab	Fountain	Public Access	045	IT-F104	<1.0	None	---	---	---	---	---	---
Rm. 172 - Hallway/Corridor	Fountain	Public Access	033	IT-F103	<1.0	None	---	---	---	---	---	---
Rm. 174 - Teaching Kitchen	Sink	Public Access	031	IT-S121	<1.0	None	---	---	---	---	---	---
Rm. 174 - Teaching Kitchen	Sink	Public Access	028	IT-S122	<1.0	None	---	---	---	---	---	---
Rm. 174 - Teaching Kitchen	Sink	Public Access	026	IT-S123	3.5	None	---	---	---	---	---	---
Rm. 174 - Teaching Kitchen	Sink	Public Access	024/002	IT-S124	16.2	See Note 6	11.1	None	---	---	---	---
Rm. 174 - Teaching Kitchen	Sink	Public Access	020	IT-S125	1.5	None	---	---	---	---	---	---
Rm. 174 - Teaching Kitchen	Sink	Public Access	019	IT-S126	<1.0	None	---	---	---	---	---	---
Rm. 174 - Teaching Kitchen	Sink	Public Access	017	IT-S127	2.3	None	---	---	---	---	---	---
Rm. 174 - Teaching Kitchen	Sink	Public Access	022/001/003	IT-S128	36.9	See Note 6	253	See Note 7	5.1	None	---	---
Rm. 174 - Teaching Kitchen	Sink	Public Access	014	IT-S129	3.0	None	---	---	---	---	---	---
Rm. 177 - Home & Careers Room	Sink	Public Access	009	IT-S118	2.9	None	---	---	---	---	---	---
Rm. 177 - Home & Careers Room	Sink	Public Access	011	IT-S119	1.8	None	---	---	---	---	---	---
Rm. 179 - Unisex Bathroom	Sink	Public Access	007	IT-S120	1.5	None	---	---	---	---	---	---
Rm. 183 - Boy's Bathroom	Sink	Public Access	038	IT-S116	5.0	None	---	---	---	---	---	---
Rm. 183 - Boy's Bathroom	Sink	Public Access	035	IT-S117	2.9	None	---	---	---	---	---	---
Rm. 184 - Girl's Bathroom	Sink	Public Access	042	IT-S114	1.9	None	---	---	---	---	---	---
Rm. 184 - Girl's Bathroom	Sink	Public Access	040	IT-S115	2.6	None	---	---	---	---	---	---
Rm. 190 - Cafeteria	Fountain	Public Access	054	IT-F101	<1.0	None	---	---	---	---	---	---
Rm. 190 - Cafeteria	Fountain	Public Access	053	IT-F102	<1.0	None	---	---	---	---	---	---
Rm. 192 - Warming Kitchen	Sink	Secured - SCSD Staff Only	055	IT-S107	2.4	None	---	---	---	---	---	---
Rm. 192 - Warming Kitchen	Sink	Secured - SCSD Staff Only	061	IT-S108	1.5	None	---	---	---	---	---	---
Rm. 192 - Warming Kitchen	Sink	Secured - SCSD Staff Only	067	IT-S109	5.7	None	---	---	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT
INSTITUTE OF TECHNOLOGY AT SYRACUSE CENTRAL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	7/22/20 RESULTS (ppb)	7/22/20 ORIGINAL ACTIONS	8/28/20 RESULTS (ppb)	8/28/20 RESAMPLE ACTIONS	11/14/20 RESULTS (ppb)	11/14/20 RESAMPLE ACTIONS	11/21/20 RESULTS (ppb)	11/21/20 RESAMPLE ACTIONS
Rm. 192 - Warming Kitchen	Sink	Secured - SCSD Staff Only	069	IT-S110	1.5	None	---	---	---	---	---	---
Rm. 192 - Warming Kitchen	Sink	Secured - SCSD Staff Only	065	IT-S111	7.8	None	---	---	---	---	---	---
Rm. 192 - Warming Kitchen	Sink	Secured - SCSD Staff Only	074	IT-S112	5.9	None	---	---	---	---	---	---
Rm. 192 - Warming Kitchen	Convotherm	Secured - SCSD Staff Only	058/004/005	IT-S113	76.8	See Note 7	21.7	See Note 7	44.7	See Note 7	---	---
Rm. 193 - Staff Bathroom	Sink	Secured - SCSD Staff Only	087	IT-S102	1.0	None	---	---	---	---	---	---
Rm. 194 - Staff Bathroom	Sink	Secured - SCSD Staff Only	089	IT-S101	<1.0	None	---	---	---	---	---	---
Rm. 195 - Maintenance Bathroom	Sink	Secured - SCSD Staff Only	076	IT-S103	<1.0	None	---	---	---	---	---	---
Rm. 202 - Girl's Bathroom	Sink	Public Access	027	IT-S512	3.4	None	---	---	---	---	---	---
Rm. 202 - Girl's Bathroom	Sink	Public Access	029	IT-S513	1.8	None	---	---	---	---	---	---
Rm. 202 - Girl's Bathroom	Sink	Public Access	030	IT-S514	2.0	None	---	---	---	---	---	---
Rm. 202 - Girl's Bathroom	Sink	Public Access	032	IT-S515	1.8	None	---	---	---	---	---	---
Rm. 212 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	023	IT-S510	3.1	None	---	---	---	---	---	---
Rm. 213 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	025	IT-S509	<1.0	None	---	---	---	---	---	---
Rm. 2XX - Staff Bathroom	Sink	Secured - SCSD Staff Only	008	IT-S503	2.1	None	---	---	---	---	---	---
Rm. 220 - Staff Kitchenette	Sink	Secured - SCSD Staff Only	010	IT-S502	<1.0	None	---	---	---	---	---	---
Rm. 224 - Boy's Bathroom	Sink	Public Access	013	IT-S504	2.4	None	---	---	---	---	---	---
Rm. 224 - Boy's Bathroom	Sink	Public Access	015	IT-S505	1.9	None	---	---	---	---	---	---
Rm. 224 - Boy's Bathroom	Sink	Public Access	---/---/004	IT-S506	---	See Note 8	---	See Note 8	1.3	None	---	---
Rm. 224 - Boy's Bathroom	Sink	Public Access	016	IT-S507	2.3	None	---	---	---	---	---	---
Rm. 228 - Director's Office Bathroom	Sink	Secured - SCSD Staff Only	006/007	IT-S501	62.8	See Note 6	4.8	None	---	---	---	---
Rm. 242 - Biology Room	Sink	Public Access	003	IT-S522	6.7	None	---	---	---	---	---	---
Rm. 242 - Biology Room	Sink	Public Access	004	IT-S523	5.8	None	---	---	---	---	---	---
Rm. 242 - Biology Room	Sink	Public Access	002	IT-S524	8.6	None	---	---	---	---	---	---
Rm. 244 - Music Room	Sink	Public Access	005	IT-S500	5.3	None	---	---	---	---	---	---
Rm. 254 - Teacher's Work Room	Sink	Secured - SCSD Staff Only	018	IT-S508	1.0	None	---	---	---	---	---	---
Rm. 255 - OT/PT Room	Sink	Secured - SCSD Staff Only	021	IT-S511	1.4	None	---	---	---	---	---	---
Rm. 261 - Classroom	Sink	Public Access	041	IT-S520	4.1	None	---	---	---	---	---	---
Rm. 261 - Classroom	Sink	Public Access	043	IT-S521	6.0	None	---	---	---	---	---	---
Rm. 263 - Classroom	Sink	Public Access	044	IT-S518	4.9	None	---	---	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT
INSTITUTE OF TECHNOLOGY AT SYRACUSE CENTRAL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	7/22/20 RESULTS (ppb)	7/22/20 ORIGINAL ACTIONS	8/28/20 RESULTS (ppb)	8/28/20 RESAMPLE ACTIONS	11/14/20 RESULTS (ppb)	11/14/20 RESAMPLE ACTIONS	11/21/20 RESULTS (ppb)	11/21/20 RESAMPLE ACTIONS
Rm. 263 - Classroom	Sink	Public Access	046	IT-S519	10.3	None	---	---	---	---	---	---
Rm. 265 - Hallway/Corridor	Fountain	Public Access	039	IT-F500	1.2	None	---	---	---	---	---	---
Rm. 266 - Storage Room	Sink	Secured - SCSD Staff Only	037	IT-S517	12.8	None	---	---	---	---	---	---
Rm. 266 - Storage Room	Sink	Secured - SCSD Staff Only	034/008/---/002	IT-S525	252.0	See Note 6	20.9	See Note 6	---	See Note 6	9.9	None
Rm. 267 - H & BS Team Room	Sink	Public Access	036	IT-S516	2.1	None	---	---	---	---	---	---
Rm. 177 - Home & Careers Room	Sink (Hot Water)	Public Access	012	IT-S1000	1.8	None	---	---	---	---	---	---
Rm. 165 - Tech Lab	Sink	Public Access	047/003/001	IT-S1001	23.3	See Note 6	21.5	See Note 9	3.6	None	---	---

Original Sample Notes [July 22, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-036
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70139608
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed, replaced, and resampled.
7. In-line lead filter installed by SCSD and resampling performed.
8. Fixture not operating.

Re-Sample Notes [August 28, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-036
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70143986
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed, replaced, and resampled.
7. Lead reducing filter installed by SCSD and resampling performed.
8. Fixture not operating.
9. Fixture placarded.

SYRACUSE CITY SCHOOL DISTRICT INSTITUTE OF TECHNOLOGY AT SYRACUSE CENTRAL

Re-Sample Notes [November 14, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-036
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70153827
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture not operating.
7. Fixture evaluation being performed by SCSD.

Re-Sample Notes [November 21, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-036
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70154655
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.