

**SYRACUSE CITY SCHOOL DISTRICT
JOHNSON VOCATIONAL CENTER SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE ID No.	TDK SAMPLE ID No.	08/04/20 RESULTS (ppb)	08/04/20 ORIGINAL ACTIONS	10/10/20 RE-SAMPLE RESULTS (ppb)	10/10/20 RE-SAMPLE ACTIONS	11/21/20 RE-SAMPLE RESULTS (ppb)	11/21/20 RE-SAMPLE ACTIONS
Rm. 104 - Principal's Office	Sink	Secured - SCSD Staff Only	018	JN-S312	3.3	None	---	---	---	---
Rm. 105 - Main Office	Sink	Secured - SCSD Staff Only	019	JN-S311	4.5	None	---	---	---	---
Rm. 107 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	017	JN-S314	6.2	None	---	---	---	---
Rm. 108 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	016	JN-S313	9.7	None	---	---	---	---
Rm. 115 - Classroom	Sink	Public Access	012	JN-S315	1.2	None	---	---	---	---
Rm. 115 - Classroom	Sink	Public Access	013	JN-S316	<1.0	None	---	---	---	---
Rm. 115B - Kitchen	Sink	Secured - SCSD Staff Only	011	JN-S319	8.5	None	---	---	---	---
Rm. 115E - Classroom Bathroom	Sink	Public Access	014	JN-S317	2.3	None	---	---	---	---
Rm. 115E - Classroom Bathroom	Sink	Public Access	015	JN-S318	3.5	None	---	---	---	---
Rm. 121/122 - Hallway/Vestibule	Sink	Public Access	009	JN-S320	3.2	None	---	---	---	---
Rm. 121/122 - Hallway/Vestibule	Sink	Public Access	010	JN-S321	4.0	None	---	---	---	---
Rm. 123 - Hallway/Corridor	Sink	Public Access	008	JN-S322	11.1	None	---	---	---	---
Rm. 125 - Hallway/Corridor	Fountain	Public Access	003	JN-F323	<1.0	None	---	---	---	---
Rm. 128 - Technology Shop	Sink	Public Access	006	JN-S324	1.7	None	---	---	---	---
Rm. 132 - Technology Shop Bathroom	Sink	Public Access	007	JN-S325	3.9	None	---	---	---	---
Rm. 141 - Auto Shop	Fountain	Public Access	001	JN-F329	9.9	None	---	---	---	---
Rm. 141 - Auto Shop	Sink	Public Access	002	JN-S328	5.6	None	---	---	---	---
Rm. 142 - Welding Shop	Sink	Public Access	004/001/002	JN-S326	111	See Note 6	22.0	See Note 6	286	See Note 6
Rm. 142 - Welding Shop	Sink	Public Access	005	JN-S327	11.4	None	---	---	---	---
Rm. 207 - Hallway/Vestibule	Sink	Public Access	030	JN-S304	2.2	None	---	---	---	---
Rm. 207 - Hallway/Vestibule	Sink	Public Access	031	JN-S305	1.9	None	---	---	---	---
Rm. 211 - Nurse's Office Bathroom	Sink	Public Access	033	JN-S302	2.5	None	---	---	---	---
Rm. 213 - Laundry Room	Sink	Secured - SCSD Staff Only	034	JN-S303	6.7	None	---	---	---	---
Rm. 214 - Nurse's Office	Sink	Public Access	032	JN-S301	4.4	None	---	---	---	---
Rm. 218A - Cosmetology Room	Sink	Public Access	022	JN-S308	8.1	None	---	---	---	---
Rm. 218C - Classroom	Sink	Public Access	028	JN-S307	2.8	None	---	---	---	---
Rm. 219 - Hallway/Corridor	Fountain	Public Access	029	JN-F306	<1.0	None	---	---	---	---
Rm. 222A - Lounge	Sink	Secured - SCSD Staff Only	020/002/001	JN-S310	14.2	None	102	See Note 7	2.4	None
Rm. 222A - Lounge	Sink Spray Nozzle	Secured - SCSD Staff Only	021	JN-S310A	128	See Note 7	---	---	---	---
Rm. 227 - Classroom	Sink	Public Access	027	JN-S309	7.4	None	---	---	---	---
Rm. 218A - Cosmetology Room	Sink	Public Access	023	JN-S2000	2.8	None	---	---	---	---
Rm. 218A - Cosmetology Room	Sink Spray Nozzle	Public Access	024	JN-S2002	5.1	None	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT
JOHNSON VOCATIONAL CENTER SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE ID No.	TDK SAMPLE ID No.	08/04/20 RESULTS (ppb)	08/04/20 ORIGINAL ACTIONS	10/10/20 RE-SAMPLE RESULTS (ppb)	10/10/20 RE-SAMPLE ACTIONS	11/21/20 RE-SAMPLE RESULTS (ppb)	11/21/20 RE-SAMPLE ACTIONS
Rm. 218A - Cosmetology Room	Sink	Public Access	025	JN-S2001	2.4	None	---	---	---	---
Rm. 227 - Classroom	Sink	Public Access	026	JN-S2003	9.1	None	---	---	---	---

Original Sample Notes [August 4, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-037
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70140599
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture to be signed/placarded by SCSD.
7. Fixture removed.

Re-Sample Notes [October 10, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-037
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70149568
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture to be signed/placarded by SCSD.
7. Fixture remediated by SCSD.

Re-Sample Notes [November 21, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-037
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70154653
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture to be signed/placarded by SCSD.