

**SYRACUSE CITY SCHOOL DISTRICT
LEMOYNE ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	3/5/20 RESULTS (ppb)	3/5/20 ORIGINAL ACTIONS	8/8/20 RESAMPLE RESULTS (ppb)	8/8/20 RESAMPLE ACTIONS	11/4/20 RESAMPLE RESULTS (ppb)	11/4/20 RESAMPLE ACTIONS
Rm. 005 - Classroom	Main Sink	Public Access	006	LM-S101	1.8	None	---	---	---	---
Rm. 005 - Classroom	Fountain	Public Access	003	LM-F101	<1.0	None	---	---	---	---
Rm. 005C - Classroom Bathroom	Sink	Public Access	008	LM-S102	1.5	None	---	---	---	---
Rm. 100E - Kitchen Bathroom	Sink	Secured - SCSD Staff Only	009	LM-S115	10.0	None	---	---	---	---
Rm. 100F - Kitchen Serving Room	Sink	Secured - SCSD Staff Only	002	LM-S116	<1.0	None	---	---	---	---
Rm. 100F - Kitchen Serving Room	Sink	Secured - SCSD Staff Only	001	LM-S117	<1.0	None	---	---	---	---
Rm. 100F - Kitchen Serving Room	Sink	Secured - SCSD Staff Only	004	LM-S118	2.1	None	---	---	---	---
Rm. 100F - Kitchen Serving Room	Sink	Secured - SCSD Staff Only	005	LM-S119	1.8	None	---	---	---	---
Rm. 100F - Kitchen Serving Room	Nozzle	Secured - SCSD Staff Only	007/001/001	LM-A	24.1	See Note 6	24.0	See Note 6	94.3	See Note 6
Rm. 101 - Classroom	Sink	Public Access	025	LM-S113	<1.0	None	---	---	---	---
Rm. 101 - Classroom	Fountain	Public Access	023	LM-F105	<1.0	None	---	---	---	---
Rm. 101A - Classroom Bathroom	Sink	Public Access	026	LM-S114	2.1	None	---	---	---	---
Rm. 101B - Hallway/Corridor	Fountain	Public Access	010	LM-F102	<1.0	None	---	---	---	---
Rm. 101J - Hallway/Corridor	Fountain	Public Access	044	LM-F106	<1.0	None	---	---	---	---
Rm. 101J - Hallway/Corridor	Fountain	Public Access	056	LM-F107	<1.0	None	---	---	---	---
Rm. 102A - Classroom Bathroom	Sink	Public Access	028	LM-S110	2.5	None	---	---	---	---
Rm. 103 - Classroom	Sink	Public Access	019	LM-S112	<1.0	None	---	---	---	---
Rm. 103 - Classroom	Fountain	Public Access	016	LM-F104	2.5	None	---	---	---	---
Rm. 103A - Classroom Bathroom	Sink	Public Access	021	LM-S111	<1.0	None	---	---	---	---
Rm. 104 - Classroom Bathroom	Sink	Public Access	029	LM-S109	<1.0	None	---	---	---	---
Rm. 105 - Classroom	Sink	Public Access	014	LM-S108	<1.0	None	---	---	---	---
Rm. 105 - Classroom	Fountain	Public Access	013	LM-F103	2.4	None	---	---	---	---
Rm. 105A - Classroom Bathroom	Sink	Public Access	015	LM-S107	5.6	None	---	---	---	---
Rm. 106B - Storage Room	Sink	Secured - SCSD Staff Only	036/---/004	LM-S103	1.5	None	---	---	<1.0	None
Rm. 110A - Clinic Room	Sink	Public Access	041	LM-S124	1.9	None	---	---	---	---
Rm. 110B - Nurse's Bathroom	Sink	Public Access	042	LM-S125	2.3	None	---	---	---	---
Rm. 113 - Classroom	Sink	Public Access	053	LM-S130	<1.0	None	---	---	---	---
Rm. 113 - Classroom	Fountain	Public Access	051	LM-F108	<1.0	None	---	---	---	---
Rm. 113A - Classroom Bathroom	Sink	Public Access	---/---/005	LM-S129	---	See Note 7	---	---	<1.0	None

**SYRACUSE CITY SCHOOL DISTRICT
LEMOYNE ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	3/5/20 RESULTS (ppb)	3/5/20 ORIGINAL ACTIONS	8/8/20 RESAMPLE RESULTS (ppb)	8/8/20 RESAMPLE ACTIONS	11/4/20 RESAMPLE RESULTS (ppb)	11/4/20 RESAMPLE ACTIONS
Rm. 115 - Classroom	Sink	Public Access	061	LM-S132	<1.0	None	---	---	---	---
Rm. 115 - Classroom	Fountain	Public Access	059	LM-F109	1.5	None	---	---	---	---
Rm. 115A - Classroom Bathroom	Sink	Public Access	057	LM-S131	4.3	None	---	---	---	---
Rm. 118 - Classroom	Sink	Public Access	060	LM-S133	<1.0	None	---	---	---	---
Rm. 118 - Classroom	Fountain	Public Access	058	LM-F110	1.5	None	---	---	---	---
Rm. 118A - Classroom Bathroom	Sink	Public Access	062	LM-S134	2.1	None	---	---	---	---
Rm. 121A - Storage Room	Sink	Secured - SCSD Staff Only	055	LM-S126	4.0	None	---	---	---	---
Rm. 121A - Storage Room	Sink	Secured - SCSD Staff Only	052	LM-S128	<1.0	None	---	---	---	---
Rm. 121E - Office Bathroom	Sink	Secured - SCSD Staff Only	054	LM-S127	1.1	None	---	---	---	---
Rm. 134 - Boy's Bathroom	Sink	Public Access	046	LM-S120	2.7	None	---	---	---	---
Rm. 134 - Boy's Bathroom	Sink	Public Access	047	LM-S121	7.0	None	---	---	---	---
Rm. 134A - Girl's Bathroom	Sink	Public Access	048	LM-S122	6.5	None	---	---	---	---
Rm. 134A - Girl's Bathroom	Sink	Public Access	049	LM-S123	<1.0	None	---	---	---	---
Rm. 136 - Classroom	Sink	Public Access	033/---/002	LM-S149	<1.0	None	---	---	1.6	None
Rm. 138 - Gym Bathroom	Sink	Public Access	037/---/003	LM-S104	<1.0	None	---	---	1.9	None
Rm.141 - Girl's Bathroom	Sink	Public Access	011	LM-S106	1.7	None	---	---	---	---
Rm. 141A - Boy's Bathroom	Sink	Public Access	012	LM-S105	<1.0	None	---	---	---	---
Rm. 201F - Hallway/Corridor	Fountain	Public Access	017	LM-F111	<1.0	None	---	---	---	---
Rm. 201F - Hallway/Corridor	Fountain	Public Access	022	LM-F112	<1.0	None	---	---	---	---
Rm. 204 - Lounge	Sink	Secured - SCSD Staff Only	040	LM-S146	<1.0	None	---	---	---	---
Rm. 204A - Lounge Bathroom	Sink	Secured - SCSD Staff Only	043	LM-S148	<1.0	None	---	---	---	---
Rm. 204B - Lounge Bathroom	Sink	Secured - SCSD Staff Only	045	LM-S147	1.7	None	---	---	---	---
Rm. 206 - Classroom	Sink	Public Access	030	LM-S140	1.2	None	---	---	---	---
Rm. 206 - Classroom	Sink	Public Access	031	LM-S141	1.2	None	---	---	---	---
Rm. 212A - Girl's Bathroom/Corridor	Sink	Public Access	018	LM-S136	1.8	None	---	---	---	---
Rm. 212A - Girl's Bathroom/Corridor	Sink	Public Access	020	LM-S137	1.8	None	---	---	---	---
Rm. 212B - Boy's Bathroom Sink/Corridor	Sink	Public Access	024	LM-S138	2.2	None	---	---	---	---
Rm. 212B - Boy's Bathroom Sink/Corridor	Sink	Public Access	027	LM-S139	<1.0	None	---	---	---	---
Rm. 212D - Staff Bathroom	Sink	Secured - SCSD Staff Only	032	LM-S142	<1.0	None	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT
LEMOYNE ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	3/5/20 RESULTS (ppb)	3/5/20 ORIGINAL ACTIONS	8/8/20 RESAMPLE RESULTS (ppb)	8/8/20 RESAMPLE ACTIONS	11/4/20 RESAMPLE RESULTS (ppb)	11/4/20 RESAMPLE ACTIONS
Rm. 219A - Library Office	Sink	Secured - SCSD Staff Only	050	LM-S135	<1.0	None	---	---	---	---
Rm. 222 - Hallway/Vestibule	Sink	Public Access	034	LM-S143	<1.0	None	---	---	---	---
Rm. 222 - Hallway/Vestibule	Sink	Public Access	035	LM-S144	2.4	None	---	---	---	---
Rm. 222 - Hallway/Vestibule	Fountain	Public Access	039	LM-F113	1.1	None	---	---	---	---
Rm. 222 - Hallway/Vestibule	Sink	Public Access	038	LM-S145	<1.0	None	---	---	---	---

Original Sample Notes [March 5, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-005
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project ID 70124363
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Remediation performed by SCSD.
7. Fixture not operating.

Re-Sample Notes [August 8, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-005
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project ID 70141477
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Evaluation performed by SCSD.

Re-Sample Notes [November 4, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-005
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project ID 70152551
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Evaluation performed by SCSD.