

**SYRACUSE CITY SCHOOL DISTRICT
LEVY K-8 SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	7/8/2020 RESULTS (ppb)	7/8/2020 ORIGINAL ACTIONS	10/10/2020 RESULTS (ppb)	10/10/2020 RESAMPLE ACTIONS	11/21/2020 RESULTS (ppb)	11/21/2020 RESAMPLE ACTIONS
Rm. 108 - Classroom	Sink	Public Access	069	LY-S218	3.5	None	---	---	---	---
Rm. 109A - Classroom	Sink	Public Access	068	LY-S217	13.4	None	---	---	---	---
Rm. 111A - Hallway/Corridor	Fountain	Public Access	070/006	LY-F205	33.0	See Note 6	8.1	None	---	---
Rm. 114 - Girl's Bathroom	Sink	Public Access	072	LY-S214	5.8	None	---	---	---	---
Rm. 114 - Girl's Bathroom	Sink	Public Access	073	LY-S215	11.2	None	---	---	---	---
Rm. 114 - Girl's Bathroom	Sink	Public Access	074	LY-S216	3.8	None	---	---	---	---
Rm. 117 - Boy's Bathroom	Sink	Public Access	064/007	LY-S211	25.4	See Note 6	5.1	None	---	---
Rm. 117 - Boy's Bathroom	Sink	Public Access	065	LY-S212	3.4	None	---	---	---	---
Rm. 117 - Boy's Bathroom	Sink	Public Access	066	LY-S213	7.1	None	---	---	---	---
Rm. 119 - Hallway/Corridor	Fountain	Public Access	067	LY-F204	2.8	None	---	---	---	---
Rm. 120 - Hallway/Corridor	Fountain	Public Access	056	LY-F202	<1.0	None	---	---	---	---
Rm. 121A - Classroom	Fountain	Public Access	061	LY-F203	<1.0	None	---	---	---	---
Rm. 121A - Classroom	Sink	Public Access	060	LY-S208	8.2	None	---	---	---	---
Rm. 125A - Staff Bathroom	Sink	Secured - SCSD Staff Only	054	LY-S204	14.4	None	---	---	---	---
Rm. 125D - Work Room	Sink	Secured - SCSD Staff Only	055/008	LY-S203	15.9	See Note 6	1.6	None	---	---
Rm. 126 - Guidance Office	Sink	Public Access	071	LY-S202	4.3	None	---	---	---	---
Rm. 129C-1 - Work Room	Sink	Secured - SCSD Staff Only	053	LY-S207	10.1	None	---	---	---	---
Rm. 129E - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	049	LY-S206	2.4	None	---	---	---	---
Rm. 129F - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	048	LY-S205	2.0	None	---	---	---	---
Rm. 132A - Clinic Office	Sink	Public Access	062	LY-S209	1.8	None	---	---	---	---
Rm. 132B - Clinic Bathroom	Sink	Public Access	063	LY-S210	4.8	None	---	---	---	---
Rm. 134 - Girl's Bathroom	Sink	Public Access	025	LY-S201	5.2	None	---	---	---	---
Rm. 135A - Hallway/Corridor	Fountain	Public Access	023	LY-F201	1.2	None	---	---	---	---
Rm. 136 - Boy's Bathroom	Sink	Public Access	047	LY-S100	1.1	None	---	---	---	---
Rm. 141 - Girl's Locker Room	Sink	Public Access	044	LY-S101	11.0	None	---	---	---	---
Rm. 141 - Girl's Locker Room	Sink	Public Access	043	LY-S102	3.5	None	---	---	---	---
Rm. 141B - Girl's Coach Bathroom	Sink	Secured - SCSD Staff Only	041	LY-S103	9.6	None	---	---	---	---
Rm. 142 - Hallway/Corridor	Fountain	Public Access	040	LY-F100	<1.0	None	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT
LEVY K-8 SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	7/8/2020 RESULTS (ppb)	7/8/2020 ORIGINAL ACTIONS	10/10/2020 RESULTS (ppb)	10/10/2020 RESAMPLE ACTIONS	11/21/2020 RESULTS (ppb)	11/21/2020 RESAMPLE ACTIONS
Rm. 145 - Boy's Locker Room	Fountain	Public Access	026	LY-F101	2.8	None	---	---	---	---
Rm. 145A-1 - Gym Office Bathroom	Sink	Secured - SCSD Staff Only	029	LY-S104	3.6	None	---	---	---	---
Rm. 145B-1 - Boy's Coach Bathroom	Sink	Secured - SCSD Staff Only	030	LY-S105	3.1	None	---	---	---	---
Rm. 145D - Boy's Locker Room Bathroom	Sink	Public Access	036	LY-S108	36.6	See Note 6	552	See Note 6	---	---
Rm. 145F - Boy's Shower	Sink	Public Access	037	LY-S107	5.4	None	---	---	---	---
Rm. 151 - Kitchen	Sink	Secured - SCSD Staff Only	006	LY-S115	12.3	None	---	---	---	---
Rm. 151 - Kitchen	Sink	Secured - SCSD Staff Only	005	LY-S116	4.1	None	---	---	---	---
Rm. 151 - Kitchen	Sink	Secured - SCSD Staff Only	003	LY-S117	4.8	None	---	---	---	---
Rm. 151 - Kitchen	Sink	Secured - SCSD Staff Only	004	LY-S118	10.9	None	---	---	---	---
Rm. 151B - Staff Lockers	Sink	Secured - SCSD Staff Only	012	LY-S114	8.1	None	---	---	---	---
Rm. 152 - Receiving Room	Sink	Secured - SCSD Staff Only	001	LY-S119	3.7	None	---	---	---	---
Rm. 154 - Cafeteria	Fountain	Public Access	002	LY-F102	<1.0	None	---	---	---	---
Rm. 154C - Boy's Bathroom	Sink	Public Access	017	LY-S112	12.9	None	---	---	---	---
Rm. 154C - Boy's Bathroom	Sink	Public Access	018	LY-S113	2.0	None	---	---	---	---
Rm. 154D - Girl's Bathroom	Sink	Public Access	020	LY-S110	2.4	None	---	---	---	---
Rm. 154D - Girl's Bathroom	Sink	Public Access	021	LY-S111	1.3	None	---	---	---	---
Rm. 211A - Hallway/Corridor	Fountain	Public Access	027	LY-F206	4.8	None	---	---	---	---
Rm. 213 - Girl's Bathroom	Sink	Public Access	035	LY-S222	6.5	None	---	---	---	---
Rm. 213 - Girl's Bathroom	Sink	Public Access	038	LY-S223	1.1	None	---	---	---	---
Rm. 213 - Girl's Bathroom	Sink	Public Access	039	LY-S224	5.5	None	---	---	---	---
Rm. 215 - Boy's Bathroom	Sink	Public Access	032	LY-S219	8.2	None	---	---	---	---
Rm. 215 - Boy's Bathroom	Sink	Public Access	033	LY-S220	2.5	None	---	---	---	---
Rm. 215 - Boy's Bathroom	Sink	Public Access	034	LY-S221	4.2	None	---	---	---	---
Rm. 221 - Classroom	Sink	Public Access	057	LY-S122	8.5	None	---	---	---	---
Rm. 221 - Classroom	Sink (hot water only)	Public Access	058/001	LY-S123	15.4	See Note 6	7.0	None	---	---
Rm. 230 - Hallway/Corridor	Fountain	Public Access	045	LY-F103	7.7	None	---	---	---	---
Rm. 231 - Staff Bathroom	Sink	Secured - SCSD Staff Only	046	LY-S121	6.2	None	---	---	---	---
Rm. 311 - Hallway/Corridor	Fountain	Public Access	007	LY-F207A	2.0	None	---	---	---	---
Rm. 311B - Hallway/Corridor	Fountain	Public Access	024	LY-F208	2.1	None	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT
LEVY K-8 SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	7/8/2020 RESULTS (ppb)	7/8/2020 ORIGINAL ACTIONS	10/10/2020 RESULTS (ppb)	10/10/2020 RESAMPLE ACTIONS	11/21/2020 RESULTS (ppb)	11/21/2020 RESAMPLE ACTIONS
Rm. 313 - Girl's Bathroom	Sink	Public Access	015	LY-S230	5.8	None	---	---	---	---
Rm. 313 - Girl's Bathroom	Sink	Public Access	016	LY-S231	6.2	None	---	---	---	---
Rm. 313 - Girl's Bathroom	Sink	Public Access	019	LY-S232	6.8	None	---	---	---	---
Rm. 315A - Teacher's Resource Bathroom	Sink	Secured - SCSD Staff Only	022	LY-S229	4.5	None	---	---	---	---
Rm. 317 - Boy's Bathroom	Sink	Public Access	009	LY-S225	12.2	None	---	---	---	---
Rm. 317 - Boy's Bathroom	Sink	Public Access	010	LY-S226	3.4	None	---	---	---	---
Rm. 317 - Boy's Bathroom	Sink	Public Access	011	LY-S227	8.9	None	---	---	---	---
Rm. 319 - Art Room	Sink	Public Access	013/004	LY-S228	27.6	See Note 6	1.6	None	---	---
Rm. 321 - Staff Bathroom	Sink	Secured - SCSD Staff Only	051	LY-S126	7.0	None	---	---	---	---
Rm. 322 - Staff Bathroom	Sink	Secured - SCSD Staff Only	050/---/001	LY-S125	196.0	See Note 6	---	See Note 7	63.4	See Note 6
Rm. 323 - Teacher's Resource	Sink	Public Access	052	LY-S124	13.2	None	---	---	---	---
Rm. 151 - Kitchen	Convotherm Oven	Secured - SCSD Staff Only	008	LY-C1000	4.1	None	---	---	---	---
Rm. 319 - Art Room	Sink	Public Access	014	LY-S3000	9.7	None	---	---	---	---
Rm. 217 - Culinary Room	Sink	Public Access	028/003	LY-S3001	22.9	See Note 6	7.5	None	---	---
Rm. 145 - Boy's Locker Room	Sink	Public Access	031	LY-S2000	12.0	None	---	---	---	---
Rm. 211B - Hallway/Corridor	Fountain	Public Access	021/002	LY-F207B	18.0	See Note 6	14.7	None	---	---
Rm. 221 - Classroom	Sink (Spray)	Public Access	059	LY-S3002	2.2	None	---	---	---	---
Rm. 319 - Art Room	Sink	Public Access	---/005	LY-S4000	---	---	<1.0	None	---	---

Original Sample Notes [July 8, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-038
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70138196
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Remediation performed by SCSD.

SYRACUSE CITY SCHOOL DISTRICT

LEVY K-8 SCHOOL

Re-Sample Notes [October 10, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-038
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70149563
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed.
7. Fixture not accessible.

Re-Sample Notes [November 21, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-038
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70154651
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture placarded.