

**SYRACUSE CITY SCHOOL DISTRICT
LINCOLN MIDDLE SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE ID No.	TDK SAMPLE ID No.	06/17/20 RESULTS (ppb)	06/17/20 ORIGINAL ACTIONS	08/08/20 RESULTS (ppb)	08/08/20 RE- SAMPLE ACTIONS	11/18/20 RESULTS (ppb)	11/18/20 RE- SAMPLE ACTIONS	12/04/20 RESULTS (ppb)	12/04/20 RE- SAMPLE ACTIONS
Rm. 101 - Hallway/Corridor	Fountain	Public Access	062	LN-F205	<1.0	None	---	---	---	---	---	---
Rm. 101 - Hallway/Corridor	Fountain	Public Access	061	LN-F206	<1.0	None	---	---	---	---	---	---
Rm. 101H - Hallway/Corridor	Fountain	Public Access	024	LN-F201	<1.0	None	---	---	---	---	---	---
Rm. 102 - Nurse's Office	Sink	Public Access	018	LN-S223	3.6	None	---	---	---	---	---	---
Rm. 102B - Clinic Office Bathroom	Sink	Public Access	017	LN-S224	11.8	None	---	---	---	---	---	---
Rm. 102C - Nurse's Office Bathroom	Sink	Public Access	019	LN-S222	2.7	None	---	---	---	---	---	---
Rm. 103 - Home & Careers Room	Sink	Public Access	013	LN-S428	4.1	None	---	---	---	---	---	---
Rm. 103 - Home & Careers Room	Sink	Public Access	015	LN-S429	11.3	None	---	---	---	---	---	---
Rm. 104 - Classroom	Sink	Public Access	---/---/002/001	LN-S430	---	See Note 6	---	See Note 6	21.7	See Note 6	9.2	None
Rm. 104 - Classroom	Sink	Public Access	---/---/001	LN-S431	---	See Note 6	---	See Note 6	5.6	None	---	---
Rm. 104 - Classroom	Sink	Public Access	011	LN-S432	11.4	None	---	---	---	---	---	---
Rm. 105 - Art Room	Sink	Public Access	008	LN-S433	5.4	None	---	---	---	---	---	---
Rm. 105 - Art Room	Sink	Public Access	007	LN-S434	6.3	None	---	---	---	---	---	---
Rm. 106A - Storage Room	Sink	Secured - SCSD Staff Only	005	LN-S435	5.9	None	---	---	---	---	---	---
Rm. 107 - Classroom	Sink	Public Access	003	LN-S436	2.9	None	---	---	---	---	---	---
Rm. 107 - Classroom	Sink	Public Access	004	LN-S437	1.2	None	---	---	---	---	---	---
Rm. 109F - Kitchen	Sink	Secured - SCSD Staff Only	014	LN-S225	<1.0	None	---	---	---	---	---	---
Rm. 109F - Kitchen	Sink	Secured - SCSD Staff Only	012	LN-S226	2.5	None	---	---	---	---	---	---
Rm. 109F - Kitchen	Sink	Secured - SCSD Staff Only	010	LN-S227	2.9	None	---	---	---	---	---	---
Rm. 109F - Kitchen	Sink	Secured - SCSD Staff Only	009	LN-S228	1.3	None	---	---	---	---	---	---
Rm. 109F - Kitchen	Sink	Secured - SCSD Staff Only	006	LN-S229	1.7	None	---	---	---	---	---	---
Rm. 109F - Kitchen	Sink	Secured - SCSD Staff Only	016	LN-S230	2.3	None	---	---	---	---	---	---
Rm. 109F - Kitchen	Kettle	Secured - SCSD Staff Only	021	LN-S232	6.0	None	---	---	---	---	---	---
Rm. 109F - Kitchen	Kettle	Secured - SCSD Staff Only	022/001	LN-S233	29.4	See Note 7	2.6	None	---	---	---	---
Rm. 109F - Kitchen	Convotherm Oven Sprayer	Secured - SCSD Staff Only	023	LN-S234	3.4	None	---	---	---	---	---	---
Rm. 109F - Kitchen	Ice Machine	Secured - SCSD Staff Only	002	LN-S235	<1.0	None	---	---	---	---	---	---
Rm. 109G - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	028	LN-S220	4.4	None	---	---	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT
LINCOLN MIDDLE SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE ID No.	TDK SAMPLE ID No.	06/17/20 RESULTS (ppb)	06/17/20 ORIGINAL ACTIONS	08/08/20 RESULTS (ppb)	08/08/20 RE- SAMPLE ACTIONS	11/18/20 RESULTS (ppb)	11/18/20 RE- SAMPLE ACTIONS	12/04/20 RESULTS (ppb)	12/04/20 RE- SAMPLE ACTIONS
Rm. 109H - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	029	LN-S219	1.4	None	---	---	---	---	---	---
Rm. 110 - Boy's Bathroom	Sink	Public Access	033	LN-S442	3.4	None	---	---	---	---	---	---
Rm. 110 - Boy's Bathroom	Sink	Public Access	034	LN-S443	4.3	None	---	---	---	---	---	---
Rm. 110 - Boy's Bathroom	Sink	Public Access	035	LN-S444	2.3	None	---	---	---	---	---	---
Rm. 110A - Kitchen Bathroom	Sink	Secured - SCSD Staff Only	025	LN-S231	1.2	None	---	---	---	---	---	---
Rm. 111 - Girl's Bathroom	Sink	Public Access	027	LN-S438	1.6	None	---	---	---	---	---	---
Rm. 111 - Girl's Bathroom	Sink	Public Access	031	LN-S439	2.0	None	---	---	---	---	---	---
Rm. 111 - Girl's Bathroom	Sink	Public Access	030	LN-S440	2.7	None	---	---	---	---	---	---
Rm. 111 - Girl's Bathroom	Sink	Public Access	032	LN-S441	2.7	None	---	---	---	---	---	---
Rm. 113 - Wood Shop	Sink	Public Access	037	LN-S236	1.1	None	---	---	---	---	---	---
Rm. 115 - Art Room	Sink	Public Access	044	LN-S237	3.5	None	---	---	---	---	---	---
Rm. 119A - Gym	Fountain	Public Access	045	LN-F204	2.4	None	---	---	---	---	---	---
Rm. 119A - Gym	Fountain	Public Access	050	LN-F202	2.9	None	---	---	---	---	---	---
Rm. 125 - Office	Sink	Secured - SCSD Staff Only	042	LN-S239	7.3	None	---	---	---	---	---	---
Rm. 128 - Library	Fountain	Public Access	041	LN-F208	1.7	None	---	---	---	---	---	---
Rm. 128A - Library Office	Sink	Secured - SCSD Staff Only	026	LN-S221	1.7	None	---	---	---	---	---	---
Rm. 130 - Boy's Bathroom	Sink	Public Access	047	LN-S208	5.8	None	---	---	---	---	---	---
Rm. 130 - Boy's Bathroom	Sink	Public Access	049	LN-S209	2.9	None	---	---	---	---	---	---
Rm. 130 - Boy's Bathroom	Sink	Public Access	048	LN-S210	4.0	None	---	---	---	---	---	---
Rm. 130 - Boy's Bathroom	Sink	Public Access	046	LN-S211	3.7	None	---	---	---	---	---	---
Rm. 132 - Girl's Locker Room	Fountain	Public Access	036	LN-F203	9.0	None	---	---	---	---	---	---
Rm. 132A - Girl's Coach Office Bathroom	Sink	Secured - SCSD Staff Only	040	LN-S207	4.7	None	---	---	---	---	---	---
Rm. 132B - Girl's Bathroom	Sink	Public Access	054	LN-S212	3.9	None	---	---	---	---	---	---
Rm. 132B - Girl's Bathroom	Sink	Public Access	055	LN-S213	2.1	None	---	---	---	---	---	---
Rm. 132B - Girl's Bathroom	Sink	Public Access	057	LN-S214	3.2	None	---	---	---	---	---	---
Rm. 132B - Girl's Bathroom	Sink	Public Access	059	LN-S215	5.9	None	---	---	---	---	---	---
Rm. 132B - Girl's Bathroom	Sink	Public Access	058	LN-S216	2.2	None	---	---	---	---	---	---
Rm. 132B - Girl's Bathroom	Sink	Public Access	060	LN-S217	2.9	None	---	---	---	---	---	---
Rm. 132B - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	051	LN-S218	3.6	None	---	---	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT
LINCOLN MIDDLE SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE ID No.	TDK SAMPLE ID No.	06/17/20 RESULTS (ppb)	06/17/20 ORIGINAL ACTIONS	08/08/20 RESULTS (ppb)	08/08/20 RE- SAMPLE ACTIONS	11/18/20 RESULTS (ppb)	11/18/20 RE- SAMPLE ACTIONS	12/04/20 RESULTS (ppb)	12/04/20 RE- SAMPLE ACTIONS
Rm. 132E - Girl's Locker Room Bathroom	Sink	Public Access	039	LN-S204	<1.0	None	---	---	---	---	---	---
Rm. 132E - Girl's Locker Room Bathroom	Sink	Public Access	038	LN-S205	2.0	None	---	---	---	---	---	---
Rm. 132E - Girl's Locker Room Bathroom	Sink	Public Access	043	LN-S206	2.0	None	---	---	---	---	---	---
Rm. 133A - Boy's Coach Office Bathroom	Sink	Secured - SCSD Staff Only	052	LN-S203	9.3	None	---	---	---	---	---	---
Rm. 133E - Boy's Locker Room Bathroom	Sink	Public Access	056	LN-S201	1.8	None	---	---	---	---	---	---
Rm. 133E - Boy's Locker Room Bathroom	Sink	Public Access	053	LN-S202	3.4	None	---	---	---	---	---	---
Rm. 134A - Hallway/Corridor	Fountain	Public Access	020	LN-F207	<1.0	None	---	---	---	---	---	---
Rm. 206A - Hallway/Corridor	Fountain	Public Access	064	LN-F402	<1.0	None	---	---	---	---	---	---
Rm. 206A - Hallway/Corridor	Fountain	Public Access	071	LN-F403	<1.0	None	---	---	---	---	---	---
Rm. 207 - Hallway/Corridor	Sink	Public Access	078	LN-F401	<1.0	None	---	---	---	---	---	---
Rm. 226 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	065	LN-S400	2.2	None	---	---	---	---	---	---
Rm. 227 - Girl's Bathroom	Sink	Public Access	070	LN-S401	3.5	None	---	---	---	---	---	---
Rm. 227 - Girl's Bathroom	Sink	Public Access	069	LN-S402	1.9	None	---	---	---	---	---	---
Rm. 227 - Girl's Bathroom	Sink	Public Access	067	LN-S403	3.4	None	---	---	---	---	---	---
Rm. 227 - Girl's Bathroom	Sink	Public Access	---/---/003	LN-S404	---	See Note 6	---	See Note 6	7.4	None	---	---
Rm. 213 - Hallway/Corridor	Fountain	Public Access	063	LN-F400	<1.0	None	---	---	---	---	---	---
Rm. 215 - Laboratory Room	Sink	Public Access	068	LN-S425	12.1	None	---	---	---	---	---	---
Rm. 224 - Laboratory Room	Sink	Public Access	079/002	LN-S414	34.9	See Note 8	6.7	None	---	---	---	---
Rm. 236A - Laboratory Storage Room	Sink	Public Access	072	LN-S409	7.6	None	---	---	---	---	---	---
Rm. 242 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	073	LN-S415	3.1	None	---	---	---	---	---	---
Rm. 242A - Storage Room	Sink	Secured - SCSD Staff Only	066	LN-S420	2.0	None	---	---	---	---	---	---
Rm. 242B - Boy's Bathroom	Sink	Public Access	075	LN-S416	3.6	None	---	---	---	---	---	---
Rm. 242B - Boy's Bathroom	Sink	Public Access	074	LN-S417	3.5	None	---	---	---	---	---	---
Rm. 242B - Boy's Bathroom	Sink	Public Access	077	LN-S418	1.6	None	---	---	---	---	---	---
Rm. 242B - Boy's Bathroom	Sink	Public Access	076	LN-S419	4.5	None	---	---	---	---	---	---
Rm. 106 - Custodian Office	Sink	Secured - SCSD Staff Only	001	LN-S1000	1.2	None	---	---	---	---	---	---

SYRACUSE CITY SCHOOL DISTRICT

LINCOLN MIDDLE SCHOOL

Original Sample Notes [June 17, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-023
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70135464
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture not operating.
7. In-line filter installed by SCSD and resampling performed.
8. Fixture removed, replaced and resampled.

Re-Sample Notes [August 8, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-023
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70141469
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture not operating.

Re-Sample Notes [November 18, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-023
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70154142
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Remediation performed by SCSD.

Re-Sample Notes [December 4, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-023
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70155706
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.