

**SYRACUSE CITY SCHOOL DISTRICT
MCKINLEY-BRIGHTON ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	06/23/20 RESULTS (ppb)	06/23/20 ACTIONS	08/12/20 RESULTS (ppb)	08/12/20 ACTIONS	12/30/20 RESULTS (ppb)	12/30/20 ACTIONS
Rm. 100D - Office Kitchenette	Sink	Secured - SCSD Staff Only	063	MY-S231	1.6	None	--	--	--	--
Rm. 100T - Principal's Bathroom	Sink	Secured - SCSD Staff Only	062	MY-S230	<1.0	None	--	--	--	--
Rm. 103T - Main Office Bathroom	Sink	Secured - SCSD Staff Only	035	MY-S229	2.3	None	--	--	--	--
Rm. 105 - Nurse's Office	Sink	Public Access	031	MY-S225	<1.0	None	--	--	--	--
Rm. 105A - Exam Room	Sink	Public Access	032	MY-S226	<1.0	None	--	--	--	--
Rm. 105B - Nurse's Office Changing Room	Sink	Public Access	034	MY-S228	<1.0	None	--	--	--	--
Rm. 105T - Nurse's Office Bathroom	Sink	Public Access	033	MY-S227	<1.0	None	--	--	--	--
Rm. 107 - Classroom	Sink	Public Access	024	MY-S211	<1.0	None	--	--	--	--
Rm. 107 - Classroom	Sink	Public Access	025	MY-S212	1.9	None	--	--	--	--
Rm. 107 - Classroom	Fountain	Public Access	023	MY-F203	<1.0	None	--	--	--	--
Rm. 108 - Staff Bathroom	Sink	Secured - SCSD Staff Only	028 / 001	MY-S213	30.1	See Note 6	1.5	None	--	--
Rm. 111 - Classroom	Sink	Public Access	020	MY-S210	<1.0	None	--	--	--	--
Rm. 111 - Classroom	Sink	Public Access	019	MY-S209	<1.0	None	--	--	--	--
Rm. 111 - Classroom	Fountain	Public Access	018	MY-F202	<1.0	None	--	--	--	--
Rm. 112 - Kitchen	Sink	Secured - SCSD Staff Only	009	MY-S204	<1.0	None	--	--	--	--
Rm. 112 - Kitchen	Sink	Secured - SCSD Staff Only	010	MY-S205	<1.0	None	--	--	--	--
Rm. 112 - Kitchen	Sink	Secured - SCSD Staff Only	012	MY-S206	1.6	None	--	--	--	--
Rm. 112 - Kitchen	Sink	Secured - SCSD Staff Only	003	MY-S207	<1.0	None	--	--	--	--
Rm. 112 - Kitchen	Sink	Secured - SCSD Staff Only	006	MY-S208	6.6	None	--	--	--	--
Rm. 112B - Kitchen Bathroom	Sink	Secured - SCSD Staff Only	015	MY-S203	<1.0	None	--	--	--	--
Rm. 113 - Classroom	Sink	Public Access	---/---/ 001	MY-S201	---	See Note 7	---	---	1.3	None
Rm. 113 - Classroom	Sink	Public Access	002	MY-S202	<1.0	None	--	--	--	--
Rm. 113 - Classroom	Fountain	Public Access	001	MY-F201	<1.0	None	--	--	--	--
Rm. 119 - Community Room	Sink	Public Access	048	MY-S218	1.3	None	--	--	--	--
Rm. 120B - Custodian's Bathroom	Sink	Secured - SCSD Staff Only	046	MY-S219	<1.0	None	--	--	--	--
Rm. 121T - Boy's Bathroom	Sink	Public Access	050	MY-S220	7.0	None	--	--	--	--
Rm. 121T - Boy's Bathroom	Sink	Public Access	051	MY-S221	9.9	None	--	--	--	--
Rm. 122T - PE Office Bathroom	Sink	Secured - SCSD Staff Only	056	MY-S224	1.5	None	--	--	--	--
Rm. 123T - Girl's Bathroom	Sink	Public Access	054	MY-S222	3.5	None	--	--	--	--

SYRACUSE CITY SCHOOL DISTRICT
MCKINLEY-BRIGHTON ELEMENTARY SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	06/23/20 RESULTS (ppb)	06/23/20 ACTIONS	08/12/20 RESULTS (ppb)	08/12/20 ACTIONS	12/30/20 RESULTS (ppb)	12/30/20 ACTIONS
Rm. 123T - Girl's Bathroom	Sink	Public Access	055	MY-S223	<1.0	None	--	--	--	--
Rm. 126 - Classroom	Sink	Public Access	126	MY-S131	2.2	None	--	--	--	--
Rm. 126 - Classroom	Sink	Public Access	127	MY-S132	<1.0	None	--	--	--	--
Rm. 126 - Classroom	Fountain	Public Access	128	MY-F114	<1.0	None	--	--	--	--
Rm. 127 - Classroom	Sink	Public Access	133 / 002	MY-S129	37.8	See Note 6	<1.0	None	--	--
Rm. 127 - Classroom	Sink	Public Access	132	MY-S130	<1.0	None	--	--	--	--
Rm. 127 - Classroom	Fountain	Public Access	131	MY-F113	<1.0	None	--	--	--	--
Rm. 128 - Classroom	Sink	Public Access	---/---/ 004	MY-S125	---	See Note 7	--	--	1.2	None
Rm. 128 - Classroom	Sink	Public Access	129	MY-S126	<1.0	None	--	--	--	--
Rm. 128 - Classroom	Fountain	Public Access	130	MY-F112	<1.0	None	--	--	--	--
Rm. 130 - Classroom	Sink	Public Access	---/---/ 005	MY-S123	--	See Note 7	--	--	1.4	None
Rm. 130 - Classroom	Sink	Public Access	123	MY-S124	2.8	None	--	--	--	--
Rm. 130 - Classroom	Fountain	Public Access	124	MY-F111	<1.0	None	--	--	--	--
Rm. 131 - Classroom	Sink	Public Access	122	MY-S122	12.0	None	--	--	--	--
Rm. 131 - Classroom	Fountain	Public Access	120	MY-F110	<1.0	None	--	--	--	--
Rm. 131T - Classroom Bathroom	Sink	Public Access	121	MY-S121	1.7	None	--	--	--	--
Rm. 132 - Art Room	Sink	Public Access	118	MY-S119	<1.0	None	--	--	--	--
Rm. 132 - Art Room	Sink	Public Access	119	MY-S120	1.2	None	--	--	--	--
Rm. 136 - Staff Bathroom	Sink	Secured - SCSD Staff Only	114	MY-S116	<1.0	None	--	--	--	--
Rm. 137 - Classroom	Sink	Public Access	115	MY-S117	1.9	None	--	--	--	--
Rm. 137 - Classroom	Sink	Public Access	116	MY-S118	1.1	None	--	--	--	--
Rm. 137 - Classroom	Fountain	Public Access	117	MY-F109	<1.0	None	--	--	--	--
Rm. 138 - Classroom	Fountain	Public Access	107	MY-F100	<1.0	None	--	--	--	--
Rm. 138 - Classroom	Sink	Public Access	108	MY-S101	<1.0	None	--	--	--	--
Rm. 138T - Classroom Bathroom	Sink	Public Access	111	MY-S100	4.9	None	--	--	--	--
Rm. 139 - Classroom	Sink	Public Access	103	MY-S103	<1.0	None	--	--	--	--
Rm. 139 - Classroom	Fountain	Public Access	102	MY-F101	<1.0	None	--	--	--	--
Rm. 139T - Classroom	Sink	Public Access	105	MY-S102	7.1	None	--	--	--	--
Rm. 140 - Classroom	Sink	Public Access	100	MY-S105	1.1	None	--	--	--	--

**SYRACUSE CITY SCHOOL DISTRICT
MCKINLEY-BRIGHTON ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	06/23/20 RESULTS (ppb)	06/23/20 ACTIONS	08/12/20 RESULTS (ppb)	08/12/20 ACTIONS	12/30/20 RESULTS (ppb)	12/30/20 ACTIONS
Rm. 140 - Classroom	Fountain	Public Access	099	MY-F102	<1.0	None	--	--	--	--
Rm. 140T - Classroom	Sink	Public Access	---/---/ 002	MY-S104	---	See Note 7	--	--	1.3	None
Rm. 141 - Classroom	Sink	Public Access	---/---/ 003	MY-S106	---	See Note 7	--	--	<1.0	None
Rm. 141 - Classroom	Sink	Public Access	094	MY-S107	<1.0	None	--	--	--	--
Rm. 141 - Classroom	Fountain	Public Access	096	MY-F103	<1.0	None	--	--	--	--
Rm. 142 - Classroom	Sink	Public Access	088	MY-S110	<1.0	None	--	--	--	--
Rm. 142 - Classroom	Sink	Public Access	087	MY-S111	1.7	None	--	--	--	--
Rm. 142 - Classroom	Fountain	Public Access	089	MY-F106	<1.0	None	--	--	--	--
Rm. 146 - Classroom	Sink	Public Access	075	MY-S112	4.8	None	--	--	--	--
Rm. 146 - Classroom	Fountain	Public Access	073	MY-F107	<1.0	None	--	--	--	--
Rm. 146 - Classroom	Sink	Public Access	074	MY-S113	1.9	None	--	--	--	--
Rm. 150 - Classroom	Sink	Public Access	070	MY-S115	<1.0	None	--	--	--	--
Rm. 150 - Classroom	Fountain	Public Access	068	MY-F108	<1.0	None	--	--	--	--
Rm. 150T - Classroom Bathroom	Sink	Public Access	069	MY-S114	5.7	None	--	--	--	--
Rm. 151A - Work Office	Sink	Secured - SCSD Staff Only	125	MY-S127	3.0	None	--	--	--	--
Rm. 151T - Library Bathroom	Sink	Public Access	066	MY-S128	1.1	None	--	--	--	--
Rm. 166 - Hallway/Vestibule	Sink	Public Access	082	MY-S108	<1.0	None	--	--	--	--
Rm. 166 - Hallway/Vestibule	Sink	Public Access	083	MY-S109	<1.0	None	--	--	--	--
Rm. 166 - Hallway/Vestibule	Fountain	Public Access	080	MY-F104	<1.0	None	--	--	--	--
Rm. 166 - Hallway/Vestibule	Fountain	Public Access	081	MY-F105	<1.0	None	--	--	--	--
Rm. 178 - Hallway/Vestibule	Sink	Public Access	038	MY-S214	2.1	None	--	--	--	--
Rm. 178 - Hallway/Vestibule	Sink	Public Access	039	MY-S215	<1.0	None	--	--	--	--
Rm. 178 - Hallway/Vestibule	Sink	Public Access	043	MY-S216	1.9	None	--	--	--	--
Rm. 178 - Hallway/Vestibule	Sink	Public Access	044	MY-S217	<1.0	None	--	--	--	--
Rm. 178 - Hallway/Vestibule	Fountain	Public Access	041	MY-F204	<1.0	None	--	--	--	--
Rm. 178 - Hallway/Vestibule	Fountain	Public Access	042	MY-F205	<1.0	None	--	--	--	--
Rm. 200 - Science Room	Sink	Public Access	030	MY-S324	1.5	None	--	--	--	--
Rm. 202 - Science Room	Sink	Public Access	029	MY-S325	1.2	None	--	--	--	--
Rm. 203 - Faculty Lounge	Sink	Secured - SCSD Staff Only	022	MY-S326	<1.0	None	--	--	--	--

SYRACUSE CITY SCHOOL DISTRICT
MCKINLEY-BRIGHTON ELEMENTARY SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	06/23/20 RESULTS (ppb)	06/23/20 ACTIONS	08/12/20 RESULTS (ppb)	08/12/20 ACTIONS	12/30/20 RESULTS (ppb)	12/30/20 ACTIONS
Rm. 203A - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	027	MY-S327	2.4	None	--	--	--	--
Rm. 203B - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	026	MY-S328	10.3	None	--	--	--	--
Rm. 204 - Science Room	Sink	Public Access	017	MY-S330	<1.0	None	--	--	--	--
Rm. 205T - Classroom Bathroom	Sink	Public Access	021	MY-S329	4.8	None	--	--	--	--
Rm. 210 - Staff Bathroom	Sink	Secured - SCSD Staff Only	016	MY-S331	1.9	None	--	--	--	--
Rm. 217 - Classroom	Sink	Public Access	037	MY-S323	<1.0	None	--	--	--	--
Rm. 217 - Classroom	Sink	Public Access	036	MY-S341	4.5	None	--	--	--	--
Rm. 217 - Classroom	Fountain	Public Access	040	MY-F314	<1.0	None	--	--	--	--
Rm. 218 - Classroom	Sink	Public Access	047	MY-S322	2.3	None	--	--	--	--
Rm. 218 - Classroom	Sink	Public Access	---/---/ 006	MY-S340	--	See Note 7	--	--	1.7	None
Rm. 218 - Classroom	Fountain	Public Access	045	MY-F311	<1.0	None	--	--	--	--
Rm. 219 - Office	Sink	Secured - SCSD Staff Only	053	MY-S320	7.2	None	--	--	--	--
Rm. 219 - Office	Sink	Secured - SCSD Staff Only	052	MY-S321	<1.0	None	--	--	--	--
Rm. 219 - Office	Fountain	Secured - SCSD Staff Only	049	MY-F310	<1.0	None	--	--	--	--
Rm. 221 - Classroom	Sink	Public Access	---/---/007	MY-S318	--	See Note 7	--	--	1.9	None
Rm. 221 - Classroom	Sink	Public Access	057	MY-S319	<1.0	None	--	--	--	--
Rm. 221 - Classroom	Fountain	Public Access	058	MY-F309	<1.0	None	--	--	--	--
Rm. 222 - Classroom	Sink	Public Access	060	MY-S316	<1.0	None	--	--	--	--
Rm. 222 - Classroom	Fountain	Public Access	061	MY-F308	<1.0	None	--	--	--	--
Rm. 222T - Classroom Bathroom	Sink	Public Access	059	MY-S317	1.4	None	--	--	--	--
Rm. 223 - Classroom	Sink	Public Access	065	MY-S315	<1.0	None	--	--	--	--
Rm. 223 - Classroom	Sink	Public Access	064	MY-S338	1.5	None	--	--	--	--
Rm. 223 - Classroom	Fountain	Public Access	067	MY-F307	<1.0	None	--	--	--	--
Rm. 224 - Resource Room	Sink	Public Access	077	MY-S314	1.9	None	--	--	--	--
Rm. 226 - Staff Bathroom	Sink	Secured - SCSD Staff Only	078	MY-S312	1.3	None	--	--	--	--
Rm. 227 - Classroom	Sink	Public Access	072	MY-S313	<1.0	None	--	--	--	--
Rm. 227 - Classroom	Sink	Public Access	071	MY-S337	1.4	None	--	--	--	--
Rm. 227 - Classroom	Fountain	Public Access	076	MY-F306	<1.0	None	--	--	--	--
Rm. 228 - Classroom	Sink	Public Access	084	MY-S307	<1.0	None	--	--	--	--

SYRACUSE CITY SCHOOL DISTRICT
MCKINLEY-BRIGHTON ELEMENTARY SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	06/23/20 RESULTS (ppb)	06/23/20 ACTIONS	08/12/20 RESULTS (ppb)	08/12/20 ACTIONS	12/30/20 RESULTS (ppb)	12/30/20 ACTIONS
Rm. 228 - Classroom	Sink	Public Access	079	MY-S336	2.1	None	--	--	--	--
Rm. 228 - Classroom	Fountain	Public Access	085	MY-F303	<1.0	None	--	--	--	--
Rm. 232 - Classroom	Sink	Public Access	086	MY-S304	<1.0	None	--	--	--	--
Rm. 233 - Classroom	Sink	Public Access	091	MY-S303	<1.0	None	--	--	--	--
Rm. 234 - Classroom	Sink	Public Access	090	MY-S302	<1.0	None	--	--	--	--
Rm. 235 - Classroom	Sink	Public Access	092	MY-S301	1.0	None	--	--	--	--
Rm. 236 - Classroom	Sink	Public Access	104	MY-S308	3.4	None	--	--	--	--
Rm. 236 - Classroom	Sink	Public Access	106	MY-S339	3.3	None	--	--	--	--
Rm. 236 - Classroom	Fountain	Public Access	101	MY-F304	<1.0	None	--	--	--	--
Rm. 238 - Resource Room	Sink	Public Access	113	MY-S311	1.4	None	--	--	--	--
Rm. 239 - Classroom	Sink	Public Access	112	MY-S309	<1.0	None	--	--	--	--
Rm. 239 - Classroom	Sink	Public Access	110	MY-S310	<1.0	None	--	--	--	--
Rm. 239 - Classroom	Fountain	Public Access	109	MY-F305	<1.0	None	--	--	--	--
Rm. 247 - Hallway/Vestibule	Sink	Public Access	004	MY-S332	1.7	None	--	--	--	--
Rm. 247 - Hallway/Vestibule	Sink	Public Access	005	MY-S333	1.0	None	--	--	--	--
Rm. 247 - Hallway/Vestibule	Sink	Public Access	011	MY-S334	1.2	None	--	--	--	--
Rm. 247 - Hallway/Vestibule	Sink	Public Access	013	MY-S335	<1.0	None	--	--	--	--
Rm. 247 - Hallway/Vestibule	Fountain	Public Access	008	MY-F312	<1.0	None	--	--	--	--
Rm. 247 - Hallway/Vestibule	Fountain	Public Access	007	MY-F313	<1.0	None	--	--	--	--
Rm. 256 - Hallway/Vestibule	Sink	Public Access	093	MY-S305	<1.0	None	--	--	--	--
Rm. 256 - Hallway/Vestibule	Sink	Public Access	095	MY-S306	<1.0	None	--	--	--	--
Rm. 256 - Hallway/Vestibule	Fountain	Public Access	097	MY-F301	<1.0	None	--	--	--	--
Rm. 256 - Hallway/Vestibule	Fountain	Public Access	098	MY-F302	<1.0	None	--	--	--	--
Rm. 112 - Kitchen	Convotherm Oven	Secured - SCSD Staff Only	014	MY-C1000	7.0	None	--	--	--	--

SYRACUSE CITY SCHOOL DISTRICT
MCKINLEY-BRIGHTON ELEMENTARY SCHOOL

Original Sample Notes [June 23, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-015
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70136072
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed, replaced, and resampled.
7. Fixture not operational.

Re-Sample Notes [August 12, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-015
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70142050
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.

Re-Sample Notes [December 30, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-015
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70158341
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.