

**SYRACUSE CITY SCHOOL DISTRICT
MEACHEM ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	6/30/20 SAMPLE RESULTS (ppb)	6/30/20 ORIGINAL ACTIONS	8/12/20 RE-SAMPLE RESULTS (ppb)	8/12/20 RE-SAMPLE ACTIONS	10/24/20 RE-SAMPLE RESULTS (ppb)	10/24/20 RE-SAMPLE ACTIONS
Rm. 002 - Cafeteria	Fountain	Public Access	---/006	MM-F100	---	See Note 8.	<1.0	None	---	---
Rm. 03C - Kitchen Bathroom	Sink	Secured - SCSD Staff Only	048	MM-S101	<1.0	None	---	---	---	---
Rm. 005 - Hallway/Vestibule	Sink	Public Access	081	MM-S106	11.0	None	---	---	---	---
Rm. 005 - Hallway/Vestibule	Sink	Public Access	080	MM-S107	1.2	None	---	---	---	---
Rm. 005 - Hallway/Vestibule	Sink	Public Access	078	MM-S108	1.8	None	---	---	---	---
Rm. 005 - Hallway/Vestibule	Sink	Public Access	079	MM-S109	3.4	None	---	---	---	---
Rm. 005 - Hallway/Corridor	Fountain	Public Access	072	MM-F101	<1.0	None	---	---	---	---
Rm. 005 - Hallway/Corridor	Fountain	Public Access	077	MM-F102	<1.0	None	---	---	---	---
Rm. 08A - Custodian's Bathroom	Sink	Secured - SCSD Staff Only	054	MM-S100	4.1	None	---	---	---	---
Rm. 016 - Art Room	Sink	Public Access	040	MM-S110	4.6	None	---	---	---	---
Rm. 016 - Art Room	Sink	Public Access	044	MM-S111	1.3	None	---	---	---	---
Rm. 020C - Unisex Bathroom	Sink	Public Access	039	MM-S112	2.5	None	---	---	---	---
Rm. 023 - Hallway/Corridor	Fountain	Public Access	038	MM-F103	<1.0	None	---	---	---	---
Rm. 026 - Kitchen	Sink	Secured - SCSD Staff Only	057	MM-S102	1.1	None	---	---	---	---
Rm. 026 - Kitchen	Sink	Secured - SCSD Staff Only	060	MM-S103	5.3	None	---	---	---	---
Rm. 026 - Kitchen	Sink	Secured - SCSD Staff Only	063	MM-S104	2.2	None	---	---	---	---
Rm. 026 - Kitchen	Sink	Secured - SCSD Staff Only	066	MM-S105	4.5	None	---	---	---	---
Rm. 100C - Hallway/Vestibule	Sink	Public Access	005	MM-S114	5.2	None	---	---	---	---
Rm. 100C - Hallway/Vestibule	Sink	Public Access	006	MM-S115	11.5	None	---	---	---	---
Rm. 100E - Hallway/Corridor	Fountain	Public Access	002	MM-F104	<1.0	None	---	---	---	---
Rm. 100E - Hallway/Corridor	Fountain	Public Access	003	MM-F105	<1.0	None	---	---	---	---
Rm. 100E - Hallway/Corridor	Fountain	Public Access	012	MM-F106	<1.0	None	---	---	---	---
Rm. 100G - Hallway/Vestibule	Sink	Public Access	010	MM-S116	8.0	None	---	---	---	---
Rm. 100G - Hallway/Vestibule	Sink	Public Access	011	MM-S117	1.9	None	---	---	---	---
Rm. 101B - Gym Office Bathroom	Sink	Secured - SCSD Staff Only	007	MM-S118	7.7	None	---	---	---	---
Rm. 103 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	021	MM-S121	<1.0	None	---	---	---	---
Rm. 103C - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	020	MM-S120	<1.0	None	---	---	---	---
Rm. 103D - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	019	MM-S119	2.1	None	---	---	---	---
Rm. 104A - Exam Room	Sink	Public Access	025	MM-S123	4.1	None	---	---	---	---
Rm. 104B - Nurse's Bathroom	Sink	Public Access	024	MM-S122	1.7	None	---	---	---	---
Rm. 105 - Computer Lab	Sink	Public Access	030	MM-S124	3.2	None	---	---	---	---
Rm. 108 - Classroom	Sink	Public Access	035/001	MM-S128	26.1	See Note 6.	2.1	None	---	---
Rm. 108 - Classroom	Fountain	Public Access	036	MM-F107	2.2	None	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT
MEACHEM ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	6/30/20 SAMPLE RESULTS (ppb)	6/30/20 ORIGINAL ACTIONS	8/12/20 RE-SAMPLE RESULTS (ppb)	8/12/20 RE-SAMPLE ACTIONS	10/24/20 RE-SAMPLE RESULTS (ppb)	10/24/20 RE-SAMPLE ACTIONS
Rm. 108 - Classroom	Sink	Public Access	037	MM-S129	4.1	None	---	---	---	---
Rm. 108B - Classroom Bathroom	Sink	Public Access	033	MM-S126	1.1	None	---	---	---	---
Rm. 108B - Classroom Bathroom	Sink	Public Access	034	MM-S127	6.2	None	---	---	---	---
Rm. 109F - Main Office Bathroom	Sink	Secured - SCSD Staff Only	032	MM-S125	4.1	None	---	---	---	---
Rm. 110 - Classroom	Sink	Public Access	042/002	MM-S131	46.3	See Note 6.	1.4	None	---	---
Rm. 110 - Classroom	Fountain	Public Access	043	MM-F108	5.3	None	---	---	---	---
Rm. 110A - Classroom Bathroom	Sink	Public Access	041	MM-S130	9.6	None	---	---	---	---
Rm. 111 - Classroom	Sink	Public Access	061	MM-S140	2.9	None	---	---	---	---
Rm. 111 - Classroom	Fountain	Public Access	062	MM-F113	4.5	None	---	---	---	---
Rm. 112 - Classroom	Sink	Public Access	056	MM-S138	1.7	None	---	---	---	---
Rm. 112 - Classroom	Fountain	Public Access	055	MM-F111	2.6	None	---	---	---	---
Rm. 113 - Classroom	Sink	Public Access	064	MM-S141	1.3	None	---	---	---	---
Rm. 113 - Classroom	Fountain	Public Access	065	MM-F114	12.6	None	---	---	---	---
Rm. 114 - Classroom	Sink	Public Access	059	MM-S139	9.3	None	---	---	---	---
Rm. 114 - Classroom	Fountain	Public Access	058	MM-F112	2.9	None	---	---	---	---
Rm. 115 - Classroom	Sink	Public Access	068	MM-S142	<1.0	None	---	---	---	---
Rm. 115 - Classroom	Fountain	Public Access	067	MM-F115	3.8	None	---	---	---	---
Rm. 116 - Classroom	Sink	Public Access	071	MM-S143	4.4	None	---	---	---	---
Rm. 116 - Classroom	Fountain	Public Access	070	MM-F116	1.4	None	---	---	---	---
Rm. 117 - Classroom	Sink	Public Access	075	MM-S144	2.0	None	---	---	---	---
Rm. 117 - Classroom	Fountain	Public Access	076	MM-F117	2.8	None	---	---	---	---
Rm. 119 - Classroom	Sink	Public Access	073	MM-S145	1.3	None	---	---	---	---
Rm. 119 - Classroom	Fountain	Public Access	074	MM-F118	2.1	None	---	---	---	---
Rm. 122 - Staff Bathroom	Sink	Secured - SCSD Staff Only	045	MM-S132	3.5	None	---	---	---	---
Rm. 128 - Hallway/Corridor	Fountain	Public Access	046	MM-F109	<1.0	None	---	---	---	---
Rm. 128 - Hallway/Corridor	Fountain	Public Access	047	MM-F110	<1.0	None	---	---	---	---
Rm. 130A - Hallway/Vestibule	Sink	Public Access	049	MM-S133	2.1	None	---	---	---	---
Rm. 130A - Hallway/Vestibule	Sink	Public Access	050	MM-S134	2.2	None	---	---	---	---
Rm. 130A - Hallway/Vestibule	Sink	Public Access	051	MM-S135	4.3	None	---	---	---	---
Rm. 130A - Hallway/Vestibule	Sink	Public Access	052/003	MM-S136	16.2	See Note 6.	1.1	None	---	---
Rm. 130A - Hallway/Vestibule	Sink	Public Access	053	MM-S137	5.9	None	---	---	---	---
Rm. 141 - Group Instruction Room	Sink	Secured - SCSD Staff Only	001	MM-S113	9.6	None	---	---	---	---
Rm. 219 - Hallway/Corridor	Fountain	Public Access	018	MM-F121	<1.0	None	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT
MEACHEM ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	6/30/20 SAMPLE RESULTS (ppb)	6/30/20 ORIGINAL ACTIONS	8/12/20 RE-SAMPLE RESULTS (ppb)	8/12/20 RE-SAMPLE ACTIONS	10/24/20 RE-SAMPLE RESULTS (ppb)	10/24/20 RE-SAMPLE ACTIONS
Rm. 219 - Hallway/Corridor	Fountain	Public Access	022	MM-F122	<1.0	None	---	---	---	---
Rm. 221 - Staff Bathroom	Sink	Secured - SCSD Staff Only	017	MM-S151	<1.0	None	---	---	---	---
Rm. 223A - Library Office	Sink	Secured - SCSD Staff Only	031	MM-S157	8.2	None	---	---	---	---
Rm. 226 - Hallway/Vestibule	Sink	Public Access	023	MM-S152	2.9	None	---	---	---	---
Rm. 226 - Hallway/Vestibule	Sink	Public Access	026	MM-S153	7.2	None	---	---	---	---
Rm. 226 - Hallway/Vestibule	Sink	Public Access	027	MM-S154	2.7	None	---	---	---	---
Rm. 226 - Hallway/Vestibule	Sink	Public Access	028/004	MM-S155	36.0	See Note 6.	<1.0	None	---	---
Rm. 226 - Hallway/Vestibule	Sink	Public Access	029	MM-S156	1.4	None	---	---	---	---
Rm. 228 - Hallway/Corridor	Fountain	Public Access	008	MM-F119	<1.0	None	---	---	---	---
Rm. 228 - Hallway/Corridor	Fountain	Public Access	009	MM-F120	<1.0	None	---	---	---	---
Rm. 228C - Staff Bathroom	Sink	Secured - SCSD Staff Only	004	MM-S146	2.5	None	---	---	---	---
Rm. 231 - Hallway/Vestibule	Sink	Public Access	013	MM-S147	2.9	None	---	---	---	---
Rm. 231 - Hallway/Vestibule	Sink	Public Access	014	MM-S148	4.3	None	---	---	---	---
Rm. 231 - Hallway/Vestibule	Sink	Public Access	015	MM-S149	2.6	None	---	---	---	---
Rm. 231 - Hallway/Vestibule	Sink	Public Access	016	MM-S150	6.8	None	---	---	---	---
Rm. 026 - Kitchen	Convotherm Oven Sprayer	Secured - SCSD Staff Only	069/005/001	MM-C1000	129.0	See Note 7.	50.9	See Note 6.	6.1	None

Original Sample Notes: [June 30, 2020 Event]

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-021
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70136899
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed, replaced and resampled.
7. In-line filter installed by SCSD and resampling performed.
8. Fountain F100 had been removed prior to the June 30, 2020 sampling event and replaced prior to the August 12, 2020 resampling event.

Re-Sample Notes: [August 12, 2020 Event]

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-021
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70142051
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Evaluation performed by SCSD.

SYRACUSE CITY SCHOOL DISTRICT
MEACHEM ELEMENTARY SCHOOL

Re-Sample Notes: [October 24, 2020 Event]

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-021
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70151490
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.