

**SYRACUSE CITY SCHOOL DISTRICT  
PORTER ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE ID No.	TDK SAMPLE ID No.	02/21/20 RESULTS (ppb)	02/21/20 ORIGINAL ACTIONS	08/07/20 RESULTS (ppb)	08/07/20 RE- SAMPLE ACTIONS	10/24/20 RESULTS (ppb)	10/24/20 RE- SAMPLE ACTIONS	11/21/20 RESULTS (ppb)	11/21/20 RE- SAMPLE ACTIONS
Rm. 001 - Hallway/Corridor	Fountain	Public Access	020	PR-F303	<1.0	None	---	---	---	---	---	---
Rm. 001C - Hallway/Corridor	Fountain	Public Access	047	PR-F302	<1.0	None	---	---	---	---	---	---
Rm. 001C - Hallway/Corridor	Fountain	Public Access	048	PR-F301	<1.0	None	---	---	---	---	---	---
Rm. 003 - Custodian's Office	Sink	Secured - SCSD Staff Only	037	PR-S313	<1.0	None	---	---	---	---	---	---
Rm. 004A - Classroom Bathroom	Sink	Public Access	038	PR-S311	<1.0	None	---	---	---	---	---	---
Rm. 005A - Classroom Bathroom	Sink	Public Access	042	PR-S310	<1.0	None	---	---	---	---	---	---
Rm. 007 - Boy's Bathroom	Sink	Public Access	044	PR-S303	<1.0	None	---	---	---	---	---	---
Rm. 007 - Boy's Bathroom	Sink	Public Access	045	PR-S304	<1.0	None	---	---	---	---	---	---
Rm. 009 - Girl's Bathroom	Sink	Public Access	049	PR-S301	3.2	None	---	---	---	---	---	---
Rm. 009 - Girl's Bathroom	Sink	Public Access	051	PR-S302	<1.0	None	---	---	---	---	---	---
Rm. 010 - Serving Room	Convotherm Oven Sprayer	Secured - SCSD Staff Only	070/001/001/001	PR-S400	30.8	See Note 6	19.9	See Note 6	20.2	See Note 6	36.4	See Note 6
Rm. 010 - Serving Room	Sink	Secured - SCSD Staff Only	056	PR-S306	<1.0	None	---	---	---	---	---	---
Rm. 010 - Serving Room	Sink	Secured - SCSD Staff Only	058	PR-S307	<1.0	None	---	---	---	---	---	---
Rm. 010 - Serving Room	Sink	Secured - SCSD Staff Only	060	PR-S308	1.1	None	---	---	---	---	---	---
Rm. 010 - Serving Room	Sink	Secured - SCSD Staff Only	055	PR-S309	2.8	None	---	---	---	---	---	---
Rm. 010C - Staff Bathroom	Sink	Secured - SCSD Staff Only	052	PR-S305	<1.0	None	---	---	---	---	---	---
Rm. 014A - Classroom Bathroom	Sink	Public Access	041	PR-S312	2.3	None	---	---	---	---	---	---
Rm. 021A - Classroom Bathroom	Sink	Public Access	010	PR-S319	<1.0	None	---	---	---	---	---	---
Rm. 022 - Classroom	Fountain	Public Access	002	PR-F305	<1.0	None	---	---	---	---	---	---
Rm. 022B - Classroom Bathroom	Sink	Public Access	003	PR-S322	<1.0	None	---	---	---	---	---	---
Rm. 024 - Classroom	Sink	Public Access	007	PR-S321	<1.0	None	---	---	---	---	---	---
Rm. 024 - Classroom	Fountain	Public Access	005	PR-F304	2.2	None	---	---	---	---	---	---
Rm. 024A - Classroom Bathroom	Sink	Public Access	004	PR-S320	1.8	None	---	---	---	---	---	---
Rm. 025A - Classroom Bathroom	Sink	Public Access	012	PR-S318	1.4	None	---	---	---	---	---	---
Rm. 026 - Staff's Lounge	Sink	Secured - SCSD Staff Only	013	PR-S314	<1.0	None	---	---	---	---	---	---
Rm. 026A - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	017	PR-S315	<1.0	None	---	---	---	---	---	---
Rm. 026A - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	018	PR-S316	2.2	None	---	---	---	---	---	---
Rm. 026B - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	014	PR-S317	<1.0	None	---	---	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT  
PORTER ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE ID No.	TDK SAMPLE ID No.	02/21/20 RESULTS (ppb)	02/21/20 ORIGINAL ACTIONS	08/07/20 RESULTS (ppb)	08/07/20 RE- SAMPLE ACTIONS	10/24/20 RESULTS (ppb)	10/24/20 RE- SAMPLE ACTIONS	11/21/20 RESULTS (ppb)	11/21/20 RE- SAMPLE ACTIONS
Rm. 036B - Hallway/Corridor	Fountain	Public Access	024	PR-F306	2.2	None	---	---	---	---	---	---
Rm. 037 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	028	PR-S323	3.0	None	---	---	---	---	---	---
Rm. 038 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	027	PR-S325	12.6	None	---	---	---	---	---	---
Rm. 041A - Gym Office Bathroom	Sink	Secured - SCSD Staff Only	025	PR-S324	3.9	None	---	---	---	---	---	---
Rm. 101 - Hallway/Corridor	Fountain	Public Access	057	PR-F307	<1.0	None	---	---	---	---	---	---
Rm. 102D - Principal's Bathroom	Sink	Secured - SCSD Staff Only	068	PR-S336	2.7	None	---	---	---	---	---	---
Rm. 102I - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	053	PR-S334	<1.0	None	---	---	---	---	---	---
Rm. 102J - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	054	PR-S335	1.0	None	---	---	---	---	---	---
Rm. 103A Assist. Principal's Bathroom	Sink	Secured - SCSD Staff Only	069	PR-S333	2.7	None	---	---	---	---	---	---
Rm. 104A - Office Bathroom	Sink	Secured - SCSD Staff Only	050	PR-S332	1.4	None	---	---	---	---	---	---
Rm. 106 - Classroom	Sink	Public Access	046	PR-S331	2.7	None	---	---	---	---	---	---
Rm. 107 - Boy's Bathroom	Sink	Public Access	039	PR-S329	<1.0	None	---	---	---	---	---	---
Rm. 107 - Boy's Bathroom	Sink	Public Access	040	PR-S330	2.3	None	---	---	---	---	---	---
Rm. 109 - Girl's Bathroom	Sink	Public Access	035	PR-S327	<1.0	None	---	---	---	---	---	---
Rm. 109 - Girl's Bathroom	Sink	Public Access	036	PR-S328	<1.0	None	---	---	---	---	---	---
Rm. 110A - Library Office	Sink	Secured - SCSD Staff Only	043	PR-S326	3.0	None	---	---	---	---	---	---
Rm. 116 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	063	PR-S338	3.5	None	---	---	---	---	---	---
Rm. 118C - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	064	PR-S341	<1.0	None	---	---	---	---	---	---
Rm. 119 - Hallway/Vestibule	Sink	Public Access	065	PR-S342	<1.0	None	---	---	---	---	---	---
Rm. 119 - Hallway/Vestibule	Sink	Public Access	066	PR-S343	<1.0	None	---	---	---	---	---	---
Rm. 119 - Hallway/Vestibule	Sink	Public Access	067	PR-S344	<1.0	None	---	---	---	---	---	---
Rm. 125A - Exam Room	Sink	Public Access	062	PR-S340	<1.0	None	---	---	---	---	---	---
Rm. 125B - Exam Room Bathroom	Sink	Public Access	061	PR-S339	1.9	None	---	---	---	---	---	---
Rm. 127 - Parent's Room	Sink	Public Access	059	PR-S337	<1.0	None	---	---	---	---	---	---
Rm. 201 - Hallway/Corridor	Fountain	Public Access	019	PR-F308	<1.0	None	---	---	---	---	---	---
Rm. 202A - Resource Room Bathroom	Sink	Public Access	023	PR-S352	<1.0	None	---	---	---	---	---	---
Rm. 203 - Classroom	Sink	Public Access	026	PR-S351	4.4	None	---	---	---	---	---	---
Rm. 206 - Classroom	Sink	Public Access	029	PR-S350	<1.0	None	---	---	---	---	---	---
Rm. 207 - Boy's Bathroom	Sink	Public Access	030/002	PR-S347	27.0	See Note 7	2.3	None	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT  
PORTER ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE ID No.	TDK SAMPLE ID No.	02/21/20 RESULTS (ppb)	02/21/20 ORIGINAL ACTIONS	08/07/20 RESULTS (ppb)	08/07/20 RE- SAMPLE ACTIONS	10/24/20 RESULTS (ppb)	10/24/20 RE- SAMPLE ACTIONS	11/21/20 RESULTS (ppb)	11/21/20 RE- SAMPLE ACTIONS
Rm. 207 - Boy's Bathroom	Sink	Public Access	031	PR-S348	1.7	None	---	---	---	---	---	---
Rm. 209 - Girl's Bathroom	Sink	Public Access	032	PR-S345	<1.0	None	---	---	---	---	---	---
Rm. 209 - Girl's Bathroom	Sink	Public Access	033	PR-S346	<1.0	None	---	---	---	---	---	---
Rm. 212 - Classroom	Sink	Public Access	034	PR-S349	<1.0	None	---	---	---	---	---	---
Rm. 218 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	015	PR-S356	<1.0	None	---	---	---	---	---	---
Rm. 220A - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	011	PR-S357	<1.0	None	---	---	---	---	---	---
Rm. 221 - Hallway/Vestibule	Sink	Public Access	009	PR-S358	<1.0	None	---	---	---	---	---	---
Rm. 221 - Hallway/Vestibule	Sink	Public Access	008	PR-S359	2.0	None	---	---	---	---	---	---
Rm. 221 - Hallway/Vestibule	Sink	Public Access	006	PR-S360	<1.0	None	---	---	---	---	---	---
Rm. 222 - Classroom	Sink	Public Access	001/003/002/002	PR-S361	23.5	See Note 7	21.2	See Note 6	28.2	See Note 6	1.9	None
Rm. 226 - Classroom	Sink	Public Access	016	PR-S355	4.6	None	---	---	---	---	---	---
Rm. 228 - Art Room	Sink	Public Access	021	PR-S353	10.2	None	---	---	---	---	---	---
Rm. 228 - Art Room	Sink	Public Access	022	PR-S354	8.7	None	---	---	---	---	---	---

# SYRACUSE CITY SCHOOL DISTRICT PORTER ELEMENTARY SCHOOL

## Original Sample Notes [February 21, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-020
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70122673
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. In-line filter installed by SCSD and resampling performed.
7. Fixture removed, replaced and resampled.

## Re-Sample Notes [August 07, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-020
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70141223
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Remediation performed by SCSD and resampling performed.

## Re-Sample Notes [October 24, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-020
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70151488
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Remediation performed by SCSD and resampling performed.

## Re-Sample Notes [November 21, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-020
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70154652
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Remediation performed by SCSD and resampling performed.