

**SYRACUSE CITY SCHOOL DISTRICT
ROBERTS PK-GRADE 8 SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	07/02/2020 ORIGINAL RESULTS (ppb)	07/02/20 ORIGINAL ACTIONS	08/07/20 RE-SAMPLE RESULTS (ppb)	08/07/20 RE-SAMPLE ACTIONS
Rm. 115 - Staff Bathroom	Sink	Secured - SCSD Staff Only	020	RS-S200	1.0	None	--	--
Rm. 118 - Art Room	Sink	Public Access	022	RS-S201A	1.1	None	--	--
Rm. 118 - Art Room	Sink	Public Access	023	RS-S202A	<1.0	None	--	--
Rm. 122 - Receiving Room	Sink	Secured - SCSD Staff Only	001	RS-S311	1.5	None	--	--
Rm. 122A - Kitchen Staff Bathroom	Sink	Secured - SCSD Staff Only	002	RS-S310	<1.0	None	--	--
Rm. 128 - Kitchen	Sink	Secured - SCSD Staff Only	009	RS-S306	6.2	None	--	--
Rm. 128 - Kitchen	Sink	Secured - SCSD Staff Only	008	RS-S307	3.7	None	--	--
Rm. 128 - Kitchen	Sink	Secured - SCSD Staff Only	005	RS-S308	2.4	None	--	--
Rm. 128 - Kitchen	Sink	Secured - SCSD Staff Only	004	RS-S309	1.6	None	--	--
Rm. 132 - Hallway/Vestibule	Sink	Public Access	029	RS-S301	6.3	None	--	--
Rm. 132 - Hallway/Vestibule	Sink	Public Access	030	RS-S302	6.7	None	--	--
Rm. 132 - Hallway/Vestibule	Sink	Public Access	031	RS-S303	2.6	None	--	--
Rm. 132 - Hallway/Vestibule	Sink	Public Access	026	RS-S304	2.5	None	--	--
Rm. 132 - Hallway/Vestibule	Sink	Public Access	025	RS-S305	1.6	None	--	--
Rm. 132 - Hallway/Corridor	Fountain	Public Access	032	RS-F301	<1.0	None	--	--
Rm. 132 - Hallway/Corridor	Fountain	Public Access	035	RS-F302	<1.0	None	--	--
Rm. 151A - Kitchen	Sink	Secured - SCSD Staff Only	037	RS-S110	<1.0	None	--	--
Rm. 151B - Kitchen Staff Bathroom	Sink	Secured - SCSD Staff Only	038	RS-S111	<1.0	None	--	--
Rm. 152A - Staff Bathroom	Sink	Secured - SCSD Staff Only	040	RS-S109	2.6	None	--	--
Rm. 158 - Classroom	Sink	Public Access	054	RS-S105	<1.0	None	--	--
Rm. 158 - Classroom	Fountain	Public Access	052	RS-F102	<1.0	None	--	--
Rm. 158C - Classroom Bathroom	Sink	Public Access	055	RS-S106	3.1	None	--	--
Rm. 159 - Classroom	Sink	Public Access	057	RS-S103	<1.0	None	--	--
Rm. 159 - Classroom	Fountain	Public Access	058	RS-F101	<1.0	None	--	--
Rm. 159C - Classroom Bathroom	Sink	Public Access	059	RS-S104	<1.0	None	--	--
Rm. 160 - Classroom	Sink	Public Access	061	RS-S101	<1.0	None	--	--
Rm. 160 - Classroom	Fountain	Public Access	062	RS-F100	<1.0	None	--	--
Rm. 160C - Classroom Bathroom	Sink	Public Access	082	RS-S102	<1.0	None	--	--
Rm. 161 - Classroom	Sink	Public Access	044	RS-S107	<1.0	None	--	--
Rm. 161 - Classroom	Fountain	Public Access	046	RS-F103	<1.0	None	--	--
Rm. 161C - Classroom Bathroom	Sink	Public Access	045	RS-S108	<1.0	None	--	--

**SYRACUSE CITY SCHOOL DISTRICT
ROBERTS PK-GRADE 8 SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	07/02/2020 ORIGINAL RESULTS (ppb)	07/02/20 ORIGINAL ACTIONS	08/07/20 RE-SAMPLE RESULTS (ppb)	08/07/20 RE-SAMPLE ACTIONS
Rm. 274 - Classroom	Sink	Public Access	080	RS-S112	<1.0	None	--	--
Rm. 211 - Classroom	Sink	Public Access	024	RS-S207	2.6	None	--	--
Rm. 211 - Classroom	Fountain	Public Access	027	RS-F203	<1.0	None	--	--
Rm. 211D - Classroom Bathroom	Sink	Public Access	028	RS-S206	1.2	None	--	--
Rm. 214 - Classroom	Sink	Public Access	033	RS-S209	<1.0	None	--	--
Rm. 214 - Classroom	Fountain	Public Access	034	RS-F204	<1.0	None	--	--
Rm. 214D - Classroom Bathroom	Sink	Public Access	036/002	RS-S208	22.0	See Note 6.	9.6	None
Rm. 215 - Hallway/Corridor	Fountain	Public Access	047	RS-F201	<1.0	None	--	--
Rm. 215 - Hallway/Corridor	Fountain	Public Access	043	RS-F202	<1.0	None	--	--
Rm. 219 - Teacher's Lounge	Fountain	Public Access	039	RS-F108	<1.0	None	--	--
Rm. 220 - Hallway/Vestibule	Sink	Public Access	049	RS-S202B	1.7	None	--	--
Rm. 220 - Hallway/Vestibule	Sink	Public Access	050	RS-S203	1.8	None	--	--
Rm. 220 - Hallway/Vestibule	Sink	Public Access	051	RS-S204	1.8	None	--	--
Rm. 220 - Hallway/Vestibule	Sink	Public Access	053	RS-S205	2.6	None	--	--
Rm. 220 - Hallway/Vestibule	Sink	Public Access	048	RS-S201B	1.4	None	--	--
Rm. 224A - Staff Bathroom	Sink	Secured - SCSD Staff Only	041	RS-S121	<1.0	None	--	--
Rm. 224B - Staff Bathroom	Sink	Secured - SCSD Staff Only	042	RS-S122	2.4	None	--	--
Rm. 229A - Gym Office Bathroom	Sink	Public Access	064	RS-S213	5.0	None	--	--
Rm. 229B - Gym Bathroom	Sink	Public Access	063	RS-S212	<1.0	None	--	--
Rm. 237 - Staff Bathroom	Sink	Secured - SCSD Staff Only	056	RS-S210	2.5	None	--	--
Rm. 239 - Hallway/Corridor	Fountain	Public Access	065	RS-F205	<1.0	None	--	--
Rm. 239 - Hallway/Corridor	Fountain	Public Access	069	RS-F107	<1.0	None	--	--
Rm. 244 - Office	Sink	Secured - SCSD Staff Only	060	RS-S211	1.7	None	--	--
Rm. 252 - Office Staff Bathroom	Bathroom Sink	Secured - SCSD Staff Only	067	RS-S123	1.6	None	--	--
Rm. 253 - Office Staff Bathroom	Bathroom Sink	Secured - SCSD Staff Only	066	RS-S124	2.9	None	--	--
Rm. 255 - Office Kitchenette	Sink	Secured - SCSD Staff Only	068	RS-S125	1.5	None	--	--
Rm. 263 - Nurse's Room	Sink	Public Access	077	RS-S118	<1.0	None	--	--
Rm. 263A - Nurse's Bathroom	Sink	Public Access	074	RS-S119	3.5	None	--	--
Rm. 267 - Kitchen/Teacher's Lounge	Sink	Secured - SCSD Staff Only	073	RS-S120	2.3	None	--	--
Rm. 269B - Classroom Bathroom	Sink	Public Access	081	RS-S113	2.9	None	--	--
Rm. 270B - Classroom Bathroom	Sink	Public Access	072	RS-S115	4.0	None	--	--

**SYRACUSE CITY SCHOOL DISTRICT
ROBERTS PK-GRADE 8 SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	07/02/2020 ORIGINAL RESULTS (ppb)	07/02/20 ORIGINAL ACTIONS	08/07/20 RE-SAMPLE RESULTS (ppb)	08/07/20 RE-SAMPLE ACTIONS
Rm. 271B - Classroom Bathroom	Sink	Public Access	078	RS-S117	3.7	None	--	--
Rm. 272 - Classroom	Sink	Public Access	076	RS-S116	2.3	None	--	--
Rm. 272 - Classroom	Fountain	Public Access	075	RS-F106	<1.0	None	--	--
Rm. 273 - Classroom	Sink	Public Access	070/003	RS-S114	41.5	See Note 6.	1.1	None
Rm. 273 - Classroom	Fountain	Public Access	071	RS-F105	<1.0	None	--	--
Rm. 274 - Classroom	Fountain	Public Access	079	RS-F104	<1.0	None	--	--
Rm. 311 - Staff Bathroom	Sink	Secured - SCSD Staff Only	003	RS-S312	3.5	None	--	--
Rm. 311 - Classroom	Sink	Public Access	021	RS-S322	2.5	None	--	--
Rm. 311 - Classroom	Sink	Public Access	018	RS-S323	4.6	None	--	--
Rm. 311 - Classroom	Sink	Public Access	019/004	RS-S324	59.5	See Note 6.	1.9	None
Rm. 313 - Classroom	Sink	Public Access	016	RS-S320	4.5	None	--	--
Rm. 313 - Classroom	Sink	Public Access	017	RS-S321	1.1	None	--	--
Rm. 325 - Hallway/Vestibule	Sink	Public Access	011	RS-S317	1.2	None	--	--
Rm. 325 - Hallway/Vestibule	Sink	Public Access	013	RS-S318	<1.0	None	--	--
Rm. 325 - Hallway/Vestibule	Sink	Public Access	014	RS-S319	1.8	None	--	--
Rm. 327 - Hallway/Vestibule	Sink	Public Access	006	RS-S314	1.3	None	--	--
Rm. 327 - Hallway/Vestibule	Sink	Public Access	007	RS-S315	2.4	None	--	--
Rm. 327 - Hallway/Vestibule	Sink	Public Access	010	RS-S316	1.6	None	--	--
Rm. 329 - Hallway/Corridor	Fountain	Public Access	015	RS-F303	<1.0	None	--	--
Rm. 151A - Kitchen	Convotherm Oven	Secured - SCSD Staff Only	012/001	RS-C1000	39.1	See Note 7.	7.8	None

Original Sample Notes: [July 2, 2020 Event]

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-014
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70137221
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed, replaced and resampled.
7. In-line filter installed by SCSD and resampling performed.

SYRACUSE CITY SCHOOL DISTRICT

ROBERTS PK-GRADE 8 SCHOOL

Re-Sample Notes: [August 7, 2020 Event]

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-014
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70141218
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.