

**SYRACUSE CITY SCHOOL DISTRICT
SALEM-HYDE ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	2/15/20 SAMPLE RESULTS (ppb)	2/15/20 ORIGINAL ACTIONS	11/14/20 RE-SAMPLE RESULTS (ppb)	11/14/20 RE-SAMPLE ACTIONS
Rm. 004 - Gym Office	Sink	Secured - SCSD Staff Only	025	SH-S100	2.2	None	---	---
Rm. 005 - Boy's Lockerroom	Sink	Public Access	024	SH-S101	2.1	None	---	---
Rm. 014 - Boy's Bathroom	Sink	Public Access	001	SH-S102	<1.0	None	---	---
Rm. 013 - Girl's Bathroom	Sink	Public Access	002	SH-S103	<1.0	None	---	---
Rm. 012 - Cafeteria	Fountain	Public Access	004	SH-F100	<1.0	None	---	---
Rm. 022 - Kitchen	Sink	Secured - SCSD Staff Only	005	SH-S104	1.5	None	---	---
Rm. 022 - Kitchen	Sink	Secured - SCSD Staff Only	007	SH-S105	1.1	None	---	---
Rm. 022 - Kitchen	Sink	Secured - SCSD Staff Only	012	SH-S106	<1.0	None	---	---
Rm. 022 - Kitchen	Sink	Secured - SCSD Staff Only	015	SH-S107	<1.0	None	---	---
Rm. 022 - Kitchen	Kitchen Equipment	Secured - SCSD Staff Only	014	SH-S400	4.6	None	---	---
Rm. 023 - Kitchen Bathroom	Sink	Secured - SCSD Staff Only	018	SH-S108	<1.0	None	---	---
Rm. 218 - Classroom	Fountain	Public Access	---/001	SH-F101	---	Fixture Repaired	7.6	None
Rm. 218 - Classroom	Sink	Public Access	003	SH-S109	1.5	None	---	---
Rm. 224A - Hallway/Vestibule	Bathroom Sink	Public Access	008	SH-S110	<1.0	None	---	---
Rm. 224A - Hallway/Vestibule	Bathroom Sink	Public Access	009	SH-S111	2.0	None	---	---
Rm. 224A - Hallway/Vestibule	Bathroom Sink	Public Access	011	SH-S112	<1.0	None	---	---
Rm. 224A - Hallway/Vestibule	Fountain	Public Access	010	SH-F102	<1.0	None	---	---
Rm. 205 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	016	SH-S113	2.2	None	---	---
Rm. 205A - Staff Bathroom	Sink	Secured - SCSD Staff Only	013	SH-S114	<1.0	None	---	---
Rm. 205B - Staff Bathroom	Sink	Secured - SCSD Staff Only	017	SH-S115	<1.0	None	---	---
Rm. 238 Girl's Bathroom	Sink	Public Access	026	SH-S116	<1.0	None	---	---
Rm. 224 - Hallway/Corridor	Fountain	Public Access	020	SH-F103	<1.0	None	---	---
Rm. 238 - Girl's Bathroom	Sink	Public Access	027	SH-S117	<1.0	None	---	---
Rm. 238 - Girl's Bathroom	Sink	Public Access	028	SH-S118	<1.0	None	---	---
Rm. 238 - Girl's Bathroom	Sink	Public Access	029	SH-S119	<1.0	None	---	---
Rm. 237 - Boy's Bathroom	Sink	Public Access	068	SH-S120	<1.0	None	---	---
Rm. 237 - Boy's Bathroom	Sink	Public Access	022	SH-S121	1.7	None	---	---
Rm. 237 - Boy's Bathroom	Sink	Public Access	023	SH-S122	1.6	None	---	---

**SYRACUSE CITY SCHOOL DISTRICT
SALEM-HYDE ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	2/15/20 SAMPLE RESULTS (ppb)	2/15/20 ORIGINAL ACTIONS	11/14/20 RE-SAMPLE RESULTS (ppb)	11/14/20 RE-SAMPLE ACTIONS
Rm. 239 - Hallway/Corridor	Bathroom Sink	Secured - SCSD Staff Only	030	SH-S123	<1.0	None	---	---
Rm. 006 - Girl's Lockerroom	Sink	Public Access	021	SH-S200	1.2	None	---	---
Rm. 025 - Hallway/Corridor	Fountain	Public Access	019	SH-F200	<1.0	None	---	---
Rm. 101 - Classroom	Fountain	Public Access	037	SH-F201	3.9	None	---	---
Rm. 119B - Classroom Bathroom	Sink	Public Access	040	SH-S202	1.5	None	---	---
Rm. 101A - Classroom Bathroom	Sink	Public Access	038	SH-S203	3.1	None	---	---
Rm. 120 - Classroom	Sink	Public Access	042	SH-S204	3.4	None	---	---
Rm. 120 - Classroom	Fountain	Public Access	046	SH-F202	4.4	None	---	---
Rm. 102 - Classroom	Sink	Public Access	049	SH-S205	1.9	None	---	---
Rm. 102 - Classroom	Fountain	Public Access	050	SH-F203	1.7	None	---	---
Rm. 102A - Classroom Bathroom	Sink	Public Access	047	SH-S206	1.6	None	---	---
Rm. 104C - Office Bathroom	Sink	Secured - SCSD Staff Only	067	SH-S207	<1.0	None	---	---
Rm. 103 - Classroom	Sink	Public Access	066	SH-S208	<1.0	None	---	---
Rm. 137 - Hallway/Corridor	Bathroom Sink	Secured - SCSD Staff Only	063	SH-S209	<1.0	None	---	---
Rm. 138 - Hallway/Corridor	Bathroom Sink	Secured - SCSD Staff Only	064	SH-S210	1.8	None	---	---
Rm. 105A - Exam Room	Sink	Public Access	061	SH-S211	<1.0	None	---	---
Rm. 105B - Nurse's Office Bathroom	Sink	Public Access	062	SH-S212	<1.0	None	---	---
Rm. 108 - Classroom	Sink	Public Access	055	SH-S213	<1.0	None	---	---
Rm. 109 - Classroom	Sink	Public Access	069	SH-S214	<1.0	None	---	---
Rm. 109 - Classroom	Fountain	Public Access	039	SH-F204	<1.0	None	---	---
Rm. 109A - Classroom Bathroom	Sink	Public Access	041	SH-S215	2.6	None	---	---
Rm. 110 - Classroom	Sink	Public Access	031	SH-S216	<1.0	None	---	---
Rm. 110 - Classroom	Fountain	Public Access	032	SH-F205	<1.0	None	---	---
Rm. 110A - Classroom Bathroom	Sink	Public Access	033	SH-S217	<1.0	None	---	---
Rm. 111 - Classroom	Fountain	Public Access	034	SH-F206	1.1	None	---	---
Rm. 111 - Classroom	Sink	Public Access	035	SH-S218	<1.0	None	---	---
Rm. 111A - Classroom Bathroom	Sink	Public Access	036	SH-S219	1.1	None	---	---
Rm. 112 - Classroom	Sink	Public Access	052	SH-S220	<1.0	None	---	---

**SYRACUSE CITY SCHOOL DISTRICT
SALEM-HYDE ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	2/15/20 SAMPLE RESULTS (ppb)	2/15/20 ORIGINAL ACTIONS	11/14/20 RE-SAMPLE RESULTS (ppb)	11/14/20 RE-SAMPLE ACTIONS
Rm. 112 - Classroom	Fountain	Public Access	048	SH-F207	1.1	None	---	---
Rm. 112A - Classroom Bathroom	Sink	Public Access	051	SH-S221	<1.0	None	---	---
Rm. 113 - Classroom	Fountain	Public Access	043	SH-F208	1.1	None	---	---
Rm. 113 - Classroom	Sink	Public Access	045	SH-S222	<1.0	None	---	---
Rm. 113A - Classroom Bathroom	Sink	Public Access	044	SH-S223	<1.0	None	---	---
Rm. 131 - Hallway/Vestibule	Fountain	Public Access	058	SH-F209	<1.0	None	---	---
Rm. 131 - Hallway/Vestibule	Sink	Public Access	059	SH-S224	<1.0	None	---	---
Rm. 131 - Hallway/Vestibule	Sink	Public Access	056	SH-S225	<1.0	None	---	---
Rm. 131 - Hallway/Vestibule	Sink	Public Access	054	SH-S226	1.3	None	---	---
Rm. 115B - Work Room	Sink	Secured -SCSD Staff Only	065	SH-S227	1.0	None	---	---
Rm. 119 - Classroom	Fountain	Public Access	060	SH-F210	4.4	None	---	---
Rm. 119 - Classroom	Sink	Public Access	057	SH-S228	1.9	None	---	---
Rm. 119A - Classroom Bathroom	Sink	Public Access	053	SH-S229	1.0	None	---	---
Rm. 223 - Hallway/Corridor	Fountain	Public Access	006	SH-F400	1.1	None	---	---

Original Sample Notes: [February 15, 2020 Event]

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-006
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70122664
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.

Re-Sample Notes: [November 14, 2020 Event]

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-006
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70153832
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.