

**SYRACUSE CITY SCHOOL DISTRICT
MSAP (SHEA) SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE ID No.	TDK SAMPLE ID No.	08/05/20 RESULTS (ppb)	08/05/20 ORIGINAL ACTIONS	11/14/20 RESULTS (ppb)	11/14/20 RE- SAMPLE ACTIONS	12/30/20 RESULTS (ppb)	12/30/20 RE- SAMPLE ACTIONS	01/23/21 RESULTS (ppb)	01/23/21 RE- SAMPLE ACTIONS
Rm. 106 - Kitchen	Sink	Secured - SCSD Staff Only	019/009/003	MSAP-S115	20.0	See Note 6	15.3	See Note 6	7.2	None	---	---
Rm. 106 - Kitchen	Sink	Secured - SCSD Staff Only	024/007	MSAP-S117	46.8	See Note 6	4.8	None	---	---	---	---
Rm. 106 - Kitchen	Sink	Secured - SCSD Staff Only	026/008/002	MSAP-S118	17.3	See Note 6	177.0	See Note 6	15.2	See Note 6	4.5	None
Rm. 106 - Kitchen	Sink	Secured - SCSD Staff Only	027	MSAP-S119	19.0	See Note 7	---	---	---	---	---	---
Rm. 106 - Kitchen	Sink	Secured - SCSD Staff Only	028	MSAP-S120	3.2	None	---	---	---	---	---	---
Rm. 106E - Kitchen Bathroom	Sink	Secured - SCSD Staff Only	032	MSAP-S123	1.9	None	---	---	---	---	---	---
Rm. 110A - Office Bathroom	Sink	Secured - SCSD Staff Only	035	MSAP-S106	5.3	None	---	---	---	---	---	---
Rm. 114 - Classroom	Sink	Public Access	055/001	MSAP-S105	54.5	See Note 6	9.7	None	---	---	---	---
Rm. 116 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	040/002	MSAP-S100	26.8	See Note 6	1.4	None	---	---	---	---
Rm. 117A - Office Bathroom	Sink	Secured - SCSD Staff Only	052/004	MSAP-S103	19.8	See Note 6	5.3	None	---	---	---	---
Rm. 117A - Boy's Bathroom	Sink	Public Access	006	MSAP-S108	4.2	None	---	---	---	---	---	---
Rm. 117A - Boy's Bathroom	Sink	Public Access	007	MSAP-S109	3.1	None	---	---	---	---	---	---
Rm. 117A - Boy's Bathroom	Sink	Public Access	008	MSAP-S110	4.7	None	---	---	---	---	---	---
Rm. 117B - Girl's Bathroom	Sink	Public Access	013	MSAP-S111	4.8	None	---	---	---	---	---	---
Rm. 117B - Girl's Bathroom	Sink	Public Access	014	MSAP-S112	8.2	None	---	---	---	---	---	---
Rm. 117B - Girl's Bathroom	Sink	Public Access	016	MSAP-S113	4.1	None	---	---	---	---	---	---
Rm. 117B - Girl's Bathroom	Sink	Public Access	017	MSAP-S114	6.8	None	---	---	---	---	---	---
Rm. 118 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	050	MSAP-S102	9.2	None	---	---	---	---	---	---
Rm. 118A - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	045/003	MSAP-S101	20.1	See Note 6	2.0	None	---	---	---	---
Rm. 120 - Girl's Locker Room	Fountain	Public Access	053/001	MSAP-F101	24.6	See Note 6	175.0	See Note 6	<1.0	None	---	---
Rm. 122 - Girl's Locker Room Bathroom	Sink	Public Access	054/006	MSAP-S104	22.0	See Note 6	3.1	None	---	---	---	---
Rm. 128 - Boy's Locker Room Bathroom	Sink	Public Access	039	MSAP-S107	9.8	None	---	---	---	---	---	---
Rm. 130A - Hallway/Corridor	Fountain	Public Access	005	MSAP-F103	11.2	None	---	---	---	---	---	---
Rm. 130J - Hallway/Corridor	Fountain	Public Access	---/---/---/---	MSAP-F100	---	See Note 8	---	---	---	---	---	---
Rm. 211P - Storage Room	Sink	Secured - SCSD Staff Only	020	MSAP-S138	8.5	None	---	---	---	---	---	---
Rm. 211Q - Main Office Bathroom	Sink	Secured - SCSD Staff Only	018	MSAP-S139	7.5	None	---	---	---	---	---	---
Rm. 211R - Main Office	Sink	Secured - SCSD Staff Only	012	MSAP-S140	1.7	None	---	---	---	---	---	---
Rm. 212 - Classroom	Sink	Public Access	037	MSAP-S127	7.7	None	---	---	---	---	---	---
Rm. 212 - Classroom	Sink	Public Access	038	MSAP-S128	9.6	None	---	---	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT
MSAP (SHEA) SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE ID No.	TDK SAMPLE ID No.	08/05/20 RESULTS (ppb)	08/05/20 ORIGINAL ACTIONS	11/14/20 RESULTS (ppb)	11/14/20 RE- SAMPLE ACTIONS	12/30/20 RESULTS (ppb)	12/30/20 RE- SAMPLE ACTIONS	01/23/21 RESULTS (ppb)	01/23/21 RE- SAMPLE ACTIONS
Rm. 212 - Classroom	Sink	Public Access	---/015/004	MSAP-S129	---	See Note 7	19.7	See Note 6	2.3	None	---	---
Rm. 215 - Home & Careers Room	Sink	Public Access	036	MSAP-S124	9.8	None	---	---	---	---	---	---
Rm. 215 - Home & Careers Room	Sink	Public Access	034/016	MSAP-S125	25.4	See Note 6	13.0	None	---	---	---	---
Rm. 215 - Home & Careers Room	Sink	Public Access	033	MSAP-S126	10.3	None	---	---	---	---	---	---
Rm. 220 - Girl's Bathroom	Sink	Public Access	041	MSAP-S134	7.4	None	---	---	---	---	---	---
Rm. 220 - Girl's Bathroom	Sink	Public Access	042	MSAP-S135	11.3	None	---	---	---	---	---	---
Rm. 220 - Girl's Bathroom	Sink	Public Access	043	MSAP-S136	15.0	None	---	---	---	---	---	---
Rm. 220 - Girl's Bathroom	Sink	Public Access	044	MSAP-S137	8.6	None	---	---	---	---	---	---
Rm. 221 - Boy's Bathroom	Sink	Public Access	046	MSAP-S130	11.6	None	---	---	---	---	---	---
Rm. 221 - Boy's Bathroom	Sink	Public Access	047	MSAP-S131	13.0	None	---	---	---	---	---	---
Rm. 221 - Boy's Bathroom	Sink	Public Access	048	MSAP-S132	7.3	None	---	---	---	---	---	---
Rm. 221 - Boy's Bathroom	Sink	Public Access	049	MSAP-S133	7.9	None	---	---	---	---	---	---
Rm. 225 - Hallway/Corridor	Fountain	Public Access	051/014/005	MSAP-F104	21.4	See Note 6	22.4	See Note 6	2.1	None	---	---
Rm. 225H - Hallway/Corridor	Fountain	Public Access	029/010/006	MSAP-F107	41.9	See Note 6	27.9	See Note 6	1.3	None	---	---
Rm. 225J - Hallway/Vestibule	Fountain	Public Access	031	MSAP-F106	10.8	None	---	---	---	---	---	---
Rm. 225N - Hallway/Corridor	Fountain	Public Access	001	MSAP-F105	8.1	None	---	---	---	---	---	---
Rm. 227 - Work Room	Sink	Secured - SCSD Staff Only	015/012	MSAP-S146	44.4	See Note 6	1.3	None	---	---	---	---
Rm. 233 - Health Service Bathroom	Sink	Public Access	002/013	MSAP-S144	17.7	See Note 6	5.5	None	---	---	---	---
Rm. 235 - Principal's Office	Sink	Secured - SCSD Staff Only	011	MSAP-S141	10.0	None	---	---	---	---	---	---
Rm. 237 - Nurse's Office	Sink	Public Access	004	MSAP-S145	9.7	None	---	---	---	---	---	---
Rm. 238 - Exam Room	Sink	Public Access	003	MSAP-S143	5.1	None	---	---	---	---	---	---
Rm. 239 - Conference Room	Sink	Secured - SCSD Staff Only	010	MSAP-S142	2.9	None	---	---	---	---	---	---
Rm. 239 - Girl's Bathroom	Sink	Public Access	021/011	MSAP-S147	41.0	See Note 6	4.1	None	---	---	---	---
Rm. 239 - Girl's Bathroom	Sink	Public Access	023	MSAP-S148	9.3	None	---	---	---	---	---	---
Rm. 240 - Boy's Bathroom	Sink	Public Access	025	MSAP-S149	3.4	None	---	---	---	---	---	---
Rm. 245 - Clinic Office	Sink	Public Access	030	MSAP-S150	1.8	None	---	---	---	---	---	---
Rm. 232 - Waiting Room	Sink	Public Access	009	MSAP-S3000	11.7	None	---	---	---	---	---	---
Rm. 106 - Kitchen	Convotherm (Oven)	Secured - SCSD Staff Only	022	MSAP-C1000	7.1	None	---	---	---	---	---	---

SYRACUSE CITY SCHOOL DISTRICT

MSAP (SHEA) SCHOOL

Original Sample Notes [August 5, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-033
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70141092
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed, replaced and resampled.
7. Fixture remediation and resampling required.
8. Fixture not operating.

Re-Sample Notes [November 14, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-033
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70153830
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Remediation performed by SCSD.
7. Fixture not operating.

Re-Sample Notes [December 30, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-033
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70158344
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Remediation performed by SCSD.

Re-Sample Notes [January 23, 2021 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-033
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70160644
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Remediation performed by SCSD.