

**SYRACUSE CITY SCHOOL DISTRICT
VAN DUYN ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	06/24/2020 ORIGINAL RESULTS (ppb)	06/24/2020 ORIGINAL ACTIONS	10/10/2020 RE-SAMPLE RESULTS (ppb)	10/10/2020 RE-SAMPLE ACTIONS
Rm. 001 - Cafeteria	Fountain	Public Access	014	VN-F100	<1.0	None	--	--
Rm. 001 - Cafeteria	Fountain	Public Access	015	VN-F101	<1.0	None	--	--
Rm. B10A - Receiving Room Bathroom	Sink	Secured - SCSD Staff Only	012	VN-S100	10.9	None	--	--
Rm. 0B8 - Kitchen	Sink	Secured - SCSD Staff Only	001	VN-S101	1.1	None	--	--
Rm. 0B8 - Kitchen	Sink	Secured - SCSD Staff Only	002	VN-S102	1.4	None	--	--
Rm. 0B8 - Kitchen	Sink	Secured - SCSD Staff Only	003	VN-S103	1.5	None	--	--
Rm. 0B8 - Kitchen	Sink	Secured - SCSD Staff Only	006	VN-S104	1.8	None	--	--
Rm. 031 - Hallway/Corridor	Fountain	Public Access	019	VN-F102	<1.0	None	--	--
Rm. 0B1A - Hallway/Vestibule	Sink	Public Access	020	VN-S105	11.5	None	--	--
Rm. 0B1A - Hallway/Vestibule	Sink	Public Access	021	VN-S106	<1.0	None	--	--
Rm. 0B1A - Hallway/Vestibule	Sink	Public Access	023	VN-S107	<1.0	None	--	--
Rm. 0B1A - Hallway/Vestibule	Sink	Public Access	024	VN-S108	3.8	None	--	--
Rm. 005 - Classroom	Sink	Public Access	055	VN-S109	<1.0	None	--	--
Rm. 010A - Office	Sink	Secured - SCSD Staff Only	054	VN-S110	2.0	None	--	--
Rm. 134 - Classroom	Sink	Public Access	058	VN-S111	4.3	None	--	--
Rm. 100M - Hallway/Corridor	Fountain	Public Access	064	VN-F103	<1.0	None	--	--
Rm. 132 - Classroom	Sink	Public Access	067	VN-S112	<1.0	None	--	--
Rm. 135 - Classroom	Sink	Public Access	063	VN-S113	1.5	None	--	--
Rm. 133 - Classroom	Sink	Public Access	065	VN-S114	<1.0	None	--	--
Rm. 128 - Classroom	Sink	Public Access	077	VN-S115A	1.7	None	--	--
Rm. 129 - Classroom	Sink	Public Access	074	VN-S115B	<1.0	None	--	--
Rm. 123 - Classroom	Sink	Public Access	070	VN-S117	2.5	None	--	--
Rm. 123 - Classroom	Fountain	Public Access	071	VN-F104	<1.0	None	--	--
Rm. 120 - Classroom	Sink	Public Access	072	VN-S118	3.1	None	--	--
Rm. 120A - Classroom Bathroom	Sink	Public Access	073	VN-S119	9.1	None	--	--
Rm. 109 - Nurse's Room	Sink	Public Access	057	VN-S120	3.7	None	--	--
Rm. 109B - Nurse's Bathroom	Sink	Public Access	059	VN-S121	1.6	None	--	--
Rm. 117 - Classroom	Sink	Public Access	069	VN-S122	2.1	None	--	--
Rm. 109A - Exam Room	Sink	Public Access	060	VN-S123	3.9	None	--	--
Rm. 115A - Staff Bathroom	Sink	Secured - SCSD Staff Only	075	VN-S124	2.3	None	--	--
Rm. 115B - Staff Bathroom	Sink	Secured - SCSD Staff Only	076	VN-S125	6.3	None	--	--

**SYRACUSE CITY SCHOOL DISTRICT
VAN DUYN ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	06/24/2020 ORIGINAL RESULTS (ppb)	06/24/2020 ORIGINAL ACTIONS	10/10/2020 RE-SAMPLE RESULTS (ppb)	10/10/2020 RE-SAMPLE ACTIONS
Rm. 119D - Work Room	Sink	Secured - SCSD Staff Only	078	VN-S126	3.9	None	--	--
Rm. 115E - Lounge Kitchenette	Sink	Secured - SCSD Staff Only	079	VN-S127	1.8	None	--	--
Rm. 0A8 - Hallway/Corridor	Fountain	Public Access	027	VN-F200	<1.0	None	--	--
Rm. 023 - Classroom	Sink	Public Access	038	VN-S201	2.2	None	--	--
Rm. 023 - Classroom	Sink	Public Access	037	VN-S202	2.6	None	--	--
Rm. 023A - Classroom	Sink	Public Access	039	VN-S203	1.8	None	--	--
Rm. 023A - Classroom	Sink	Public Access	040	VN-S204	1.3	None	--	--
Rm. 021 - Kitchen Room	Sink	Secured - SCSD Staff Only	030	VN-S205	1.6	None	--	--
Rm. 020A - Classroom	Sink	Public Access	032	VN-S206	<1.0	None	--	--
Rm. 020A - Classroom	Sink	Public Access	033	VN-S207	<1.0	None	--	--
Rm. 024 - Classroom	Sink	Public Access	044	VN-S208	1.4	None	--	--
Rm. 024 - Classroom	Sink	Public Access	045	VN-S209	1.7	None	--	--
Rm. 022 - Classroom	Sink	Public Access	041	VN-S210	2.0	None	--	--
Rm. 022 - Classroom	Sink	Public Access	042	VN-S211	<1.0	None	--	--
Rm. 015 - Art Room	Sink	Public Access	047	VN-S212	1.4	None	--	--
Rm. 015 - Art Room	Sink	Public Access	049	VN-S213	2.8	None	--	--
Rm. 023A - Staff's Bathroom	Sink	Secured - SCSD Staff Only	051/002	VN-S214	26.7	See Note 6.	<1.0	None
Rm. 018A - Staff Resource Bathroom	Sink	Public Access	026	VN-S215	5.0	None	--	--
Rm. 100P - Hallway/Corridor	Fountain	Public Access	050	VN-F201	<1.0	None	--	--
Rm. 102A - Boy's Locker Room	Sink	Public Access	052	VN-S216	7.9	None	--	--
Rm. 104A - Girl's Locker Room	Sink	Public Access	053	VN-S217	7.0	None	--	--
Rm. 103 - Gym	Fountain	Public Access	043	VN-F202	2.8	None	--	--
Rm. 103 - Gym	Fountain	Public Access	046	VN-F203	<1.0	None	--	--
Rm. 103D - Gym Office Bathroom	Sink	Secured - SCSD Staff Only	048	VN-S218	6.6	None	--	--
Rm. 108 - Classroom	Sink	Public Access	056	VN-S219	1.8	None	--	--
Rm. 110 - Classroom	Sink	Public Access	061	VN-S220	1.3	None	--	--
Rm. 111 - Classroom	Sink	Public Access	062	VN-S221	<1.0	None	--	--
Rm. 113 - Office	Sink	Secured - SCSD Staff Only	066	VN-S222	<1.0	None	--	--
Rm. 113C - Principal's Bathroom	Sink	Secured - SCSD Staff Only	068	VN-S223	5.3	None	--	--
Rm. 230 - Hallway/Corridor	Fountain	Public Access	009	VN-F301	<1.0	None	--	--
Rm. 230A - Girl's Bathroom	Sink	Public Access	004	VN-S301	7.4	None	--	--

**SYRACUSE CITY SCHOOL DISTRICT
VAN DUYN ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	06/24/2020 ORIGINAL RESULTS (ppb)	06/24/2020 ORIGINAL ACTIONS	10/10/2020 RE-SAMPLE RESULTS (ppb)	10/10/2020 RE-SAMPLE ACTIONS
Rm. 230A - Girl's Bathroom	Sink	Public Access	005	VN-S302	4.1	None	--	--
Rm. 230A - Girl's Bathroom	Sink	Public Access	007	VN-S303	5.8	None	--	--
Rm. 230B - Boy's Bathroom	Sink	Public Access	010	VN-S304	<1.0	None	--	--
Rm. 230B - Boy's Bathroom	Sink	Public Access	011	VN-S305	9.2	None	--	--
Rm. 230B - Boy's Bathroom	Sink	Public Access	013	VN-S306	9.5	None	--	--
Rm. 207 - Teacher Resource	Sink	Secured - SCSD Staff Only	016	VN-S307	6.5	None	--	--
Rm. 221 - Staff Bathroom	Sink	Secured - SCSD Staff Only	025	VN-S308	2.2	None	--	--
Rm. 231 - Hallway/Corridor	Fountain	Public Access	080	VN-F302	<1.0	None	--	--
Rm. 231B - Boy's Bathroom	Sink	Public Access	029	VN-S309	8.5	None	--	--
Rm. 231B - Boy's Bathroom	Sink	Public Access	028	VN-S310	3.1	None	--	--
Rm. 231B - Boy's Bathroom	Sink	Public Access	031	VN-S311	<1.0	None	--	--
Rm. 231A - Girl's Bathroom	Sink	Public Access	034	VN-S312	1.4	None	--	--
Rm. 231A - Girl's Bathroom	Sink	Public Access	035	VN-S313	9.2	None	--	--
Rm. 231A - Girl's Bathroom	Sink	Public Access	036	VN-S314	9.1	None	--	--
Rm. 227A - Laboratory	Sink	Public Access	017	VN-S315	<1.0	None	--	--
Rm. 227A - Laboratory	Sink	Public Access	018	VN-S316	1.3	None	--	--
Rm. 0B8 - Kitchen	Convotherm Oven Sprayer	Secured - SCSD Staff Only	008/001	VN-C1000	24.9	See Note 7.	7.8	None
Rm. 227F - Work Room	Sink	Public Access	022	VN-S3000	6.7	None	--	--

Original Sample Notes: [June 24, 2020 Event]

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-014
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70136225
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed, replaced and resampled.
7. In-line filter installed by SCSD and resampling performed.

Re-Sample Notes: [October 10, 2020 Event]

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-014
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70149564
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.