

**SYRACUSE CITY SCHOOL DISTRICT
WEBSTER ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE ID No.	TDK SAMPLE ID No.	02/25/20 RESULTS (ppb)	02/25/20 ORIGINAL ACTIONS	03/07/20 RESULTS (ppb)	03/07/20 RE- SAMPLE ACTIONS	11/04/20 RESULTS (ppb)	11/04/20 RE- SAMPLE ACTIONS	12/30/20 RESULTS (ppb)	12/30/20 RE- SAMPLE ACTIONS
Rm. 002A - Gym Office Bathroom	Sink	Secured - SCSD Staff Only	005	W-S136	3.8	None	---	---	---	---	---	---
Rm. 011A - Staff Bathroom	Sink	Secured - SCSD Staff Only	014	W-S141	1.6	None	---	---	---	---	---	---
Rm. 012A - Classroom (012) Bathroom	Sink	Public Access	017	W-S137	1.1	None	---	---	---	---	---	---
Rm. 021 - Hallway/Corridor	Fountain	Public Access	002	W-F107	<1.0	None	---	---	---	---	---	---
Rm. 100D - Hallway/Corridor	Fountain	Public Access	008	W-F101	<1.0	None	---	---	---	---	---	---
Rm. 100D - Hallway/Corridor	Fountain	Public Access	006	W-F102	<1.0	None	---	---	---	---	---	---
Rm. 100Q - Hallway/Corridor	Fountain	Public Access	020	W-F100	1.0	None	---	---	---	---	---	---
Rm. 100T - Hallway/Corridor	Fountain	Public Access	034	W-F104	2.0	None	---	---	---	---	---	---
Rm. 110 - Hallway/Vestibule	Sink	Public Access	040	W-S128	1.0	None	---	---	---	---	---	---
Rm. 110 - Hallway/Vestibule	Sink	Public Access	038	W-S129	<1.0	None	---	---	---	---	---	---
Rm. 110 - Hallway/Vestibule	Sink	Public Access	039	W-S130	<1.0	None	---	---	---	---	---	---
Rm. 110 - Hallway/Vestibule	Fountain	Public Access	037	W-F105	1.8	None	---	---	---	---	---	---
Rm. 110 - Art Classroom	Sink	Public Access	045	W-S122	3.4	None	---	---	---	---	---	---
Rm. 110 - Art Classroom	Sink	Public Access	046	W-S123	1.1	None	---	---	---	---	---	---
Rm. 111 - Staff Bathroom	Sink	Secured - SCSD Staff Only	043	W-S127	2.4	None	---	---	---	---	---	---
Rm. 114 - Hallway/Vestibule	Sink	Public Access	013	W-S138	<1.0	None	---	---	---	---	---	---
Rm. 114 - Hallway/Vestibule	Sink	Public Access	012	W-S139	<1.0	None	---	---	---	---	---	---
Rm. 114 - Hallway/Vestibule	Sink	Public Access	011	W-S140	<1.0	None	---	---	---	---	---	---
Rm. 114 - Hallway/Vestibule	Fountain	Public Access	007	W-F108	1.3	None	---	---	---	---	---	---
Rm. 114A - Nurse's Office Exam Room	Sink	Public Access	047	W-S121	2.2	None	---	---	---	---	---	---
Rm. 114B - Nurse's Office Bathroom	Sink	Public Access	048	W-S120	<1.0	None	---	---	---	---	---	---
Rm. 118A - Library Office	Sink	Secured - SCSD Staff Only	044	W-S119	3.5	None	---	---	---	---	---	---
Rm. 137 - Classroom Bathroom	Sink	Public Access	015	W-S105	2.8	None	---	---	---	---	---	---
Rm. 139 - Classroom	Sink	Public Access	016	W-S104	8.5	None	---	---	---	---	---	---
Rm. 140 - Classroom	Sink	Public Access	018	W-S103	1.3	None	---	---	---	---	---	---
Rm. 144 - Classroom	Fountain	Public Access	031	W-F103	3.1	None	---	---	---	---	---	---
Rm. 144B - Classroom (144) Bathroom	Sink	Public Access	032	W-S116	1.3	None	---	---	---	---	---	---
Rm. 145 - Classroom	Sink	Public Access	033	W-S115	2.4	None	---	---	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT
WEBSTER ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE ID No.	TDK SAMPLE ID No.	02/25/20 SAMPLE RESULTS (ppb)	02/25/20 ORIGINAL ACTIONS	03/07/20 RESULTS (ppb)	03/07/20 RE- SAMPLE ACTIONS	11/04/20 RESULTS (ppb)	11/04/20 RE- SAMPLE ACTIONS	12/30/20 RESULTS (ppb)	12/30/20 RE- SAMPLE ACTIONS
Rm. 149 - Girl's Bathroom	Sink	Public Access	--- / 001	--- / W-S106	---	Fixture Not Operating	---	---	20.4	See Note 6	<1.0	None
Rm. 149 - Girl's Bathroom	Sink	Public Access	010	W-S107	<1.0	None	---	---	---	---	---	---
Rm. 149 - Girl's Bathroom	Sink	Public Access	009	W-S108	<1.0	None	---	---	---	---	---	---
Rm. 150 - Boy's Bathroom	Sink	Public Access	004	W-S109	1.1	None	---	---	---	---	---	---
Rm. 150 - Boy's Bathroom	Sink	Public Access	003	W-S110	1.8	None	---	---	---	---	---	---
Rm. 150 - Boy's Bathroom	Sink	Public Access	001	W-S111	2.4	None	---	---	---	---	---	---
Rm. 151 - Staff Bathroom	Sink	Secured - SCSD Staff Only	029	W-S113	2.4	None	---	---	---	---	---	---
Rm. 152A - Kitchen	Sink	Secured - SCSD Staff Only	026	W-S100	3.5	None	---	---	---	---	---	---
Rm. 152A - Kitchen	Sink	Secured - SCSD Staff Only	025	W-S101	<1.0	None	---	---	---	---	---	---
Rm. 152A - Kitchen	Sink	Secured - SCSD Staff Only	023	W-S102	<1.0	None	---	---	---	---	---	---
Rm. 152A - Kitchen	Cooker Spray	Secured - SCSD Staff Only	027 / 004	W-C100 / W-C100R	77.1	See Note 6	11.7	None	--	--	--	--
Rm. 155 - Classroom (145) Bathroom	Sink	Public Access	035	W-S114	<1.0	None	---	---	---	---	---	---
Rm. 157 - Staff Bathroom (Men's)	Sink	Secured - SCSD Staff Only	041	W-S117	2.6	None	---	---	---	---	---	---
Rm. 158 - Staff Bathroom (Women's)	Sink	Secured - SCSD Staff Only	042	W-S118	2.6	None	---	---	---	---	---	---
Rm. 159 - Staff Bathroom	Sink	Secured - SCSD Staff Only	036	W-S112	3.3	None	---	---	---	---	---	---
Rm. 178 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	--- / 001	--- / W-S124	---	See Note 7	1.9	None	--	--	--	--
Rm. 180A - Staff Bathroom (Men's)	Sink	Secured - SCSD Staff Only	--- / 003	--- / W-S125	---	See Note 7	3.2	None	--	--	--	--
Rm. 180C - Staff Bathroom (Women's)	Sink	Secured - SCSD Staff Only	--- / 002	--- / W-S126	---	See Note 7	3.3	None	--	--	--	--
Rm. 210D - Staff Bathroom (Men's)	Sink	Secured - SCSD Staff Only	030	W-S131	<1.0	None	---	---	---	---	---	---
Rm. 210E - Staff Bathroom (Women's)	Sink	Secured - SCSD Staff Only	028	W-S132	1.6	None	---	---	---	---	---	---
Rm. 211 - Hallway/Vestibule	Sink	Public Access	024	W-S133	1.3	None	---	---	---	---	---	---
Rm. 211 - Hallway/Vestibule	Sink	Public Access	022	W-S134	<1.0	None	---	---	---	---	---	---
Rm. 211 - Hallway/Vestibule	Sink	Public Access	021	W-S135	<1.0	None	---	---	---	---	---	---
Rm. 211 - Hallway/Vestibule	Fountain	Public Access	019	W-F106	<1.0	None	---	---	---	---	---	---

SYRACUSE CITY SCHOOL DISTRICT

WEBSTER ELEMENTARY SCHOOL

Original Sample Notes: [February 25, 2020 Event]

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-003
2. Water samples analyzed By: Pace Analytical Services - Pace Project No. 70123138
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. In-line lead filter installed by SCSD and resampling performed.
7. Fixture sampled on 03/07/20.

Re-Sample Notes: [March 7, 2020 Event]

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-003
2. Water samples analyzed By: Pace Analytical Services - Pace Project No. 70124732
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.

Re-Sample Notes: [November 4, 2020 Event]

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-003
2. Water samples analyzed By: Pace Analytical Services - Pace Project No. 70152548
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Filter installed by SCSD and resampling performed.

Re-Sample Notes: [December 30, 2020 Event]

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-003
2. Water samples analyzed By: Pace Analytical Services - Pace Project No. 70158338
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.